

August 29, 2023

Attention: Sydney Haen
API HEAT TRANSFER
BASCO DIVISION
2777 WALDEN AVENUE
BUFFALO, NY 14225

The design submission, Tracking Number 2023-04892, Web Portal Number 2023-S3125, originally received on August 11, 2023 was surveyed and accepted for registration as follows:

CRN : Z9478.2 **Accepted on:** August 29, 2023
Reg Type: NEW DESIGN
Drawing No. : 1452-08-168-001 Rev 3 As Noted

Description	MAWP	Design Temperature	MDMT
SS Internal Pressure	3103kPa	121 °C	-29 °C
TS Internal Pressure	1034kPa	121 °C	-29 °C


The registration is conditional on your compliance with the following notes:

As per the calculation the registration is given based on the understanding that tubes expansion depth ratio is 0.95.

An invoice covering survey and registration fees will be forwarded from our Revenue Accounts.

If you have any question don't hesitate to contact me by phone at (780) 433-0281 ext 3310 or fax (780) 437-7787 or e-mail Onshchenko@absa.ca.

Sincerely,



ONSHCHENKO, TETYANA, P. Eng.
DOP Cert. No. D00010125