

November 21, 2023

Attention: Cecylia Garbacz
TECHNICAL STANDARDS & SAFETY AUTHORITY
345 CARLINGVIEW DRIVE
TORONTO, ON M9W 6N9

The design submission, Tracking Number 2023-06587, Web Portal Number 2023-S4394, originally received on October 27, 2023 was surveyed and accepted for registration as follows:

CRN : R9573.52 **Accepted on:** November 21, 2023

Reg Type: NEW DESIGN

Drawing No. : CT-1086 & CT-1087 Rev A/A

Design registered in the name of : COLUMBIA BOILER COMPANY

Description	MAWP	Design Temperature
MAWP	1034kPa	185 °C

The registration is conditional on your compliance with the following notes:

- Registration is accepted on the basis that the design is as per ASME Section I, 2021 edition.
- Design is registered with the understanding that the stay bolts are 1in OD, SA-36.

An invoice covering survey and registration fees will be forwarded from our Revenue Accounts.

If you have any question don't hesitate to contact me by phone at (403) 291-7070 ext 2239 or fax (403) 291-4545 or e-mail LakeA@absa.ca.

Sincerely,



LAKE, ANITA, P. Eng.
DOP Cert. No. D00010563