

REGISTRATION OF A BOILER OR PRESSURE VESSEL DESIGN

21-Nov-23

Round Engineering Inc.
10 Segwun Rd.
Waterdown, Ontario
L8B 0K6

Attention: Scott Islip

File Number: 63839 [0V]

Re: Manufacturer: API Heat Transfer
Item: Air Aftercooler
Drawing Number: 1510-06-036-042 Rev. 2

TSASK Codes and Standards Compliance has registered the design listed above in accordance with The Boiler and Pressure Vessel Act and Regulations. The Canadian Registration Number (CRN) is:

C3579.3

This item was registered with the following design conditions:

MAWP: 2068 kPa	Design Temp: 149 °C
MDMT: -7 °C	Corrosion Allowance: 0 mm

Please note that every piece of equipment must be constructed in strict accordance with the registered design.

In addition to stamping every unit with the CRN given, and as required in CSA B51, a Manufacturer's Data Report shall be forwarded to this office at the time the unit is shipped. The Manufacturer's Data Report form is available on the TSASK website at www.tsask.ca.

Should you require anything further, please do not hesitate to contact the Codes and Standards Compliance Office at your convenience.

Yours truly,



Williams Uju, P.Eng.
Codes and Standards Compliance

Remarks:

As per the drawing, the conditions listed in U-2(a)(2)(a) are not applicable. Therefore, this design has been registered without a User's Design Requirements form.

The heat exchanger shall be marked with a caution as per UHX-19.2.2.