



345 Carlingview Drive
Toronto, Ontario M9W 6N9
Tel.: 416.734.3300
Fax: 416.231.1626
Toll Free: 1.877.682.8772

www.tssa.org

October 25, 2017

ERIK SCHULTZ
COLUMBIA BOILER COMPANY
390 OLD READING PIKE
POTTSTOWN PA 19464
US

Service Request Type: BPV-Boiler Registration
Service Request No.: 2174586
Your Reference No.:
Registered to: COLUMBIA BOILER COMPANY

Dear ERIK SCHULTZ,

Technical Standards and Safety Authority (TSSA) is pleased to inform you that your submission has been reviewed and registered as follows:

CRN No.: E1332.65

Main Design No.: CT-785 REV A with following conditions (marked up on the drawing):

- Weld joints of Burner Tube to Shell/Combustion Chamber shall be full penetration with 3/8" fillet welds.

A stamped copy of the approved registration and invoice for engineering services will be sent to you shortly. Should you have any questions or require further assistance, however, please contact a Customer Service Advisor at 1.877.682.TSSA (8772) or e-mail customerservices@tssa.org. We will be happy to assist you. When contacting TSSA regarding this file, please refer to the Service Request number provided above.

Yours truly,

Zivko Gacevic P. Eng.
Mechanical Engineer, BPV
Tel.: 416-734-3429
Fax: 416-231-6183
Email: zgacevic@tssa.org