


UNIFORM STATUTORY DECLARATION FORM FOR THE REGISTRATION OF FITTING DESIGNS

New Brunswick
Nunavut

Nova Scotia
Yukon

Prince Edward Island
Northwest Territories

Newfoundland and Labrador

Manufacturers Name: Ebro - Armaturen Gebr. Broer GmbH	
Manufacturers Address: Karlstr. 8, 58135 Hagen, Germany	
Plant Locations: Karlstr. 8, 58135 Hagen, Germany	
<p align="center">Category of Fittings to be registered. Circle one Category only</p> <p>A Pipe fittings, including couplings, tees, elbows, Ys, plugs, unions, pipe caps, or reducers B Flanges: all flanges <input checked="" type="radio"/> C Valves: all line valves D Expansion joints, flexible connections, and hose assemblies: all types E Strainers, filters, separators, and steam traps F Measuring devices, including pressure gauges, level gauges, sight glasses, levels, or pressure transmitters G Certified capacity-rated pressure relief devices acceptable as primary over pressure protection on boilers, pressure vessels, piping and fusible plugs H Pressure retaining components that do not fall into one of the above categories N Nuclear components: Class 1 <input type="checkbox"/> Class 2 <input type="checkbox"/> Class 3 <input type="checkbox"/> , (Meeting CNSC or ASME requirements)</p>	<p align="center">Title of the Standard of Construction</p> <p align="center">- ASME B31.3</p>
<p>Show Manufacturers Name, Trademark, or Logo as it will appear on the product</p> <div align="center">  </div>	<p align="center">Type of Construction</p> <p>Forged <input type="checkbox"/> Welded <input type="checkbox"/> Wrought <input type="checkbox"/> Cast <input checked="" type="checkbox"/> Other <input type="checkbox"/> Describe other:</p>
<p>List of supporting documentation and identification of the actual items to be registered:</p> <p>- Butterfly Valve Report containing Drawings and Calculations, Scope of CRN</p>	

Declaration:

I, Mr. Andreas Kohlscheen, Head of R&D Valve Technology (see note 3) employed by Ebro - Armaturen Gebr. Broer GmbH and being the person having full authority and responsibility for the quality of the end product do solemnly declare that the information contained in this form is true to the best of my knowledge represents the product for which registration is sought. The dimensions, materials of construction, pressure temperature ratings, and identification markings are in accordance with the herein named standards. I further declare that the manufacture of these fittings is regulated by a Quality Control Program which extends to each plant where fabrication occurs in whole or in part and has been verified by TUV ISO 9001: 2015 as being suitable for that purpose and I make this solemn declaration conscientiously believing it to be true, and knowing that it is of the same force and effect as if made under oath.

Signature of Declarer: 


Declared before me at _____

This _____ day of _____ AD _____

Commissioner of Oaths

Or Notary Public: (sign) _____

(Affix Official seal to the right)




**DEPT OF JUSTICE PUBLIC SAFETY
BOILER & PRESSURE VESSEL ACT**

This space for Regulatory Authority use. **REGISTRATION ONLY**

This registration must be revalidated after ten (10) years from the date of acceptance.

CRN OC 3473.7


CHIEF BOILER INSPECTOR

DATE 4/5/24

BLRs PVs Sect 1.0 - Fittings Rev.2

FITTINGS NUCLEAR COMPONENTS

CRN: OC3473.7

FID#: 2750

Notes:

- All Fittings shall be registered in the name of the Manufacturer.
- Each Category shall be supported with two Statutory Declaration forms and one copy of supporting documentation.
- The Declaration shall be made by the person having full authority and responsibility for the quality of the end product.
- Quality Control programs shall be resubmitted for validation.

11/2016

ACI Central Inc.

20 McAulay Court
Charlottetown, PE C1A 9M7
Canada

Data Information - Pressure Fitting Design

CRN 0C3473.7

Manufacturer: EBRO-Armaturen Gerb. Broer GmbH

FID/PV: FID-2750

Trademark: 'EBRO' within an oval shape, within a larger circle shape, with 'ARMATUREN' to the right.

Description: HP111, HP114 butterfly valves. Note: valves are identical in construction to the CRN registered valves 0C6516.5 Rev.2

Design code: ASME B31.3

Registration date: 04/05/2024

Expiry date: 04/05/2034

Pressure Rating	Type	Size	Material
20bar @ 38C to 13.8bar @ 200C (290psi @ 100F to 200psi @ 392F) -10C/14F MDMT	HP111 (wafer), HP114 (lug)	2" to 24" Cl.150	Duplex SS GX2CrNiMoN26-7-4 1.4469 stress value is calculated in accordance with ASME Sec.II Part D, Appendix 1