



TECHNICAL STANDARDS &
SAFETY AUTHORITY
14th Floor, Centre Tower
3300 Bloor Street West
Toronto, Ontario
Canada M8X 2X4

Show facsimile of manufacturer's logo or trademark, as it will appear on the fitting, in the space below

"Apollo"[®]

STATUTORY DECLARATION Registration of Fittings

I, CHAD NICOLAY, ENGINEER
(Name and Position, e.g. President, Plant Manager, Chief Engineer)

of CONBRACO INDUSTRIES, INC.
(Name of Manufacturer)

Located at 1418 S. PEARL STREET, PAGELAND, SC 29728 (843) 672-6161 (843) 672-1556
(Plant Address) (Telephone No.) (Fax No.)

do solemnly declare that the fittings listed hereunder, which are subject to the **Technical Standards and Safety Act**, Boilers and Pressure Vessels Regulation, comply with all of the requirements of B16.34

(Title of recognized North American Standard)

which specifies the dimensions, materials of construction, pressure/temperature ratings, identification marking the fittings and service;

or are not covered by the provisions of a recognized North American standard and are therefore manufactured to comply with _____ as supported by the attached data which identifies the dimensions, material of construction, pressure/temperature ratings and the basis for such ratings, the marking of the fitting for identification and service.

I further declare that the manufacture of these fittings is controlled by a quality system meeting the requirements of _____ ISO 9001:2000 which has been verified by the following authority, TUV RHEINLAND OF NORTH AMERICA.

The items covered by this declaration, for which I seek registration, are category C type fittings. In support of this application, the following information and/or test data are attached as follows:

PRODUCT DOCUMENTATION (DRAWINGS & CALCULATIONS), ISO 9001:2000 CERTIFICATE

(drawings, calculations, test reports, etc.)


Declared before me at Pageland in the state of South Carolina
the 20th day of August AD 2015.

Commissioner for Oaths:

Nancy Strawn
(Printed name)

Nancy Strawn
(Signature)

Carl Hugg
(Signature of Declarer)



FOR OFFICE USE ONLY

To the best of my knowledge and belief, the application meets the requirements of the **Technical Standards and Safety Act**, Boilers and Pressure Vessels Regulation, and CSA Standard B51 and is accepted for registration in Category C.

CRN: OC109085R7

Registered by: K. Kei

Dated: Dec 4/15

NOTE: This registration expires on: Dec 4/2025

Technical Standards and Safety Authority
Boilers and Pressure Vessels Safety Program

REGISTERED

CRN: OC109085R7

K. Kei

Dec 4/15

See one sheet of attachment for scope. KK
12/4/15



Apollo Flanged Ball Valves			
Valve Series	Material	Technical File	ASME Standard
87A	A351-CF8M (S. Steel)	ES1092A, B	B16.34
87C	A351-CN7M (Alloy 20)		
87G	A479-316/316L (S. Steel)		
87H	A494-CW12MW (Hastelloy C)		
87J	CD3MN (2205 Duplex)		
87K	CD3MWCuN (2507 Super Duplex)		
87M	A494-M35-1 (Monel)		
88A	A216-WCB (C. Steel)		
88L	A352-LCC (C. Steel)		

Available Sizes (150#/300#)	
SP	FP
1/2"	
3/4"	
1"	
1.5"	
2"	
2.5"	
3"	
4"	
6"	
8"	
10"	
12"	

Available Sizes 600#	
SP	FP
1"	
1.5"	
2"	
2.5"	
3"	
4"	
6"	
8"	
10"	
12"	

Apollo Industrial 3-Piece Ball Valves			
Valve Series	Material	Technical File	ASME Standard
83B	A216-WCB (C. Steel)	ES1394	B16.34
83L	A352-LCC (C. Steel)		
86B	A351-CF8M (S. Steel)		
86C	A351-CN7M (Alloy 20)		
86D	A494-CW12MW (Hastelloy C)		
86E	A494-M35-1 (Monel)		
86G	A479-316/316L (S. Steel)		
86J	CD3MN (2205 Duplex)		
86K	CD3MWCuN (2507 Super Duplex)		

Available Sizes			
Size	NPT	Socket	Butt Weld
1/4"			
1/2"			
3/4"			
1"			
1.5"			
2"			

Apollo Top Entry Ball Valves			
Valve Series	Material	Technical File	ASME Standard
A	A351-CN7M (Alloy 20)	ES1093	B16.34
B	A351-CF3M (S. Steel)		
C	A216-WCB (C. Steel)		
G	A351-CG8M (S. Steel)		
H	A494-CW12MW (HASTELLOY C)		
J	CD3MN (DUPLEX 2205)		
K	CD3MWCuN (SUPER DUPLEX 2507)		
L	A352-LCC (C. Steel)		
M	A494-M35-1 (Monel)		
P	A217-C12 (Alloy Steel)		
R	A351-CN3MN (AL-6XN)		
S	A351-CF8M (S. Steel)		
W	A351-CK3MCuM (254 SMO)		
Y	A494 N-12MV (HASTELLOY B)		

Available Sizes (150/300)	
SP	FP
3/4"	
1"	
1.5"	
2"	
2.5"	
3"	
4"	
6"	
8"	
10"	

Available Sizes 600#	
SP	FP
1"	
1.5"	
2"	
2.5"	
3"	
4"	
6"	
8"	

THIS IS PART OF
 CRN OC10908.SR7
 Technical Standards & Safety Authority
 Boilers & Pressure Vessels
 Safety Program