



**STATUTORY DECLARATION
Registration of Fittings**

In this space, show facsimile of manufacturer's logo or trademark as it will appear on the fitting.

COLTON

I, KEVIN FANE,
PRESIDENT

(company title, e.g. vice president, plant manager, chief engineer) (must be in a position of authority)

of COLTON INDUSTRIES

(name of manufacturer)

located at 40 CORSTATE AVE., VAUGHAN, ONTARIO, CANADA, L4K 4X2

(plant address)

do solemnly declare that the fittings listed hereunder, which are subject to the Safety Codes Act (check one)

☒ comply with the requirements of ASME B16.34, B16.5, ASME VIII-1 which specifies the dimensions,
(title of recognized North American Standard)

materials of construction, pressure/temperature ratings and identification marking of the fittings, or

☐ are not covered by the provisions of a recognized North American standard and are therefore manufactured to comply with _____ as supported by the attached data which identifies the dimensions, materials of construction, pressure/temperature ratings and the basis for such ratings, and the marking of the fittings for identification.

I further declare that the manufacture of these fittings is controlled by a quality control program which has been verified by the following authority, QAS INTERNATIONAL as being suitable for the manufacture of these fittings to the stated standard. The fittings covered by this declaration, for which I seek registration, are CAT E Y-STRAINERS

In support of this application, the following information, calculations and/or test data are attached:

SCOPE OF CRN, DRAWINGS, DESIGN CALCULATIONS

DECLARED before me at Vaughan in the municipality of York
this 25 day of June, 2015
(Month) (Year)
(print) Kyle Armagon
(sign) [Signature]
(A Commissioner for Oaths) (Signature of Applicant)

For Office Use Only

To the best of my knowledge and belief, the application meets the requirements of the Safety Codes Act and CSA Standard B51, Clause 4.2, and is accepted for registration in Category E

Registration Number: OE16011.2

Date Registered: AUG 12 2015

(For the Administrator/Chief Inspector of Alberta)

Expiry Date: August 12, 2025

COLTON INDUSTRIES

40 CORSTATE AVENUE

VAUGHAN, ONTARIO

L4K 4X2, CANADA

17-Jul-15

SCOPE OF CRN REGISTRATION

Product Description	Colton Drawing No.	Part Number	Material Specification	Design Code	Size Range	ANSI Class	End Connection	MAP at 100 F	MAWP at MAWT
Y-Strainer	R-0570A	150YFS, 150YBWS	ASTM A216-WCB Carbon Steel	ASME B16.34, B16.5, VIII-1	1/2" thru 1-1/2"	150 Lb.	Flanged, Buttweld	285 psig at 100 F	200 psig at 400 F
Y-Strainer	R-0570A	150YFSS, 150YBWSS	ASTM A351-CF8M Stainless Steel	ASME B16.34, B16.5, VIII-1	1/2" thru 1-1/2"	150 Lb.	Flanged, Buttweld	275 psig at 100 F	195 psig at 400 F
Y-Strainer	R-0570B	150YFS, 150YBWS	ASTM A216-WCB Carbon Steel	ASME B16.34, B16.5, VIII-1	2" thru 12"	150 Lb.	Flanged, Buttweld	285 psig at 100 F	200 psig at 400 F
Y-Strainer	R-0570B	150YFSS, 150YBWSS	ASTM A351-CF8M Stainless Steel	ASME B16.34, B16.5, VIII-1	2" thru 12"	150 Lb.	Flanged, Buttweld	275 psig at 100 F	195 psig at 400 F
Y-Strainer	R-0571A	300YFS, 300YBWS	ASTM A216-WCB Carbon Steel	ASME B16.34, B16.5, VIII-1	1/2" thru 1-1/2"	300 Lb.	Flanged, Buttweld	740 psig at 100 F	410 psig at 800 F
Y-Strainer	R-0571A	300YFSS, 300YBWSS	ASTM A351-CF8M Stainless Steel	ASME B16.34, B16.5, VIII-1	1/2" thru 1-1/2"	300 Lb.	Flanged, Buttweld	720 psig at 100 F	365 psig at 1000 F
Y-Strainer	R-0571B	300YFS, 300YBWS	ASTM A216-WCB Carbon Steel	ASME B16.34, B16.5, VIII-1	2" thru 12"	300 Lb.	Flanged, Buttweld	740 psig at 100 F	410 psig at 800 F
Y-Strainer	R-0571B	300YFSS, 300YBWSS	ASTM A351-CF8M Stainless Steel	ASME B16.34, B16.5, VIII-1	2" thru 12"	300 Lb.	Flanged, Buttweld	720 psig at 100 F	365 psig at 1000 F

0E16011.2