



345 Carlingview Drive
Toronto, Ontario M9W 6N9
Tel: 416.734.3300
Fax: 416.231.1626
Toll Free: 1 877.682.8772

www.tssa.org

May 03, 2017

CHUCK TYSON
CONBRACO INDUSTRIES
1418 PEARL STREET
PAGELAND SC 29728
US

Service Request Type: BPV-Fitting Registration
Service Request No.: 2046122
Your Reference No.: ASME BALL VALVE REGISTRATION
Registered to: CONBRACO INDUSTRIES

Dear CHUCK TYSON,


Technical Standards and Safety Authority (TSSA) is pleased to inform you that your submission has been reviewed and registered as follows:

CRN No.: 0C10908.5ADD11
Main Design No.: ADD11: Addition of Valve series 89FV - see the attachment to the Statutory Declaration Form for the scope of registration
Expiry Date: 07-Mar-2026

Please be advised that a valid quality control system must be maintained for the fitting registration to remain valid until the expiry date.

The stamped copy of the approved registration and the invoice are mailed separately. Should you have any questions or require further assistance, please contact a Customer Service Advisor at 1.877.682.TSSA (8772) or e-mail customerservices@tssa.org. We will be happy to assist you. When contacting TSSA regarding this file, please refer to the Service Request number provided above.

Yours truly,



Mark Valcic P. Eng.
Engineer Specialist BPV
Tel.: 416-734-3494
Fax: 416-231-1626
Email: mvalcic@tssa.org

Putting Public Safety First



TECHNICAL STANDARDS &
SAFETY AUTHORITY
14th Floor, Centre Tower
3300 Bloor Street West
Toronto, Ontario
Canada M8X 2X4

Show facsimile of manufacturer's logo or trademark, as it will appear on the fitting, in the space below

"Apollo"
POWERPRESS

STATUTORY DECLARATION

Registration of Fittings

I, CHUCK TYSON, SENIOR PROJECT ENGINEER

(Name and Position, e.g. President, Plant Manager, Chief Engineer)

of CONBRACO INDUSTRIES, INC.

(Name of Manufacturer)

Located at 1418 S. PEARL STREET, PAGELAND, SC 29728

(Plant Address)

(843) 679-6161

(Telephone No.)

(843) 672-1566

(Fax No.)

do solemnly declare that the fittings listed hereunder, which are subject to the **Technical Standards and Safety Act**, Boilers and Pressure Vessels Regulation, comply with all of the requirements of ASME B31.3 or ASME B16.34

(Title of recognized North American Standard)

which specifies the dimensions, materials of construction, pressure/temperature ratings, identification marking the fittings and service;

or are not covered by the provisions of a recognized North American standard and are therefore manufactured to comply with _____ as supported by the attached data which identifies the dimensions, material of construction, pressure/temperature ratings and the basis for such ratings, the marking of the fitting for identification and service.

I further declare that the manufacture of these fittings is controlled by a quality system meeting the requirements of ISO 9001:2008 which has been verified by the following authority, TUV RHEINLAND OF NORTH AMERICA

The items covered by this declaration, for which I seek registration, are category G type fittings. In support of this application, the following information and/or test data are attached as follows:

PRODUCT DOCUMENTATION (DRAWINGS & CALCULATIONS), ISO 9001:2008 CERTIFICATE

(drawings, calculations, test reports, etc.)


Declared before me at Conbraco, Pageland in the State

the 28th day of February AD 2017.

Commissioner for Oaths:

Nancy Strawn
(Printed name)

Nancy Strawn
(Signature)



Chuck Tyson
(Signature of Declarer)

FOR OFFICE USE ONLY

To the best of my knowledge and belief, the application meets the requirements of the **Technical Standards and Safety Act**, Boilers and Pressure Vessels Regulation, and CSA Standard B51 and is accepted for registration in Category C1

CRN:

0C10908.5 ADD 11

Registered by:

MARK VALCIC, P. ENG

Dated:

MAY 3, 2017

NOTE: This registration expires on

MARCH 7, 2026

Technical Standards and Safety Authority

Boilers and Pressure Vessels Safety Program

REGISTERED

C.R.N.:

0C10908.5 ADD 11

Signed:

M Valcic

Date:

MAY 3, 2017



TSSA Scope of Registration

Apollo PowerPress Floating Type Ball Valve	
Valve Series	89FV
Valve Models	89FV
Material Description	Carbon Steel
Material Specification	ASTM A216 Grade WCB & ASTM A108-12L14 (G12144)
Technical File	ES1584 Rev. A
National Standard	ASME B31.3
Size Range	1/2"-2"
End Connection	Press
Max Pressure Range	0 psig - 235 psig
Max Temperature Range	-40°F - 338°F

THIS IS PART OF
 CRN *110908.5 ADD*
 Technical Standards & Safety Authority
 Boilers & Pressure Vessels
 Safety Program

Wali Mays / 2017



Manufactured By Conbraco Industries, Inc.
 ISO 9001:2008 Certified

