



345 Carlingview Drive
Toronto, Ontario M9W 6N9
Tel.: 416.734.3300
Fax: 416.231.1626
Toll Free: 1.877.682.8772

www.tssa.org

November 24, 2017

SCOTT ISLIP
ROUND ENGINEERING INC
10 SEGWUN RD
WATERDOWN ON L8B 0K6
CA

Service Request Type: BPV-P-STD Registration

Service Request No.: 2151760

Your Reference No.: R-0772 PIPING

Install At: (SKIDDED PIPING ASSEMBLY - INSTALLATION LOCATION MAY VARY)
TILLEY MECHANICAL TECHNOLOGIES, INC. ENVIROSEP FLUID & HEAT RECOVERY SYSTEMS
31 AVIATION BLVD, GEORGETOWN, SOUTH CAROLINA, 29440 US

Dear SCOTT ISLIP,

Technical Standards and Safety Authority (TSSA) is pleased to inform you that your submission has been reviewed and registered as follows:

CRN No.: PSTD45145

Main Design No.: 1702031 SHEET NUMBER MM 0.11 REV.0, MM 2.11 TO MM 2.19 REV.2

Note: Line No. ¾" SW-115-040-A (water, 100psig@100F) is exempt from registration.

- The system is subject to inspection and pressure testing. Before commencing the system installation, please contact your authorized inspector.
- The CRN covers the piping system only and does not include registration of boilers, pressure vessels and fittings required under the Technical Standards and Safety Act, 2000 (the Act), Boilers and Pressure Vessels Regulations.
- Welding/brazing procedures and welders/brazers are to be accepted by the Technical Standards and Safety Authority, Boilers and Pressure Vessels Safety Program.
- The Manufacturer's Data Report, Form P-4A shall be provided.
- In compliance with TSS Act 2000 and Ontario Regulation 220/01, the Supply/Return tie-in piping to the skidded boiler and piping assembly shall be inspected and tested by an Inspector for each site - specific service location.

The stamped copy of the approved registration and the invoice are mailed separately. Should you have any questions or require further assistance, please contact a Customer Service Advisor at 1.877.682.TSSA (8772) or e-mail customerservices@tssa.org. We will be happy to assist you. When contacting TSSA regarding this file, please refer to the Service Request number provided above.

Yours truly,

Wendy Du, P.Eng.
Technical Standards & Safety Authority
Boilers & Pressure Vessels Safety Program
Tel.: 416-734-3566
Fax: 416-231-6183
Email: wdu@tssa.org