



345 Carlingview Drive
Toronto, Ontario M9W 6N9
Tel: 416.734.3300
Fax: 416.231.1626
Toll Free: 1.877.682.8772

www.tssa.org

April 02, 2018

SCOTT ISLIP
ROUND ENGINEERING INC
10 SEGWUN RD
WATERDOWN ON L8B 0K6
CA

Service Request Type: BPV-Fitting Registration
Service Request No.: 2257972
Your Reference No.: R-0881
Registered to: LESLIE CONTROLS INC

Dear SCOTT ISLIP,


Technical Standards and Safety Authority (TSSA) is pleased to inform you that your submission has been reviewed and registered as follows:

CRN No.: 0E20210.5
Main Design No.: TRAPS & MOUNTING BLOCKS - SEE SCOPE OF REGISTRATION
Design Report, Catalog cut, Parts Drawings
Expiry Date: 02-Apr-2028

Please be advised that a valid quality control system must be maintained for the fitting registration to remain valid until the expiry date.

The stamped copy of the approved registration and the invoice are mailed separately. Should you have any questions or require further assistance, please contact a Customer Service Advisor at 1.877.682.TSSA (8772) or e-mail customerservices@tssa.org. We will be happy to assist you. When contacting TSSA regarding this file, please refer to the Service Request number provided above.

Yours truly,


Ruiming You, P.Eng.
Mechanical Engineer, BPV
Tel.: 416-734-3428
Fax: 416-231-6183
Email: ryou@tssa.org



TECHNICAL STANDARDS &
SAFETY AUTHORITY
14th Floor, Centre Tower
3300 Bloor Street West
Toronto, Ontario
Canada M8X 2X4

Show facsimile of manufacturer's logo or trademark, as it will appear on the fitting, in the space below

Leslie Controls
Nicholson

STATUTORY DECLARATION
Registration of Fittings

I, JULIAN MILLARES, ENGINEERING MANAGER
(Name and Position, e.g. President, Plant Manager, Chief Engineer)

of LESLIE CONTROLS INC.
(Name of Manufacturer)

Located at 12501 TELECOM DR., TAMPA, FLORIDA, 33637, U.S.A. 813-978-1000
(Plant Address) (Telephone No.) (Fax No.)

do solemnly declare that the fittings listed hereunder, which are subject to the **Technical Standards and Safety Act**, Boilers and Pressure Vessels Regulation, comply with all of the requirements of ASME B16.34, ASME B31.1, ASME B31.3
(Title of recognized North American Standard)

which specifies the dimensions, materials of construction, pressure/temperature ratings, identification marking the fittings and service;

or are not covered by the provisions of a recognized North American standard and are therefore manufactured to comply with _____ as supported by the attached data which identifies the dimensions, material of construction, pressure/temperature ratings and the basis for such ratings, the marking of the fitting for identification and service.

I further declare that the manufacture of these fittings is controlled by a quality system meeting the requirements of ISO 9001 which has been verified by the following authority, ABS QUALITY EVALUATIONS

The items covered by this declaration, for which I seek registration, are category E type fittings. In support of this application, the following information and/or test data are attached as follows:
SCOPE OF CRN, DRAWINGS, CALCULATIONS, REPORTS


(drawings, calculations, test reports, etc.)

Declared before me at Tampa, Florida in the State of Florida
the 26th day of January AD 2018.

Commissioner for Oaths:

Cynthia Ann Vescio
(Printed name)

Cynthia Ann Vescio
(Signature)



Julian Millares
(Signature of Declarer)

FOR OFFICE USE ONLY

To the best of my knowledge and belief, the application meets the requirements of the **Technical Standards and Safety Act**, Boilers and Pressure Vessels Regulation, and CSA Standard B51 and is accepted for registration in Category E.

CRN: OE 20210.5

Registered by: RUIMING YOU

Dated: APR 02, 2018

NOTE: This registration expires on APR 02, 2028

OE 20210.5
[Signature]
APR 2 / 2018

NOTE: SEE SCOPE OF REGISTRATION (ONE PAGE) ATTACHED. 4/2/18

LESLIE CONTROLS INC.
 12501 TELECOM DR.
 TAMPA, FLORIDA
 33637, USA

Leslie Controls
Nicholson

SCOPE OF CRN REGISTRATION

Product Description	Design Code	Size Range	End Connection Inlet/Outlet	Material Specification	MAWP at MAWT (psig)	MDMT (F)	Report Number
UMT450 Traps	ASME B31.1, ASME B31.3.	N/A	Universal Mount (Swival)	Type 304 Stainless Steel ASTM A351-CF8	450 psig at 600°F	-20°F	R-0881
UMTTD Traps	ASME B31.1, ASME B31.3.	N/A	Universal Mount (Swival)	Type 304 Stainless Steel ASTM A351-CF8	450 psig at 650°F	-20°F	R-0881
UMTC Mounting Blocks	ASME B31.1, ASME B31.3.	1/2" thru 3/4"	NPT or Socketweld	Type 304 Stainless Steel ASTM A351-CF8	450 psig at 650°F	-20°F	R-0881
UMTCY Mounting Blocks	ASME B31.1, ASME B31.3.	1/2" thru 1"	NPT or Socketweld	Type 304 Stainless Steel ASTM A351-CF8	450 psig at 650°F	-20°F	R-0881

THIS IS PART OF
 CRN 0E20210.5
 Technical Standards & Safety Authority
 Boilers & Pressure Vessels
 Safety Program