



345 Carlingview Drive
Toronto, Ontario
CANADA M9W 6N9
Tel.: 416.734.3300
Fax.: 416.231.1626
Toll Free: 1.877.682.8772
www.tssa.org

June 18, 2018

SCOTT ISLIP
ROUND ENGINEERING INC
10 SEGWUN RD
WATERDOWN ON L8B 0K6
CA

Service Request Type.: BPV-National AB
Service Request No.: 2293186
Your Reference No.: R-0881
Registered to.: LESLIE CONTROLS INC

Dear SCOTT ISLIP,

Please find enclosed the original response from AB, registered under the CRN No.: 0E20210.52.

As all jurisdictional fees are handled by the Technical Standards and Safety Authority (TSSA), you do not pay any jurisdictions directly.

Should you have any questions or require further assistance, I will be happy to assist you.
For general enquiries, please contact a Customer Service Advisor at 1.877.682.TSSA (8772) or e-mail customerservices@tssa.org. When contacting TSSA regarding this file, please refer to the Service Request number provided above.

Yours truly,

Joanna Karpinski

Tel: 416-734-3377
Fax: 416-231-6183
Email: jkarpinski@tssa.org

May 23, 2018

Attention: Tanya Francis
TECHNICAL STANDARDS & SAFETY AUTHORITY
345 CARLINGVIEW DRIVE
TORONTO, ON M9W 6N9

Email: tfrancis@tssa.org

The design submission, tracking number 2018-02820, originally received on May 02, 2018 was surveyed and accepted for registration as follows:

CRN : 0E20210.52 **Accepted on:** May 23, 2018
Reg Type: NEW DESIGN **Expiry Date:** April 02, 2028
Drawing No. : SEE SCOPE OF REGISTRATION
Fitting type: TRAPS & MOUNTING BLOCKS
Design registered in the name of : LESLIE CONTROLS INC.

Description	MAWP	Design Temperature
rating per scope		

The registration is conditional on your compliance with the following notes:

As indicated on AB-41 Statutory Declaration form and submitted documentation, the code of construction are ASME B31.3, B16.34 and ASME B31.1.

This registration is valid only for fittings fabricated at the location(s) covered by the QC certificate attached to the accepted AB-41 Statutory Declaration form.

This registration is valid only until the indicated expiry date and only if the Manufacturer maintains a valid quality management system approved by an acceptable third-party agency until that date.


Should the approval of the quality management system lapse before the expiry date indicated above, this registration shall become void.

An invoice covering survey and registration fees will be forwarded from our Revenue Accounts.

Enclosed are stamped prints for your reference.

If you have any question don't hesitate to contact me by phone at (780) 433-0281 ext 3330 or fax (780) 437-7787 or e-mail grynchuk@absa.ca.

Sincerely,



GRYNCHUK, MILLA, P. Eng.
DOP Cert. No. D00005217

STATUTORY DECLARATION Registration of Fittings

In this space, show facsimile of manufacturer's logo or trademark as it will appear on the fitting. Leslie Controls Nicholson

I, JULIAN MILLARES, ENGINEERING MANAGER (name of applicant) (position title) (must be in a position of authority) of LESLIE CONTROLS INC. (name of manufacturer) located at 12501 TELECOM DR., TAMPA, FLORIDA, 33637, U.S.A. (plant address)

do solemnly declare that the fittings listed hereunder, which are subject to the Safety Codes Act (check one)

- [X] comply with the requirements of ASME B16.34, B31.1, B31.3 which specifies the dimensions, materials of construction, pressure/temperature ratings and identification marking of the fittings, or [] are not covered by the provisions of a recognized North American standard and are therefore manufactured to comply with as supported by the attached (title of code of construction or other applicable document) data which identifies the dimensions, materials of construction, pressure/temperature ratings and the basis for such ratings, and the marking of the fittings for identification.


I further declare that the manufacture of these fittings is controlled by a quality control program which has been verified by the following authority, ABS QUALITY EVALUATIONS as being suitable for the manufacture of these fittings to the stated standard. The fittings covered by this declaration, for which I seek registration, are

CATEGORY E (brief description of fittings)

In support of this application, the following information, calculations and/or test data are attached: SCOPE OF CRN, DRAWINGS, CALCULATIONS, REPORTS

DECLARED before me at Tampa in the State of Florida this 26th day of January, 2018

(print) Cynthia Ann Vesco (a Commissioner of Oaths or Notary Public)



(sign) Cynthia Ann Vesco (a Commissioner of Oaths or Notary Public)

Julian Millares (signature of applicant)

For ABSA Office Use Only:

NOTES:

To the best of my knowledge and belief, the application meets the requirements of the Safety Codes Act and CSA Standard B51, Clause 4.2, and is accepted for registration in Category E

Registration Number: OE20210.5A (Signature of the Administrator/SCO)

Date Registered: MAY 23 2018 Expiry Date: 2028, April 02

Leslie Controls Nicholson

LESLIE CONTROLS INC.
12501 TELECOM DR.
TAMPA, FLORIDA
33637, USA

02-Mar-18

PAGE 1 OF 1

SCOPE OF CRN REGISTRATION

Product Description	Design Code	Size Range	End Connection Inlet/Outlet	Material Specification	MAWP at MAWT (psig)	MDMT (F)	Report Number
UMT450 Traps	ASME B31.1, ASME B31.3.	N/A	Universal Mount (Swival)	Type 304 Stainless Steel ASTM A351-CF8	450 psig at 600°F	-20°F	R-0881
UMTTD Traps	ASME B31.1, ASME B31.3.	N/A	Universal Mount (Swival)	Type 304 Stainless Steel ASTM A351-CF8	450 psig at 650°F	-20°F	R-0881
UMTC Mounting Blocks	ASME B31.1, ASME B31.3.	1/2" thru 3/4"	NPT or Socketweld	Type 304 Stainless Steel ASTM A351-CF8	450 psig at 650°F	-20°F	R-0881
UMTCY Mounting Blocks	ASME B31.1, ASME B31.3.	1/2" thru 1"	NPT or Socketweld	Type 304 Stainless Steel ASTM A351-CF8	450 psig at 650°F	-20°F	R-0881

SAFETY CODES ACT - PROVINCE OF ALBERTA

REGISTRATION OF PIPING

REGISTRATION NO. **OE20210.52**

UWG. NO. or GME NO. *Scope*

TYPE OF PIPING *TRAPS & Mounting blocks*

MAY 23 2018

Date

REGISTRAR
[Signature]
MILLA GYRANOVICH, P. ENG.
DIR. OF SAFETY ENGINEERING