



345 Carlingview Drive
Toronto, Ontario
CANADA M9W 6N9
Tel.: 416.734.3300
Fax.: 416.231.1626
Toll Free: 1.877.682.8772
www.tssa.org

June 26, 2018

SCOTT ISLIP
ROUND ENGINEERING INC
10 SEGWUN RD
WATERDOWN ON L8B 0K6
CA

Service Request Type.: BPV-National BC
Service Request No.: 2293194
Your Reference No.: R-0881
Registered to.: LESLIE CONTROLS INC

Dear SCOTT ISLIP,

Please find enclosed the original response from BC, registered under the CRN No.: 0E20210.51.

As all jurisdictional fees are handled by the Technical Standards and Safety Authority (TSSA), you do not pay any jurisdictions directly.

Should you have any questions or require further assistance, I will be happy to assist you.
For general enquiries, please contact a Customer Service Advisor at 1.877.682.TSSA (8772) or e-mail customerservices@tssa.org. When contacting TSSA regarding this file, please refer to the Service Request number provided above.

Yours truly,

Joanna Karpinski

Tel: 416-734-3377
Fax: 416-231-6183
Email: jkarpinski@tssa.org

TECHNICAL STANDARDS & SAFETY AUTHORITY
345 CARLINGVIEW DRIVE
TORONTO ON M9W 6N9

Date: May 28, 2018

Account #: 35231

Journal #: 70803

Attn: TANYA FRANCIS

Re: Application for Design Registration

The design, as detailed in your, TSSA SR# 2293194, for a Fitting is accepted for registration as follows:

Registered To: LESLIE CONTROLS INC

CRN: 0E20210.51

MDMT: -20 deg F

MAWP: 450 psig

Drawing #: R-0881

Drawing Revision: 0

Conditions Of Registration:

Registration of Traps and Mounting Blocks as per att'd scope of registration sheet.

This design was registered based on a technical review performed by the province of initial registration in accordance with the Association of Chief Inspectors policy on reciprocal recognition of design review.

Reviewer's Notes:

MAWT: 600/650 Deg F.

As required by CSA B51 4.2.1, this registration expires on April 02, 2028. This CRN is valid until the expiry date as long as the Manufacturer maintains a valid quality control program verified by an acceptable third-party agency until that date. Should the certification of the quality control program lapse before the expiry date, this registration shall become void.

Contact me if you have any questions. The invoice for registration will be forwarded under separate cover.

SHARON PETERS

boiler.designregistration@technicalsaftybc.ca
Design Administration

cc:

Leslie Controls Nicholson

LESLIE CONTROLS INC.
12501 TELECOM DR.
TAMPA, FLORIDA
33637, USA

02-Mar-18

PAGE 1 OF 1

SCOPE OF CRN REGISTRATION

Product Description	Design Code	Size Range	End Connection Inlet/Outlet	Material Specification	MAWP at MAWT (psig)	MDMT (F)	Report Number
UMT450 Traps	ASME B31.1, ASME B31.3.	N/A	Universal Mount (Swival)	Type 304 Stainless Steel ASTM A351-CF8	450 psig at 600°F	-20°F	R-0881
UMTTD Traps	ASME B31.1, ASME B31.3.	N/A	Universal Mount (Swival)	Type 304 Stainless Steel ASTM A351-CF8	450 psig at 650°F	-20°F	R-0881
UMTC Mounting Blocks	ASME B31.1, ASME B31.3.	1/2" thru 3/4"	NPT or Socketweld	Type 304 Stainless Steel ASTM A351-CF8	450 psig at 650°F	-20°F	R-0881
UMTCY Mounting Blocks	ASME B31.1, ASME B31.3.	1/2" thru 1"	NPT or Socketweld	Type 304 Stainless Steel ASTM A351-CF8	450 psig at 650°F	-20°F	R-0881



CRN #: 0E20210.51
Date: May 24, 2018
BC J#: 70803

THIS IS PART OF
CRN 0E20210.5
Technical Standards & Safety Authority
Boilers & Pressure Vessels
Safety Program

2