

June 19, 2018

Attention: Scott Islip
ROUND ENGINEERING INC
10 SEGWUN ROAD
WATERDOWN, ON L8B 0K6

Email: scott.islip@roundeng.com

The design submission, tracking number 2018-02603, originally received on April 23, 2018 was surveyed and accepted for registration as follows:

CRN : E1506.62

Accepted on: June 19, 2018

Reg Type: NEW DESIGN

Drawing No. : CT-409 Rev C

Design registered in the name of : COLUMBIA BOILER CO

Description	MAWP	Design Temperature
MAWP	1034kPa	185 °C

The registration is conditional on your compliance with the following notes:

This design is accepted for registration based on the understanding that:

- the maximum pitch measured is 7"
- The following drawings are also included as part of this registration:*
- CT-407 Rev D
 - CT-079 Rev H
 - CT-080 Rev D
 - CT-095 Rev C
 - CT-096 Rev H
 - CT-103 Rev D
 - CT-705 Rev C
 - CT-727 Rev B
 - CT-737 Rev B
 - CT-786 Rev ---
 - HH PAD ASSY Rev ---
 - HH PAD 1 Rev ---

An invoice covering survey and registration fees will be forwarded from our Revenue Accounts.

Enclosed are stamped prints for your reference.

If you have any question don't hesitate to contact me by phone at (780) 433-0281 ext 3337 or fax (780) 437-7787 or e-mail Dick@absa.ca.

Sincerely,



June 19, 2018

DICK, ASHLING, P. Eng.
DOP Cert. No. D00007936