

ROUND ENGINEERING INC  
10 SEGWUN ROAD  
WATERDOWN ON L8B 0K6

**Date:** May 28, 2018  
**Account #:** 59067  
**Journal #:** 70833

**Attn:** SCOTT ISLIP

**Re:** Application for Design Registration

The design, as detailed in your, R-0916, for a Boiler is accepted for registration as follows:

**Registered To:** COLUMBIA BOILER CO                      **CRN:** E01506.61

**MAWT:** 365 deg F

**MAWP:** 150 psig

**Drawing #:** CT-409

**Drawing Revision:** C

**Conditions Of Registration:**

Registration of a CT25 Heat Exchanger Assembly.

This design was registered based on a technical review performed by the province of initial registration in accordance with the Association of Chief Inspectors policy on reciprocal recognition of design review.

Contact me if you have any questions. The invoice for registration will be forwarded under separate cover.

SHARON PETERS

boiler.designregistration@technicalsaftybc.ca  
Design Administration

**cc:**