

REGISTRATION OF A BOILER OR PRESSURE VESSEL DESIGN

27-Jun-18

Round Engineering Inc.
10 Segwun Rd.
Waterdown, Ontario
L0R 2H6

Attention: Scott Islip

File Number: 52965 [0V]

Re: Manufacturer: Columbia Boiler Co.
Item: CT 25 Heat Exchanger
Drawing Number: CT-409 Rev. C

TSASK Codes and Standards Compliance has registered the design listed above in accordance with The Boiler and Pressure Vessel Act and Regulations. The Canadian Registration Number (CRN) is:

E01506.63

This item was registered with the following design conditions:

MAWP: 1034 kPa	Design Temp: 185 °C
MDMT: °C	Corrosion Allowance: 0 mm

Please note that every piece of equipment must be constructed in strict accordance with the registered design.

In addition to stamping every unit with the CRN given, and as required in CSA B51, a Manufacturer's Data Report shall be forwarded to this office at the time the unit is shipped. The Manufacturer's Data Report form is available on the TSASK website at www.tsask.ca. Follow the links from the Codes and Standards Compliance page.

Should you require anything further, please do not hesitate to contact the Codes and Standards Compliance Office at your convenience.

Yours truly,



Williams Uju, P.Eng.
Codes and Standards Compliance

Remarks:

CRN registered under reciprocal agreement.