



14th Floor, Centre Tower
3300 Bloor Street West
Toronto, Ontario
Canada M8X 2X4
Tel.: 416.734.3300
Fax: 416.231.1626
Toll Free: 1.877.682.8772

www.tssa.org

March 27, 2015

SCOTT ISLIP
ROUND ENGINEERING INC
10 SEGWUN RD
WATERDOWN ON L0R 2H8
CA

Service Request Type: BPV-Fitting Registration
Service Request No.: 1579668
Your Reference No.: COLTON 125YFD
Registered to: COLTON INDUSTRIES INC

Dear SCOTT ISLIP,

Technical Standards and Safety Authority (TSSA) is pleased to inform you that your submission has been reviewed and registered as follows:

CRN No.: 0E17554.5
Main Design No.: R-0449-2 REV 0
Expiry Date: 27-Mar-2025

Please be advised that a valid quality control system must be maintained for the fitting registration to remain valid until the expiry date.

The stamped copy of the approved registration and the invoice are mailed separately. Should you have any questions or require further assistance, please contact a Customer Service Advisor at 1.877.682.TSSA (8772) or e-mail customerservices@tssa.org. We will be happy to assist you. When contacting TSSA regarding this file, please refer to the Service Request number provided above.

Yours truly,

Charley Dong, P.Eng.

Tel.: 416-734-3436
Fax: 416-231-6183
Email: cdong@tssa.org



TECHNICAL STANDARDS &
SAFETY AUTHORITY
14th Floor, Centre Tower
3300 Bloor Street West
Toronto, Ontario
Canada M8X 2X4

Show facsimile of manufacturer's logo or trademark, as it will
appear on the fitting, in the space below

COLTON

STATUTORY DECLARATION Registration of Fittings

I, KEVIN FANE, PRESIDENT

(Name and Position, e.g. President, Plant Manager, Chief Engineer)

of COLTON INDUSTRIES

40 CORSTATE AVE. VAUGHAN, ON L4K 4Y2 (Name of Manufacturer)

Located at 16 COSENTINO DR., SCARBOROUGH, ONTARIO, M1P 3A2

888-300-9155

888-300-9160

(Plant Address)

(Telephone No.)

(Fax No.)

☒ do solemnly declare that the fittings listed hereunder, which are subject to the **Technical Standards and Safety Act**, Boilers and Pressure Vessels Regulation, comply with all of the requirements of
ASME B16.1, ASME B16.42, ASME SECTION VIII, DIVISION 1

(Title of recognized North American Standard)

which specifies the dimensions, materials of construction, pressure/temperature ratings, identification marking the fittings and service;

☐ or are not covered by the provisions of a recognized North American standard and are therefore manufactured to comply with
as supported by the attached data which identifies the dimensions, material of construction,
pressure/temperature ratings and the basis for such ratings, the marking of the fitting for identification and service.

I further declare that the manufacture of these fittings is controlled by a quality system meeting the requirements of ISO:9001:2008
which has been verified by the following authority, QAS INTERNATIONAL

The items covered by this declaration, for which I seek registration, are category E - STRAINERS 125YFD type fittings. In support of
this application, the following information and/or test data are attached as follows:

DRAWING R-0449, DESIGN CALCULATIONS

(drawings, calculations, test reports, etc.)

Declared before me at Pickering in the Municipality of Durham
the 21st day of January AD 20 15.

Commissioner for Oaths:

Kyle Amegon
(Printed name)

(Signature)

(Signature of Declarer)

FOR OFFICE USE ONLY

To the best of my knowledge and belief, the application meets the requirements of the
Technical Standards and Safety Act, Boilers and Pressure Vessels Regulation, and
CSA Standard B51 and is accepted for registration in Category E

CRN: 0E17554.5

Registered by: Charley Dong

Dated: MAR. 27/15

NOTE: This registration expires on MAR. 27, 2025

NOTE: SEE ATTACHED
"PART OF CRN"
FOR THE SCOPE.

CX2
TSSA
MAR. 27/15

REGISTERED

CRN: 0E17554.5
Signed: Charley Dong
MAR. 27/15

COLTON INDUSTRIES

40 CORSTATE AVENUE
VAUGHAN, ONTARIO
L4K 4X2, CANADA

16-Feb-15

SCOPE OF CRN REGISTRATION

| Product Description | Colton Drawing No. | Part Number | Material Specification | Design Code | Size Range | ANSI Class | End Connection | MAWP at Temperature |
|---------------------|--------------------|-------------|--------------------------------|-------------------------------|-------------|------------|----------------|---------------------|
| Y-Strainer | R-0449 | 125YFD | Ductile Iron SA395 60-40-18 | ASME B16.1, B16.42, VIII-1 | 2" thru 12" | 125 Lb. | FF Flanged | 200 psig at 150 F |

