



345 Carlingview Drive
Toronto, Ontario M9W 6N9
Tel.: 416.734.3300
Fax: 416.231.1626
Toll Free: 1.877.682.8772

www.tssa.org

July 20, 2018

SCOTT ISLIP
ROUND ENGINEERING INC
10 SEGWUN RD
WATERDOWN ON L8B 0K6
CA

Service Request Type: BPV-PV Registration
Service Request No.: 2337048
Your Reference No.: R-0923
Registered to: DE DIETRICH SAS

Dear SCOTT ISLIP,


Technical Standards and Safety Authority (TSSA) is pleased to inform you that your submission has been reviewed and registered as follows:

CRN No.: 0C20546.5
Main Design No.: DE DIETRICH 6" X 4" VALVE CIP GLASS LINED
- SCOPE OF REGISTRATION, DRAWING D16244-001 & VAM-100-105
Expiry Date: July 20, 2028

Please be advised that a valid quality control system must be maintained for the fitting registration to remain valid until the expiry date.

The stamped copy of the approved registration and the invoice are mailed separately. Should you have any questions or require further assistance, please contact a Customer Service Advisor at 1.877.682.TSSA (8772) or e-mail customerservices@tssa.org. We will be happy to assist you. When contacting TSSA regarding this file, please refer to the Service Request number provided above.

Yours truly,


Ruying You, P.Eng.
Mechanical Engineer, BPV
Tel.: 416-734-3428
Fax: 416-231-6183
Email: ryou@tssa.org



TECHNICAL STANDARDS & SAFETY AUTHORITY
 14th Floor, Centre Tower
 3300 Bloor Street West
 Toronto, Ontario
 Canada M8X 2X4

Show facsimile of manufacturer's logo or trademark, as it will appear on the fitting, in the space below



STATUTORY DECLARATION

Registration of Fittings

I, CARLOS ENRIQUEZ, LEAD ENGINEER GLASS LINED EQUIPMENT
(Name and Position, e.g. President, Plant Manager, Chief Engineer)

of DE DIETRICH SAS
(Name of Manufacturer)

Located at GRAND RUE - BP 8, 67110 ZINSWILLER, FRANCE
(Plant Address) (Telephone No.) (Fax No.)

do solemnly declare that the fittings listed hereunder, which are subject to the **Technical Standards and Safety Act**, Boilers and Pressure Vessels Regulation, comply with all of the requirements of ASME B16.34, ASME SECTION VIII-1

(Title of recognized North American Standard)

which specifies the dimensions, materials of construction, pressure/temperature ratings, identification marking the fittings and service;

or are not covered by the provisions of a recognized North American standard and are therefore manufactured to comply with _____ as supported by the attached data which identifies the dimensions, material of construction, pressure/temperature ratings and the basis for such ratings, the marking of the fitting for identification and service.

I further declare that the manufacture of these fittings is controlled by a quality system meeting the requirements of ISO 9001 which has been verified by the following authority, TUV

The items covered by this declaration, for which I seek registration, are category C - 6"X4" Glass Lined Valve type fittings. In support of this application, the following information and/or test data are attached as follows:
SCOPE OF CRN REGISTRATION, REPORTS, DRAWINGS, CALCULATIONS


(drawings, calculations, test reports, etc.)

Declared before me at 246 McKinzie Rd in the State of Texas
 the 21ST day of June AD 2018.

Commissioner for Oaths:

Katherine Sanford
(Printed name)

Katherine Sanford
(Signature)



(Signature of Declarer)

FOR OFFICE USE ONLY

To the best of my knowledge and belief, the application meets the requirements of the **Technical Standards and Safety Act**, Boilers and Pressure Vessels Regulation, and CSA Standard B51 and is accepted for registration in Category C

Boilers and Pressure Vessels Safety Program

CRN: OC 20546.5

Registered by: RUINING YOU

Dated: July 20, 2018

NOTE: This registration expires on July 20, 2028

TSSA 80

OC 20546.5

July 20, 2018

PV 09553 (06/04) NOTE: SEE SCOPE OF REGISTRATION - ONE SHEET ATTACHED. 8/7/2018

DE DIETRICH SAS
 GRAND RUE - BP 8
 67110 ZINSWILLER
 FRANCE



19-Jul-18

PAGE 1 OF 1

SCOPE OF CRN REGISTRATION

Product Description	Drawing Number	Design Code	Connection Size	End Connection	Materials of Construction	MAWP at MAWT	MDMT
6" x 4" Valve CIP Glass Lined	D16244-001 Rev. A, VAM-100-105 Rev. E	ASME B16.34, ASME B31.1, ASME B31.3	6" x 4"	CL. 150 Flanged	Body: Carbon Steel ASME SA216-WCB, Adapter Accessories: UNS N10276 Alloy C276 ASME SB-575, SB-619, SB-564	150/FV psig at 500F	-20F

Note 1: MAWP = Maximum allowable working pressure, MAWT = Maximum allowable working temperature, MDMT = Minimum design metal temperature.

THIS IS PART OF
 CRN *OC 20546.5*
 Technical Standards & Safety Authority
 Boilers & Pressure Vessels
 Safety Program