

November 09, 2018

Attention: Scott Islip
ROUND ENGINEERING INC
10 SEGWUN ROAD
WATERDOWN, ON L8B 0K6

Email: scott.islip@roundeng.com

The design submission, tracking number 2018-07226, originally received on October 29, 2018 was surveyed and accepted for registration as follows:

CRN : Y8826.2

Accepted on: November 09, 2018

Reg Type: NEW DESIGN

Drawing No. : 1806035 Rev 1

Design registered in the name of : TILLEY TECHNOLOGIES INC, DBA ENVIROSEP

Description	MAWP	Design Temperature	MDMT
Internal Pressure	1172 kPa	260 °C	-29 °C
External Pressure	0kPa	260 °C	-29 °C

An invoice covering survey and registration fees will be forwarded from our Revenue Accounts.

If you have any question don't hesitate to contact me by phone at (780) 433-0281 or fax (780) 437-7787 or e-mail liu@absa.ca.

Sincerely,



LIU, XING, P. Eng.
DOP Cert. No. D00008861