

**REGISTRATION OF A BOILER OR PRESSURE VESSEL DESIGN**

19-Nov-18

Round Engineering Inc.  
10 Segwun Rd.  
Waterdown, Ontario  
L8B 0K6

**Attention: Scott Islip**

**File Number: 53341 [ 0V]**

**Re: Manufacturer: Enerquip, LLC**  
**Item: Heat Exchanger**  
**Drawing Number: 271250 Rev. 1**

TSASK Codes and Standards Compliance has registered the design listed above in accordance with The Boiler and Pressure Vessel Act and Regulations. The Canadian Registration Number (CRN) is:

**A8492.3**

This item was registered with the following design conditions:

<b>MAWP (Shell side):</b>	<b>1034 kPa</b>	<b>Design Temp (Shell side):</b>	<b>302 °C</b>
<b>MAWP (Tube side):</b>	<b>1034 kPa</b>	<b>Design Temp (Tube side):</b>	<b>302 °C</b>
<b>MDMT:</b>	<b>-29 °C</b>	<b>Corrosion Allowance:</b>	<b>0 mm</b>

Please note that every piece of equipment must be constructed in strict accordance with the registered design.

In addition to stamping every unit with the CRN given, and as required in CSA B51, a Manufacturer's Data Report shall be forwarded to this office at the time the unit is shipped. The Manufacturer's Data Report form is available on the TSASK website at [www.tsask.ca](http://www.tsask.ca). Follow the links from the Codes and Standards Compliance page.

Should you require anything further, please do not hesitate to contact the Codes and Standards Compliance Office at your convenience.

Yours truly,



Williams Uju, P.Eng.  
Codes and Standards Compliance

**Remarks:**