



14th Floor, Centre Tower
3300 Bloor Street West
Toronto, Ontario
Canada M8X 2X4
Tel.: 416.734.3300
Fax: 416.231.1626
Toll Free: 1.877.682.8772

www.tssa.org

May 13, 2015

SCOTT ISLIP
ROUND ENGINEERING INC
10 SEGWUN RD
WATERDOWN ON L0R 2H8
CA

Service Request Type.: BPV-National BC
Service Request No.: 1580830
Your Reference No.: EVOGUARD
Registered to.: EVOGUARD GMBH

Dear SCOTT ISLIP,

Please find enclosed the original response from BC, registered under the CRN No.: 0C17443.51.

As all jurisdictional fees are handled by the Technical Standards and Safety Authority (TSSA), you do not pay any jurisdictions directly.

Should you have any questions or require further assistance, I will be happy to assist you.
For general enquiries, please contact a Customer Service Advisor at 1.877.682.TSSA (8772) or e-mail customerservices@tssa.org. When contacting TSSA regarding this file, please refer to the Service Request number provided above.

Yours truly,

Tanya Francis
Administrative Assistant_ BPV Engineering
Tel. : 416-734-3423
Fax : 416-231-6183
Email : tfrancis@tssa.org



505 - 6th Street, Suite 200
New Westminster, BC V3L 0E1

Toll Free: 1-866-566-SAFE
Fax: (778) 396 - 2064
www.safetyauthority.ca

TECHNICAL STANDARDS & SAFETY AUTHORITY
14TH FLOOR CENTRE TOWER-3300 BLOOR STREE
TORONTO ON M8X 2X4

Date: March 10, 2015
Account #: 35231
Journal #: 61942
Our File #: 5531497

Attn: TANYA FRANCIS

Re: Application for Design Registration

The design, as detailed in your, TSSA Service Request No.: 1580830, for a Fitting is accepted for registration as follows:

Registered To: EVOGUARD GMBH **CRN:** 0C17443.51

MDMT: -20 deg F

MAWT: 302 deg F

MAWP: 145 psig

Drawing #: WVV, FVF

Drawing Revision: 0

Conditions Of Registration:

Registration of Butterfly Valve Series WVV, FVF Sizes 1" thru 6", DN25 thru DN150.

This design was registered based on a technical review performed by the province of initial registration in accordance with the Association of Chief Inspectors policy on reciprocal recognition of design review.

Reviewer's Notes:

As required by CSA B51 4.2.1, this registration expires on January 30, 2025. This CRN is valid until the expiry date as long as the Manufacturer maintains a valid quality control program verified by an acceptable third-party agency until that date. Should the certification of the quality control program lapse before the expiry date, this registration shall become void.

Contact me if you have any questions. The invoice for registration will be forwarded under separate cover.

SHARON PETERS

boiler.designregistration@safetyauthority.ca
Design Administration

cc: