

Montréal, 02 avril 2019

Mr. SCOTT ISLIP  
ROUND ENGINEERING  
10 Segwun Rd.  
WATERDOWN ONTARIO  
CANADA L8B 0K6

Fabricant : OY GALVATEK AB  
38 VESIJARVENKATU  
FI-15140 LAHTI  
FINLAND

Numéro de dossier : 952960  
Numéro(s) de dessin (s) : HEATING COIL HG-2018-02-01A, HG-2018-02-02A  
R-1048

**Objet : Enregistrement des plans et devis – Confirmation de l'enregistrement**

Monsieur,

La Régie du bâtiment du Québec (RBQ) vous informe que votre demande d'enregistrements de plans et devis a été traitée et que cette conception a été enregistrée sous le numéro d'enregistrement canadien (NEC\CRN) : **0H05003.6**.

Nous portons à votre attention cette exigence applicable à la réglementation sur les appareils sous pression et des codes et normes qui y sont associés :

- Le constructeur doit maintenir un système de contrôle de la qualité valide pour fabriquer selon ce NEC.

Le présent avis d'approbation ne dégage pas le constructeur de ses responsabilités quant à la conception ou à la construction des équipements fabriqués selon ce NEC.

Salutations distinguées,

Bureau d'expertise et d'homologation en équipements sous pression

## Statutory Declaration Registration of Fittings

**(a) Design Qualification**

GALVATEK

I<sup>1</sup> Ulf Prah  
(Name of applicant)

President  
(Position eg, president, plant manager, chief eng.)

of Oy Galvatek Ab  
(name of company)

Located at Vesijarvenkatu 38, FI-15410, Lahti, Finland  
(plant address)

do solemnly declare that the fittings listed hereunder, which are subject to the Boilers & Pressure Vessels Act:

comply with all the requirements of the ANSI/ASME codes as to their dimensions, material, identification & service for which are required:

Or

are not covered by the provisions of the ANSI/ASME codes, and are therefore constructed to comply with \_\_\_\_\_ code and standard, and are designed to the best current engineering practice, as shown by the supporting test data.

**(b) Quality control of Manufacture**

I further declare the manufacture of these fittings is controlled by a quality control program which complies with the requirements of ISO 9001:2015 \_\_\_\_\_, and has been verified by the following authority or authorized agency Bureau Veritas

The fittings<sup>2</sup> covered by this declaration, for which I seek registration, are Category H Heating Coils

In support of the application, the following information, calculations and/or test data are attached:  
Scope of CRN, Drawings, Calculations, Reports

Declared before me at Lahti, Finland

In the of Municipality of Päijänne Tavastia

The 4 day of January AD 2019

A (commissioner for oaths)

*[Handwritten Signature]*  
Signature of Declarer<sup>3</sup>

For Official Use Only	
The application is accepted for registration in Category <u>"H"</u> in accordance with the Boilers and Pressure Vessels Act and CSA Standard B51.	<div style="border: 1px solid black; padding: 5px; margin: 0 auto; width: 80%;"> <p style="margin: 0;"><b>QUÉBEC ENREGISTRÉ</b></p> <p style="margin: 0;">NEC (CRN) : <u>OH05003.6</u></p> <p style="margin: 0;">DATE : <u>2019-04-01</u></p> </div>
This registration must be revalidated after ten (10) years from the date of acceptance.	
Registered Number CRN <b style="font-size: 24pt;">OH 05003.6</b>	For the Chief Inspector Date <u>01 AVR. 2019</u>

<sup>1</sup> Three completed copied of Statutory Declaration form together with three copies of Catalogs, drawings of Bulletins illustrating above fittings shall be submitted.  
<sup>2</sup> All fittings are required to be registered in the name of the Manufacturer.  
<sup>3</sup> This form shall be completed and signed by the president of highest official in the manufacturing plan where the fitting is produced.

This is to certify the above own hand signature(s) of  
ULF CHRISTER PRÄHL

*[Handwritten Signature]*

Joni Setälä  
District Registrar  
Notary Public





**Oy Galvatek Ab**

Vesijarvenkatu 38  
FI-15140, Lahti  
Finland

20-Jan-19

Page 1 of 1

**SCOPE OF CRN REGISTRATION**

Product Description	Drawing Number	Design Code	Diameter x Thickness	Volume (Cu. Ft.)	Material	MAWP at MAWT
Heating Coil Hot Water Tank	HG-2018-02-01A	ASME B31.3, 2016	33.7 mm x 2.6 mm, 26.9 mm x 2.3 mm, 26.9 mm x 2.6 mm	0.239	ASTM A312-316L, ASTM A358-316L, ASTM A240-316L	58 psig at 306F
Heating Coil Hot Water Tank	HG-2018-02-01B	ASME B31.3, 2016	33.7 mm x 2.6 mm, 26.9 mm x 2.3 mm, 26.9 mm x 2.6 mm	0.236	ASTM A312-316L, ASTM A358-316L, ASTM A240-316L	58 psig at 306F

**Note 1:** Per CSA Table 1 Note (2)(B) the total volume of any configured manifold assembly shall not exceed 1.5 cubic feet in volume.