

July 25, 2019

**Attention:** Tanya Francis  
TECHNICAL STANDARDS & SAFETY AUTHORITY  
345 CARLINGVIEW DRIVE  
TORONTO, ON M9W 6N9

The design submission, tracking number 2019-04808, originally received on July 08, 2019 was surveyed and accepted for registration as follows:

**CRN :** 0C21439.52 **Accepted on:** July 25, 2019  
**Reg Type:** NEW DESIGN **Expiry Date:** May 23, 2029  
**Drawing No. :** SEE SCOPE, ROTARY ON-OFF CONTROL VALVE As Noted  
**Fitting type:** VALVES, 1/4 THRU 1 INCH, 250, 300, 600 LB  
Design registered in the name of : LESLIE CONTROLS INC.

**The registration is conditional on your compliance with the following notes:**

*As indicated on AB-41 Statutory Declaration form and submitted documentation, the code of construction are B16.34, ASME B31.1 and other engineering analysis.*

- *This registration is valid only for fittings fabricated at the location(s) covered by the QC certificate attached to the accepted AB-41 Statutory Declaration form.*
- *This registration is valid only until the indicated expiry date and only if the Manufacturer maintains a valid quality management system approved by an acceptable third-party agency until that date.*
- *Should the approval of the quality management system lapse before the expiry date indicated above, this registration shall become void.*


*Registration is based on the understanding that the valves meet ASME B16.34 or ASME B16.15 and also are qualified for installation on B31.1& N31.3 piping.*

*Valves designed to B16.34 shall fully comply with Tables 1, 2 & 3*

An invoice covering survey and registration fees will be forwarded from our Revenue Accounts.

If you have any question don't hesitate to contact me by phone at (780) 433-0281 ext 3330 or fax (780) 437-7787 or e-mail [grynchuk@absa.ca](mailto:grynchuk@absa.ca).

Sincerely,



GRYNCHUK, MILLA, P. Eng.  
DOP Cert. No. D00005217