



505 - 6th Street, Suite 200
New Westminster, BC V3L 0E1

Toll Free: 1-866-566-SAFE

Fax: (778) 396 - 2064

www.safetyauthority.ca

TECHNICAL STANDARDS & SAFETY AUTHORITY
14TH FLOOR CENTRE TOWER-3300 BLOOR STREE
TORONTO ON M8X 2X4

Date: December 20, 2013

Account #: 35231

Journal #: 58666

Our File #: 5480038

Attn: TANYA FRANCIS

Re: Application for Design Registration

The design, as detailed in your, TSSA Service Request No: 1290564, for a Fitting is accepted for registration as follows:

Registered To: CONBRACO INDUSTRIES INC **CRN:** 0E8959.51

MDMT: -20 deg F

MAWT: 150 deg F

MAWP: 400 psig

Drawing #: 59ULX01 etc

Drawing Revision: A etc

Conditions Of Registration:

Registration of Series 59 Bronze Y-Strainer.

This design was registered based on a technical review performed by the province of initial registration in accordance with the Association of Chief Inspectors policy on reciprocal recognition of design review.

Reviewer's Notes:

As required by CSA B51 4.2.1, this registration expires on November 19, 2023. This CRN is valid until the expiry date as long as the Manufacturer maintains a valid quality control program verified by an acceptable third-party agency until that date. Should the certification of the quality control program lapse before the expiry date, this registration shall become void.

Contact me if you have any questions. The invoice for registration will be forwarded under separate cover.

SHARON PETERS

(778) 396-2027

Sharon.Peters@safetyauthority.ca

Design Administration

cc: