



TECHNICAL STANDARDS & SAFETY AUTHORITY
 14th Floor, Centre Tower
 3300 Bloor Street West
 Toronto, Ontario
 Canada M8X 2X4

Show facsimile of manufacturer's logo or trademark, as it will appear on the fitting, in the space below

"Apollo"[®]
 INTERNATIONAL

STATUTORY DECLARATION
Registration of Fittings

I, GREG GOODSON, MANAGER OF PRODUCT ENGINEERING
 (Name and Position, e.g. President, Plant Manager, Chief Engineer)

of CONBRACO INDUSTRIES, INC.
 (Name of Manufacturer)

Located at 701 MATTHEWS-MINT HILL ROAD, MATTHEWS, NC, USA, 28105 704-841-6000 704-841-6020
 (Plant Address) (Telephone No.) (Fax No.)

do solemnly declare that the fittings listed hereunder, which are subject to the **Technical Standards and Safety Act**, Boilers and Pressure Vessels Regulation, comply with all of the requirements of ASME B16.34, API 607, API 609

(Title of recognized North American Standard)

which specifies the dimensions, materials of construction, pressure/temperature ratings, identification marking the fittings and service;

or are not covered by the provisions of a recognized North American standard and are therefore manufactured to comply with _____ as supported by the attached data which identifies the dimensions, material of construction, pressure/temperature ratings and the basis for such ratings, the marking of the fitting for identification and service.

I further declare that the manufacture of these fittings is controlled by a quality system meeting the requirements of ISO:9001:2008 which has been verified by the following authority, TUV RHEINLAND OF NORTH AMERICA, INC.

The items covered by this declaration, for which I seek registration, are category C - DOUBLE OFFSET HPBV type fittings. In support of this application, the following information and/or test data are attached as follows:

CATALOGUE, SCOPE OF SUPPLY, QUALITY CERTIFICATES AND REPORTS

(drawings, calculations, test reports, etc.)


Declared before me at Chesterfield County in the State of South Carolina
 the 5th day of January AD 2015.

Commissioner for Oaths:

Nancy Strawn
 (Printed name)

Nancy Strawn
 (Signature)

Greg Goodson
 (Signature of Declarer)



FOR OFFICE USE ONLY

To the best of my knowledge and belief, the application meets the requirements of the **Technical Standards and Safety Act**, Boilers and Pressure Vessels Regulation, and CSA Standard B51 and is accepted for registration in Category CI

CRN: 0C17459.5

Registered by: MARK VALCIC, P.ENG.

Dated: FEB 6, 2015

NOTE: This registration expires on FEB 6, 2025

Technical Standards and Safety Authority
 Boilers and Pressure Vessels Safety Program

REGISTERED
 C.R.N.: 0C17459.5
 Signed: [Signature]
 Date: FEB 6, 2015

CONBRACO INDUSTRIES INC.
 701 MATTHEWS-MINT HILL ROAD
 MATTHEWS, NC
 USA, 28105

06-Jan-15

DOUBLE OFFSET HIGH PERFORMANCE BUTTERFLY VALVE - SCOPE OF CRN REGISTRATION

Series Number	Body Material Specification	Design Code	Size Range	ANSI Class	End Connection	MAWP at Temperature
215L	ASTM A216-WCB C.Steel	ASME B16.34, API 607, API 609	2" thru 24"	150 Lb.	Lug	285 psig at 100F
215L	ASTM A351-CF8M S.Steel	ASME B16.34, API 607, API 609	2" thru 24"	150 Lb.	Lug	275 psig at 100F
215W	ASTM A216-WCB C.Steel	ASME B16.34, API 607, API 609	2" thru 24"	150 Lb.	Wafer	285 psig at 100F
215W	ASTM A351-CF8M S.Steel	ASME B16.34, API 607, API 609	2" thru 24"	150 Lb.	Wafer	275 psig at 100F
230L	ASTM A216-WCB C.Steel	ASME B16.34, API 607, API 609	2" thru 24"	300 Lb.	Lug	740 psig at 100F
230L	ASTM A351-CF8M S.Steel	ASME B16.34, API 607, API 609	2" thru 24"	300 Lb.	Lug	720 psig at 100F
230W	ASTM A216-WCB C.Steel	ASME B16.34, API 607, API 609	2" thru 24"	300 Lb.	Wafer	740 psig at 100F
230W	ASTM A351-CF8M S.Steel	ASME B16.34, API 607, API 609	2" thru 24"	300 Lb.	Wafer	720 psig at 100F
260L	ASTM A216-WCB C.Steel	ASME B16.34, API 607, API 609	3" thru 12"	600 Lb.	Lug	1480 psig at 100F
260L	ASTM A351-CF8M S.Steel	ASME B16.34, API 607, API 609	3" thru 12"	600 Lb.	Lug	1440 psig at 100F
260W	ASTM A216-WCB C.Steel	ASME B16.34, API 607, API 609	3" thru 12"	600 Lb.	Wafer	1480 psig at 100F
260W	ASTM A351-CF8M S.Steel	ASME B16.34, API 607, API 609	3" thru 12"	600 Lb.	Wafer	1440 psig at 100F

THIS IS PART OF
CRN 0617491.5
 Technical Standards & Safety Authority
 Boilers & Pressure Vessels
 Safety Program

WAL Feb 6/15