



Montréal, 28 Février 2020

MME TANYA FRANCIS
TECHNICAL STANDARDS & SAFETY AUTHORITY
345 CARLINGVIEW DRIVE
TORONTO ONTARIO,
CANADA M9W6N9

Fabricant : STRAHMAN VALVES INC
2801 BAGLYOS CIRCLE
BETHLEHEM PA
USA 18020

Numéro de dossier : 951494

Numéro(s) de dessin (s) : DIRECT DIFFUSE STEAM TRAP - SEE SCOPE OF REGISTRATION

Objet : Enregistrement des plans et devis – Confirmation de l'enregistrement

Madame,

La Régie du bâtiment du Québec (RBQ) vous informe que votre demande d'enregistrements de plans et devis a été traitée et que cette conception a été enregistrée sous le numéro d'enregistrement canadien (NEC\CRN) : 0E22109.56

Nous portons à votre attention cette exigence applicable à la réglementation sur les appareils sous pression et des codes et normes qui y sont associés :

- Le constructeur doit maintenir un système de contrôle de la qualité valide pour fabriquer selon ce NEC.

Le présent avis d'approbation ne dégage pas le constructeur de ses responsabilités quant à la conception ou à la construction des équipements fabriqués selon ce NEC.

Salutations distinguées,

Bureau d'expertise et d'homologation en équipements sous pression

N.B. Translation of this communication below.

Montréal

545, boul. Crémazie Est, 7^e étage

Montréal (Québec) H2M 2V2

Téléphone : 514 873-6459

Sans frais : 1 866 262-2084

www.rbq.gouv.qc.ca



Montréal, February 28, 2020

MME TANYA FRANCIS
TECHNICAL STANDARDS & SAFETY AUTHORITY
345 CARLINGVIEW DRIVE
TORONTO ONTARIO,
CANADA M9W6N9

Manufacturer : STRAHMAN VALVES INC
2801 BAGLYOS CIRCLE
BETHLEHEM PA
USA 18020

Our reference : 951494
Design number : DIRECT DIFFUSE STEAM TRAP - SEE SCOPE OF REGISTRATION

Subject: Registration of designs – Confirmation of approval

Dear Madam,

The Régie du bâtiment du Québec (RBQ) informs you that your application for the registration of designs has been evaluated and that the design was registered under the Canadian Registration Number (CRN\NEC) : 0E22109.56.

We bring your attention this requirement of the regulation respecting pressure vessels, and the codes and standards adopted:

- The manufacturer must maintain a valid quality control program to produce according to the CRN.

This notice of approval does not relieve the constructor of his responsibilities with respect to the design or construction of equipment manufactured according to this CRN.

Yours sincerely,

Bureau d'expertise et d'homologation en équipements sous pression

Montréal

545, boul. Crémazie Est, 7^e étage
Montréal (Québec) H2M 2V2
Téléphone : 514 873-6459
Sans frais : 1 866 262-2084
www.rbq.gouv.qc.ca

Statutory Declaration Registration of Fittings



(a) Design Qualification

I S. GREGORY STEDNITZ ENGINEER, WASH DOWN of STRAHMAN VALVES, INC. Located at 2801 BAGLYOS CIRCLE, BETHLEHEM, PENNSYLVANIA, 18020, USA

do solemnly declare that the fittings listed hereunder, which are subject to the Bollers & Pressure Vessels Act:


- comply with all the requirements of the ANSI/ASME codes as to their dimensions, material, identification & service for which are required: Or are not covered by the provisions of the ANSI/ASME codes, and are therefore constructed to comply with code and standard, and are designed to the best current engineering practice, as shown by the supporting test data.

(b) Quality control of Manufacture

I further declare the manufacture of these fittings is controlled by a quality control program which complies with the requirements of ISO 9001, and has been verified by the following authority or authorized agency SAI GLOBAL The fittings covered by this declaration, for which I seek registration, are CATEGORY E STEAM TRAPS

In support of the application, the following information, calculations and/or test data are attached: SCOPE OF CRN, DRAWINGS, CALCULATIONS, REPORTS

Declared before me at Bethlehem PA In the of County of Northampton The 17th day of Dec AD 2019



Signature of Declarer

For Official Use Only The application is accepted for registration in Category in accordance with the Bo and CSA Standard B51. This registration must be revalidated after ten (10) years from the date of acceptance. Registered Number CRN For the Chief Inspector Date 0E22109.56 28 FEV 2020

1 Three completed copied of Statutory Declaration form together with three copies of Catalogs, drawings of Bulletins illustrating above fittings shall be submitted. 2 All fittings are required to be registered in the name of the Manufacturer. 3 This form shall be completed and signed by the president of highest official in the manufacturing plan where the fitting is produced.



STRAHMAN VALVES, INC.

2801 BAGLYOS CIRCLE
BETHLEHEM, PENNSYLVANIA
18020, USA

15-Nov-19

PAGE 1 OF 1

SCOPE OF CRN REGISTRATION


Product Description	Model	Design Code	Size Range Inlet/Outlet	Body Material Specification	MAWP at MAWT	Report Number
Steam Trap	Direct Diffuse	ASME B31.1, ASME B31.3.	3/4", 1", 1-1/2" NPT	Stainless Steel ASTM A351-CF8	1000 psig at 350°F	R-1144

Note 1: MAWP = Maximum Allowable Working Pressure, MAWT = Maximum Allowable Working Temperature.

Note 2: The pressure-temperature ratings shown are the maximum CRN pressure-temperature ratings. In all cases the MAWP may be limited by the seat or seal material or other considerations. Please consult Strahman literature.

Note 3: For low temperature operation the products shall conform to the rules of the applicable codes under which they are used.

Note 4: Stainless Steel ASTM A351-CF8M may substitute for ASTM A351-CF8.



0E22109.56
28 FEV 2020