



Technical Standards and Safety Authority  
 345 Carlingview Drive  
 Toronto, Ontario M9W 6N9  
 www.tssa.org

Show facsimile of manufacturer's logo or trademark, as it will appear on the fitting, in the space below



**LESLIE**  
**CONTROLS, INC.**  
 A subsidiary of CIRCOR International, Inc.

## STATUTORY DECLARATION

### Registration of Fittings

I, JULIAN MILLARES, ENGINEERING MANAGER  
(Name and Position, e.g. President, Plant Manager, Chief Engineer)

of LESLIE CONTROLS INC.  
(Name of Manufacturer)

Located at 12501 TELECOM DR., TAMPA, FLORIDA, 33637, USA 813-978-1000  
(Plant Address) (Telephone No.) (Fax No.)

do solemnly declare that the fittings listed hereunder, which are subject to the **Technical Standards and Safety Act**, Boilers and Pressure Vessels Regulation, comply with all of the requirements of ASME Section VIII-1  
(Title of recognized North American Standard)

which specifies the dimensions, materials of construction, pressure/temperature ratings, identification marking the fittings and service;

or are not covered by the provisions of a recognized North American standard and are therefore manufactured to comply with \_\_\_\_\_ as supported by the attached data which identifies the dimensions, material of construction, pressure/temperature ratings and the basis for such ratings, the marking of the fitting for identification and service.

I further declare that the manufacture of these fittings is controlled by a quality system meeting the requirements of ASME UV \_\_\_\_\_ which has been verified by the following authority, ASME

The items covered by this declaration, for which I seek registration, are category G - Safety Relief Valves type fittings. In support of this application, the following information and/or test data are attached as follows:  
SCOPE OF CRN, DRAWINGS, CALCULATIONS, REPORTS

(drawings, calculations, test reports, etc.)

Declared before me at LESLIE CONTROLS INC. in the STATE of FLORIDA

the 21<sup>ST</sup> day of JULY AD 20 20

Commissioner for Oaths:

STEVEN J. REED

(Printed name)

*Steven J. Reed*  
(Signature)



**STEVEN J REED**  
 MY COMMISSION # GG087845  
 EXPIRES March 28, 2021

*Julian Millares*  
(Signature of Declarer)

#### FOR OFFICE USE ONLY

To the best of my knowledge and belief, the application meets the requirements of the **Technical Standards and Safety Act**, Boilers and Pressure Vessels Regulation, and CSA Standard B51 and is accepted for registration in Category 'G'

CRN: \_\_\_\_\_

Registered by: \_\_\_\_\_

Dated: \_\_\_\_\_

NOTE: This registration expires on: **Aug. 18, 2030**

Technical Standards and Safety Authority

Boilers and Pressure Vessels Safety Program

REGISTERED

C.R.N.: 0G22625.5

Signed: *Lucas Z...*

Date: **August 18, 2020.**

*\*Information provided in this application is releasable under the Freedom of Information and Privacy Protection Act and may be disclosed upon request.*

PV 09553 (04/17) **Note: See attached document for Scope of Registration**



**SCOPE OF CRN REGISTRATION**

Product Description	Model	Design Code	Code Stamp	Material Specifications	Size Range	End Connection Inlet/Outlet	MAWP at MAWT (Note 1,2,3)	Report Number
ASME Safety Relief Valves	Fig. 710 RXSO	ASME Section VIII Division 1	ASME UV	Brass ASME SB283 C37700	1/2", 3/4", 1", 1-1/4", 1-1/2", 2", 2-1/2"	MNPT x FNPT	400 psig at 200°F	R-1141
ASME Safety Relief Valves	Fig. 760 RXSO-S	ASME Section VIII Division 1	ASME UV	Stainless Steel ASME SA351-CF8M, SA479-316	1/2", 3/4", 1", 1-1/4"	MNPT x FNPT	400 psig at 400°F	R-1141

**Note 1:** MAWP = Maximum Allowable Working Pressure, MAWT = Maximum Allowable Working Temperature.

**Note 2:** The pressure-temperature ratings shown are the maximum CRN pressure-temperature ratings. In all cases the pressure-temperature ratings may be limited by the seat and seal materials. Please consult Leslie Controls, Inc.

**Note 3:** For low temperature operation the products shall conform to the rules of the applicable codes under which they are used.

**Note 4:** See attached copy of National Board Listing.

**THIS IS PART OF CRN**  
 0G22625.5  
 Technical Standards and Safety Authority  
 Boilers and Pressure Vessels Safety  
 Program