


UNIFORM STATUTORY DECLARATION FORM FOR THE REGISTRATION OF FITTING DESIGNS

New Brunswick
Nunavut

Nova Scotia
Yukon

Prince Edward Island
Northwest Territories

Newfoundland and Labrador

Manufacturers Name: GUNTNER DE MEXICO, S.A. DE C.V.	
Manufacturers Address: Av. Rogelio Gonzalez Caballero No. 1000, Parque Industrial Sliva, Aeropuerto, 66600 Apodaca, N.L., Mexico	
Plant Locations: SAME AS ABOVE	
<p>Category of Fittings to be registered. Circle one Category only</p> <p>A Pipe fittings, including couplings, tees, elbows, Ys, plugs, unions, pipe caps, or reducers</p> <p>B Flanges: all flanges</p> <p>C Valves: all line valves</p> <p>D Expansion joints, flexible connections, and hose assemblies: all types</p> <p>E Strainers, filters, separators, and steam traps</p> <p>F Measuring devices, including pressure gauges, level gauges, sight glasses, levels, or pressure transmitters</p> <p>G Certified capacity-rated pressure relief devices acceptable as primary over pressure protection on boilers, pressure vessels, piping and fusible plugs</p> <p><input checked="" type="radio"/> H Pressure retaining components that do not fall into one of the above categories</p> <p>N Nuclear components: Class 1 <input type="checkbox"/> Class 2 <input type="checkbox"/> Class 3 <input type="checkbox"/> (Meeting CNSC or ASME requirements)</p>	<p>Title of the Standard of Construction</p> <p>- ASME Section VIII-1</p> <p>- ASME B31.3</p>
<p>Show Manufacturers Name, Trademark, or Logo as it will appear on the product</p> <p align="center"></p>	<p>Type of Construction</p> <p>Forged <input checked="" type="checkbox"/> Welded <input type="checkbox"/> Wrought <input type="checkbox"/></p> <p>Cast <input type="checkbox"/> Other <input type="checkbox"/></p> <p>Describe other:</p>
<p>List of supporting documentation and identification of the actual items to be registered:</p> <p>- SCOPE OF CRN, DRAWINGS, CALCULATIONS, REPORTS</p>	

Declaration:

I, Jamison Dithardt, Product and Solutions Development Manager (see note 3) employed by GUNTNER DE MEXICO, S.A. DE C.V. and being the person having full authority and responsibility for the quality of the end product do solemnly declare that the information contained in this form is true to the best of my knowledge represents the product for which registration is sought. The dimensions, materials of construction, pressure temperature ratings, and identification markings are in accordance with the herein named standards. I further declare that the manufacture of these fittings is regulated by a Quality Control Program which extends to each plant where fabrication occurs in whole or in part and has been verified by TUV-SUD ISO 9001 as being suitable for that purpose and I make this solemn declaration conscientiously believing it to be true, and knowing that it is of the same force and effect as if made under oath.

Signature of Declarer: Jamison Dithardt

Declared before me at ROLLING MEADOWS

This 24th day of JUNE AD 2020

Commissioner of Oaths Linda Downey

Or Notary Public: (sign) Linda Downey

(Affix Official seal to the right)



<p align="center">This space for Regulatory Authority use.</p> <p align="center">This registration must be revalidated after ten (10) years from the date of acceptance.</p>	
<p>CRN: <u>0H16949.5 Rev1</u></p> <p>FID#: <u>2474</u></p> <p>Revision is CRN renewal. 12 different distributor designs (Model 21-4, -5, -6, 26-4, -5, -6, 33-4, -5, -6, 42-4, -5, -6).</p> <p>1. All Fittings shall be registered in the name of the Manufacturer.</p> <p>2. Each Category shall be supported with two Statutory Declaration forms and one copy of supporting documentation.</p> <p>3. The Declaration shall be made by the person having full authority and responsibility for the quality of the end product.</p> <p>4. Quality Control programs shall be resubmitted for validation.</p> <p>Design pressure has increased from 80Bar to 120Bar;</p> <p>Design temperature has increased from 300F to 302F.</p> <p>CRN expires Sept. 1, 2030 - DG</p>	<p align="center">ACCEPTED</p> <p align="center">PROVINCE OF PRINCE EDWARD ISLAND</p> <p align="center">COMMUNITIES, LAND & ENVIRONMENT</p> <p>C.R.N. <u>0H16949.59 Rev1</u></p> <p>DATE: <u>Oct 30/20</u></p> <p align="center"></p> <p align="center">INSPECTION SERVICES SECTION</p> <p align="center">BOILER/PRESSURE VESSEL BRANCH</p> <p align="right">Sept 1, 2030 Fittings Rev.2</p>


UNIFORM STATUTORY DECLARATION FORM FOR THE REGISTRATION OF FITTING DESIGNS

New Brunswick
Nunavut

Nova Scotia
Yukon

Prince Edward Island
Northwest Territories

Newfoundland and Labrador

Manufacturers Name: GUNTNER DE MEXICO, S.A. DE C.V.	
Manufacturers Address: Av. Rogelio Gonzalez Caballero No. 1000, Parque Industrial Silva, Aeropuerto, 66800 Apodaca, N.L., Mexico	
Plant Locations: SAME AS ABOVE	
<p>Category of Fittings to be registered. Circle one Category only</p> <p>A Pipe fittings, including couplings, tees, elbows, Ys, plugs, unions, pipe caps, or reducers</p> <p>B Flanges: all flanges</p> <p>C Valves: all line valves</p> <p>D Expansion joints, flexible connections, and hose assemblies: all types</p> <p>E Strainers, filters, separators, and steam traps</p> <p>F Measuring devices, including pressure gauges, level gauges, sight glasses, levels, or pressure transmitters</p> <p>G Certified capacity-rated pressure relief devices acceptable as primary over pressure protection on boilers, pressure vessels, piping and fusible plugs</p> <p><input checked="" type="radio"/> H Pressure retaining components that do not fall into one of the above categories</p> <p>N Nuclear components: Class 1 <input type="checkbox"/> Class 2 <input type="checkbox"/> Class 3 <input type="checkbox"/> (Meeting CNSC or ASME requirements)</p>	<p>Title of the Standard of Construction</p> <p>- ASME Section VIII-1</p> <p>- ASME B31.3</p>
<p>Show Manufacturers Name, Trademark, or Logo as it will appear on the product</p> <p align="center"></p>	<p>Type of Construction</p> <p>Forged <input type="checkbox"/> Welded <input type="checkbox"/> Wrought <input type="checkbox"/></p> <p>Cast <input type="checkbox"/> Other <input type="checkbox"/></p> <p>Describe other:</p>
<p>List of supporting documentation and identification of the actual items to be registered:</p> <p>- SCOPE OF CRN, DRAWINGS, CALCULATIONS, REPORTS</p>	

Declaration:

I, James O'Hare, Product and Solutions Development Manager (see note 3) employed by GUNTNER DE MEXICO, S.A. DE C.V. and being the person having full authority and responsibility for the quality of the end product do solemnly declare that the information contained in this form is true to the best of my knowledge represents the product for which registration is sought. The dimensions, materials of construction, pressure temperature ratings, and identification markings are in accordance with the herein named standards. I further declare that the manufacture of these fittings is regulated by a Quality Control Program which extends to each plant where fabrication occurs in whole or in part and has been verified by TUV-SUD ISO 9001 as being suitable for that purpose and I make this solemn declaration conscientiously believing it to be true, and knowing that it is of the same force and effect as if made under oath.

Signature of Declarer: James O'Hare

Declared before me at Rolling Meadows

This 24th day of June AD 2020

Commissioner of Oaths Linda Downey

Or Notary Public: (sign) Linda Downey

(Affix Official seal to the right)



<p>This space for Regulatory Authority use.</p> <p align="center">This registration must be revalidated after ten (10) years from the date of acceptance</p> <p>CRN: <u>0H16949.5 Rev1</u></p> <p>FID#: <u>2474</u></p> <p>Revision is CRN renewal. 12 different distributor designs (Model 21-4, -5, -6, 26-4, -5, -6, 33-4, -5, -6, 42-4, -5, -6).</p> <ol style="list-style-type: none"> All Fittings shall be registered in the name of the Manufacturer. Each Category shall be supported with two Statutory Declaration forms and one copy of supporting documentation. The Declaration shall be made by the person having full authority and responsibility for the quality of the end product. Quality Control programs shall be resubmitted for validation. <p>Design pressure has increased from 80Bar to 120Bar; Design temperature has increased from 300F to 302F.</p> <p>CRN expires Sept.1, 2030 - DG</p>	<p align="center">BOILER & PRESSURE VESSEL</p> <p align="center">NOVA SCOTIA</p> <p>Date <u>Oct. 30/20</u></p> <p>C.R.N. <u>0H16949.58REV1</u></p> <p>Dwg. <u>as described</u></p> <p>Signed <u>Yvonne Perry</u></p> <p align="center">1 of 1 Part</p> <p align="center">ACT & REGULATIONS</p> <p align="right">Sect 1.0 - Fittings Rev.2</p>
--	---

UNIFORM STATUTORY DECLARATION FORM FOR THE REGISTRATION OF FITTING DESIGNS

New Brunswick
Nunavut

Nova Scotia
Yukon

Prince Edward Island
Northwest Territories

Newfoundland and Labrador

Manufacturers Name: GUNTNER DE MEXICO, S.A. DE C.V.

Manufacturers Address: Av. Rogelio Gonzalez Caballero No. 1000, Parque Industrial Stiva, Aeropuerto, 66600 Apodaca, N.L., Mexico

Plant Locations: SAME AS ABOVE

Category of Fittings to be registered. Circle one Category only

- A Pipe fittings, including couplings, tees, elbows, Ys, plugs, unions, pipe caps, or reducers
 B Flanges: all flanges
 C Valves: all line valves
 D Expansion joints, flexible connections, and hose assemblies: all types
 E Strainers, filters, separators, and steam traps
 F Measuring devices, including pressure gauges, level gauges, sight glasses, levels, or pressure transmitters
 G Certified capacity-rated pressure relief devices acceptable as primary over pressure protection on boilers, pressure vessels, piping and fusible plugs
☒ H Pressure retaining components that do not fall into one of the above categories

N Nuclear components: Class 1 ☐ Class 2 ☐ Class 3 ☐ , (Meeting CNSC or ASME requirements)

Title of the Standard of Construction

- ASME Section VIII-1
 - ASME B31.3

Show Manufacturers Name, Trademark, or Logo as it will appear on the product



Type of Construction

- Forged ☒ Welded ☐ Wrought ☒
 Cast ☐ Other ☐
 Describe other:

List of supporting documentation and identification of the actual items to be registered:

- SCOPE OF CRN, DRAWINGS, CALCULATIONS, REPORTS

Declaration:

I Jamison Ditthardt, Product and Solutions Development Manager (see note 3) employed by GUNTNER DE MEXICO, S.A. DE C.V. and being the person having full authority and responsibility for the quality of the end product do solemnly declare that the information contained in this form is true to the best of my knowledge represents the product for which registration is sought. The dimensions, materials of construction, pressure temperature ratings, and identification markings are in accordance with the herein named standards. I further declare that the manufacture of these fittings is regulated by a Quality Control Program which extends to each plant where fabrication occurs in whole or in part and has been verified by TUV-SUD ISO 9001 as being suitable for that purpose and I make this solemn declaration conscientiously believing it to be true, and knowing that it is of the same force and effect as if made under oath.

Signature of Declarer: Jamison Ditthardt

Declared before me at ROLLING MEADOWS

This 24th day of JUNE AD 2020

Commissioner of Oaths

Or Notary Public: (sign) Linda Downey

(Affix Official seal to the right)



DEPT OF JUSTICE PUBLIC SAFETY
 BOILER & PRESSURE VESSEL ACT

This registration must be revalidated after ten (10) years from the date of acceptance.

CRN: 0H16949.5 Rev1

FID#: 2474

Revision is CRN renewal. 12 different distributor designs (Model 21-4, -5, -6, 26-4, -5, -6, 33-4, -5, -6, 42-4, -5, -6).

- All Fittings shall be registered in the name of the Manufacturer.
- Each Category shall be supported with two Statutory Declaration forms and one copy of supporting documentation.
- The Declaration shall be made by the person having full authority and responsibility for the quality of the end product.
- Quality Control programs shall be resubmitted for validation.

Design pressure has increased from 80Bar to 120Bar;
 Design temperature has increased from 300F to 302F.

CRN expires Sept.1, 2030 - DG

REGISTRATION ONLY
 CRN 0H16949.57 Rev1

Ram Arora
 CHIEF BOILER INSPECTOR
 DATE 10/30/20

- ☐ BLRs ☐ PVs Sect 1.0 - Fittings Rev.2
☒ FITTINGS ☐ NUCLEAR COMPONENTS


UNIFORM STATUTORY DECLARATION FORM FOR THE REGISTRATION OF FITTING DESIGNS

New Brunswick
Nunavut

Nova Scotia
Yukon

Prince Edward Island
Northwest Territories

Newfoundland and Labrador

Manufacturers Name: GUNTNER DE MEXICO, S.A. DE C.V.	
Manufacturers Address: Av. Rogelio Gonzalez Caballero No. 1000, Parque Industrial Stiva, Aeropuerto, 66600 Apodaca, N.L., Mexico	
Plant Locations: SAME AS ABOVE	
<p>Category of Fittings to be registered. Circle one Category only</p> <p>A Pipe fittings, including couplings, tees, elbows, Ys, plugs, unions, pipe caps, or reducers</p> <p>B Flanges: all flanges</p> <p>C Valves: all line valves</p> <p>D Expansion joints, flexible connections, and hose assemblies: all types</p> <p>E Strainers, filters, separators, and steam traps</p> <p>F Measuring devices, including pressure gauges, level gauges, sight glasses, levels, or pressure transmitters</p> <p>G Certified capacity-rated pressure relief devices acceptable as primary over pressure protection on boilers, pressure vessels, piping and fusible plugs</p> <p><input checked="" type="radio"/> H Pressure retaining components that do not fall into one of the above categories</p> <p>N Nuclear components: Class 1 <input type="checkbox"/> Class 2 <input type="checkbox"/> Class 3 <input type="checkbox"/> (Meeting CNSC or ASME requirements)</p>	<p>Title of the Standard of Construction</p> <p>- ASME Section VIII-1</p> <p>- ASME B31.3</p>
<p>Show Manufacturers Name, Trademark, or Logo as it will appear on the product</p> <div style="text-align: center;">  </div>	
<p>Type of Construction</p> <p>Forged <input type="checkbox"/> Welded <input type="checkbox"/> Wrought <input type="checkbox"/></p> <p>Cast <input type="checkbox"/> Other <input type="checkbox"/></p> <p>Describe other:</p>	
<p>List of supporting documentation and identification of the actual items to be registered:</p> <p>- SCOPE OF CRN, DRAWINGS, CALCULATIONS, REPORTS</p>	

Declaration:

I, Jamison Dillhard, Product and Solutions Development Manager (see note 3) employed by GUNTNER DE MEXICO, S.A. DE C.V. and being the person having full authority and responsibility for the quality of the end product do solemnly declare that the information contained in this form is true to the best of my knowledge represents the product for which registration is sought. The dimensions, materials of construction, pressure temperature ratings, and identification markings are in accordance with the herein named standards. I further declare that the manufacture of these fittings is regulated by a Quality Control Program which extends to each plant where fabrication occurs in whole or in part and has been verified by TUV-SUD ISO 9001 as being suitable for that purpose and I make this solemn declaration conscientiously believing it to be true, and knowing that it is of the same force and effect as if made under oath.

Signature of Declarer: Jamison Dillhard

Declared before me at ROLLING MEADOWS

This 24th day of JUNE AD 2020

Commissioner of Oaths Linda Downey

Or Notary Public: (sign) Linda Downey

(Affix Official seal to the right)



<p>This space for Regulatory Authority use.</p> <p>This registration must be revalidated after ten (10) years from the date of acceptance.</p>	
<p>CRN: 0H16949.5 Rev1</p> <p>FID#: 2474</p> <p>Revision is CRN renewal. 12 different distributor designs (Model 21-4, -5, -6, 26-4, -5, -6, 33-4, -5, -6, 42-4, -5, -6).</p> <p>1. All Fittings shall be registered in the name of the Manufacturer.</p> <p>2. Each Category shall be supported with two Statutory Declaration forms and one copy of supporting documentation.</p> <p>3. The Declaration shall be made by the person having full authority and responsibility for the quality of the end product.</p> <p>4. Quality Control programs shall be resubmitted for validation.</p> <p>Design pressure has increased from 80Bar to 120Bar;</p> <p>Design temperature has increased from 300F to 302F.</p> <p>CRN expires Sept.1, 2030 - DG</p>	<p>Newfoundland Labrador</p> <p>Service NL</p> <p>Registered <u>0H16949.50 Rev1</u></p> <p>Date <u>20/10/30</u></p> <p>Engineering and Inspection Services</p> <p>Registered by <u>[Signature]</u></p> <p>UNDER THE AUTHORITY OF THE PUBLIC SAFETY ACT AND THE BOILER, PRESSURE VESSEL AND COMPRESSED GAS REGULATIONS</p>


UNIFORM STATUTORY DECLARATION FORM FOR THE REGISTRATION OF FITTING DESIGNS

New Brunswick
Nunavut

Nova Scotia
Yukon

Prince Edward Island
Northwest Territories

Newfoundland and Labrador

Manufacturers Name: GUNTNER DE MEXICO, S.A. DE C.V.	
Manufacturers Address: Av. Rogelio Gonzalez Caballero No. 1000, Parque Industrial Stiva, Aeropuerto, 86600 Apodaca, N.L., Mexico	
Plant Locations: SAME AS ABOVE	
Category of Fittings to be registered. Circle one Category only A Pipe fittings, including couplings, tees, elbows, Ys, plugs, unions, pipe caps, or reducers B Flanges: all flanges C Valves: all line valves D Expansion joints, flexible connections, and hose assemblies: all types E Strainers, filters, separators, and steam traps F Measuring devices, including pressure gauges, level gauges, sight glasses, levels, or pressure transmitters G Certified capacity-rated pressure relief devices acceptable as primary over pressure protection on boilers, pressure vessels, piping and fusible plugs <input checked="" type="radio"/> H Pressure retaining components that do not fall into one of the above categories N Nuclear components: Class 1 <input type="checkbox"/> Class 2 <input type="checkbox"/> Class 3 <input type="checkbox"/> , (Meeting CNSC or ASME requirements)	Title of the Standard of Construction - ASME Section VIII-1 - ASME B31.3
Show Manufacturers Name, Trademark, or Logo as it will appear on the product <div style="text-align: center; margin: 10px 0;">  </div>	
Type of Construction Forged <input checked="" type="checkbox"/> Welded <input type="checkbox"/> Wrought <input type="checkbox"/> Cast <input type="checkbox"/> Other <input type="checkbox"/> Describe other:	
List of supporting documentation and identification of the actual items to be registered: - SCOPE OF CRN, DRAWINGS, CALCULATIONS, REPORTS	

Declaration:

I, Jamison Diltzhardt, Product and Solutions Development Manager (see note 3) employed by GUNTNER DE MEXICO, S.A. DE C.V. and being the person having full authority and responsibility for the quality of the end product do solemnly declare that the information contained in this form is true to the best of my knowledge represents the product for which registration is sought. The dimensions, materials of construction, pressure temperature ratings, and identification markings are in accordance with the herein named standards. I further declare that the manufacture of these fittings is regulated by a Quality Control Program which extends to each plant where fabrication occurs in whole or in part and has been verified by TUV-SUD ISO 9001 as being suitable for that purpose and I make this solemn declaration conscientiously believing it to be true, and knowing that it is of the same force and effect as if made under oath.

Signature of Declarer: Jamison Diltzhardt

Declared before me at ROLLING MEADOWS


This 24th day of JUNE AD 2020

Commissioner of Oaths

Or Notary Public: (sign) Linda Downey

(Affix Official seal to the right)



This space for Regulatory Authority use. This registration must be revalidated after ten (10) years from the date of acceptance.	
CRN: <u>0H16949.5 Rev1</u> FID#: <u>2474</u> Revision is CRN renewal. 12 different distributor designs (Model 21-4, -5, -6, 26-4, -5, -6, 33-4, -5, -6, 42-4, -5, -6). 1. All Fittings shall be registered in the name of the Manufacturer. 2. Each Category shall be supported with two Statutory Declaration forms and one copy of supporting documentation. 3. The Declaration shall be made by the person having full authority and responsibility for the quality of the end product. 4. Quality Control programs shall be resubmitted for validation. Design pressure has increased from 80Bar to 120Bar; Design temperature has increased from 300F to 302F. CRN expires Sept.1, 2030 - DG	 <p>GOVERNMENT OF YUKON BY <u>[Signature]</u> CRN <u>0H16949.5Y REV1</u> DATE <u>10/30/2020</u> Sect 1.0 - Fittings Rev.2</p>


UNIFORM STATUTORY DECLARATION FORM FOR THE REGISTRATION OF FITTING DESIGNS

New Brunswick
Nunavut

Nova Scotia
Yukon

Prince Edward Island
Northwest Territories

Newfoundland and Labrador

Manufacturers Name: GUNTNER DE MEXICO, S.A. DE C.V.	
Manufacturers Address: Av. Rogelio Gonzalez Caballero No. 1000, Parque Industrial Silva, Aeropuerto, 86600 Apodaca, N.L., Mexico	
Plant Locations: SAME AS ABOVE	
<p>Category of Fittings to be registered. Circle one Category only</p> <p>A Pipe fittings, including couplings, tees, elbows, Ys, plugs, unions, pipe caps, or reducers</p> <p>B Flanges: all flanges</p> <p>C Valves: all line valves</p> <p>D Expansion joints, flexible connections, and hose assemblies: all types</p> <p>E Strainers, filters, separators, and steam traps</p> <p>F Measuring devices, including pressure gauges, level gauges, sight glasses, levels, or pressure transmitters</p> <p>G Certified capacity-rated pressure relief devices acceptable as primary over pressure protection on boilers, pressure vessels, piping and fusible plugs</p> <p><input checked="" type="radio"/> H Pressure retaining components that do not fall into one of the above categories</p> <p>N Nuclear components: Class 1 <input type="checkbox"/> Class 2 <input type="checkbox"/> Class 3 <input type="checkbox"/> (Meeting CNSC or ASME requirements)</p>	<p>Title of the Standard of Construction</p> <p>- ASME Section VIII-1</p> <p>- ASME B31.3</p>
<p>Show Manufacturers Name, Trademark, or Logo as it will appear on the product</p> <div align="center">  </div>	<p>Type of Construction</p> <p>Forged <input checked="" type="checkbox"/> Welded <input type="checkbox"/> Wrought <input type="checkbox"/></p> <p>Cast <input type="checkbox"/> Other <input type="checkbox"/></p> <p>Describe other:</p>
<p>List of supporting documentation and identification of the actual items to be registered:</p> <p>- SCOPE OF CRN, DRAWINGS, CALCULATIONS, REPORTS</p>	

Declaration:

I, Jessica Elmerit, Product and Solutions Development Manager (see note 3) employed by GUNTNER DE MEXICO, S.A. DE C.V. and being the person having full authority and responsibility for the quality of the end product do solemnly declare that the information contained in this form is true to the best of my knowledge represents the product for which registration is sought. The dimensions, materials of construction, pressure temperature ratings, and identification markings are in accordance with the herein named standards. I further declare that the manufacture of these fittings is regulated by a Quality Control Program which extends to each plant where fabrication occurs in whole or in part and has been verified by TUV-SUD ISO 9001 as being suitable for that purpose and I make this solemn declaration conscientiously believing it to be true, and knowing that it is of the same force and effect as if made under oath.

Signature of Declarer: Jessica Elmerit

Declared before me at ROLLING MEADOWS


This 24th day of JUNE AD 2020

Commissioner of Oaths Linda Downey

Or Notary Public: (sign) Linda Downey

(Affix Official seal to the right)



<p>This space for Regulatory Authority use.</p> <p>This registration must be revalidated after ten (10) years from the date of acceptance.</p> <p>CRN: <u>0H16949.5 Rev1</u></p> <p>FID#: <u>2474</u></p> <p>Revision is CRN renewal. 12 different distributor designs (Model 21-4, -5, -6, 26-4, -5, -6, 33-4, -5, -6, 42-4, -5, -6).</p> <ol style="list-style-type: none"> All Fittings shall be registered in the name of the Manufacturer. Each Category shall be supported with two Statutory Declaration forms and one copy of supporting documentation. The Declaration shall be made by the person having full authority and responsibility for the quality of the end product. Quality Control programs shall be resubmitted for validation. <p>Design pressure has increased from 80Bar to 120Bar; Design temperature has increased from 300F to 302F.</p> <p>CRN expires Sept.1, 2030 - DG</p>	<div align="center">  <p>Northwest Territories</p> <p>REGISTERED</p> <p>UNDER THE AUTHORITY OF</p> <p>THE BOILER AND PRESSURE</p> <p>VESSEL ACT.</p> <p>C.R.N. <u>0H16949.5T Rev1</u></p> <p>SIGNED <u>[Signature]</u></p> <p>DATE <u>Nov 2 2020</u> Fittings Rev.2</p> </div>
--	--


UNIFORM STATUTORY DECLARATION FORM FOR THE REGISTRATION OF FITTING DESIGNS

New Brunswick
Nunavut

Nova Scotia
Yukon

Prince Edward Island
Northwest Territories

Newfoundland and Labrador

Manufacturers Name: GUNTNER DE MEXICO, S.A. DE C.V.	
Manufacturers Address: Av. Rogelio Gonzalez Caballero No. 1000, Parque Industrial Stiva, Aeropuerto, 66600 Apodaca, N.L., Mexico	
Plant Locations: SAME AS ABOVE	
<p>Category of Fittings to be registered. Circle one Category only</p> <p>A Pipe fittings, including couplings, tees, elbows, Ys, plugs, unions, pipe caps, or reducers</p> <p>B Flanges: all flanges</p> <p>C Valves: all line valves</p> <p>D Expansion joints, flexible connections, and hose assemblies: all types</p> <p>E Strainers, filters, separators, and steam traps</p> <p>F Measuring devices, including pressure gauges, level gauges, sight glasses, levels, or pressure transmitters</p> <p>G Certified capacity-rated pressure relief devices acceptable as primary over pressure protection on boilers, pressure vessels, piping and fusible plugs</p> <p>H Pressure retaining components that do not fall into one of the above categories</p> <p>N Nuclear components: Class 1 <input type="checkbox"/> Class 2 <input type="checkbox"/> Class 3 <input type="checkbox"/> , (Meeting CNSC or ASME requirements)</p>	<p>Title of the Standard of Construction</p> <p>- ASME Section VIII-1</p> <p>- ASME B31.3</p>
<p>Show Manufacturers Name, Trademark, or Logo as it will appear on the product</p> 	<p>Type of Construction</p> <p>Forged <input type="checkbox"/> Welded <input type="checkbox"/> Wrought <input type="checkbox"/></p> <p>Cast <input type="checkbox"/> Other <input type="checkbox"/></p> <p>Describe other:</p>
<p>List of supporting documentation and identification of the actual items to be registered:</p> <p>- SCOPE OF CRN, DRAWINGS, CALCULATIONS, REPORTS</p>	

Declaration:

I, Jamison Dillhardt, Product and Solutions Development Manager (see note 3) employed by GUNTNER DE MEXICO, S.A. DE C.V. and being the person having full authority and responsibility for the quality of the end product do solemnly declare that the information contained in this form is true to the best of my knowledge represents the product for which registration is sought. The dimensions, materials of construction, pressure temperature ratings, and identification markings are in accordance with the herein named standards. I further declare that the manufacture of these fittings is regulated by a Quality Control Program which extends to each plant where fabrication occurs in whole or in part and has been verified by TUV-SUD ISO 9001 as being suitable for that purpose and I make this solemn declaration conscientiously believing it to be true, and knowing that it is of the same force and effect as if made under oath.

Signature of Declarer: Jamison Dillhardt

Declared before me at ROCKING MEADOWS

This 24th day of JUNE AD 2020

Commissioner of Oaths Linda Downey

Or Notary Public: (sign) Linda Downey

(Affix Official seal to the right)

LINDA DOWNEY
Use this space for the Official Seal
Notary Public - State of Illinois
My Commission Expires Nov 20, 2021

<p>This space for Regulatory Authority use.</p> <p>This registration must be revalidated after ten (10) years from the date of acceptance.</p> <p>CRN: <u>0H16949.5 Rev1</u></p> <p>FID#: <u>2474</u></p> <p>Revision is CRN renewal. 12 different distributor designs (Model 21-4, -5, -6, 26-4, -5, -6, 33-4, -5, -6, 42-4, -5, -6).</p> <ol style="list-style-type: none"> All Fittings shall be registered in the name of the Manufacturer. Each Category shall be supported with two Statutory Declaration forms and one copy of supporting documentation. The Declaration shall be made by the person having full authority and responsibility for the quality of the end product. Quality Control programs shall be resubmitted for validation. <p>Design pressure has increased from 80Bar to 120Bar; Design temperature has increased from 300F to 302F.</p> <p>CRN expires Sept.1, 2030 - DG</p>	<p>NUNAVUT</p> <p>Pressure Vessels Act</p> <p>REGISTERED</p> <p>CRN <u>0H16949.5 N Rev1</u></p> <p>Date <u>OCT 30, 2020</u></p> <p>Signed <u>[Signature]</u></p> <p>Sect 1.0 - Fittings Rev.2</p> <p>Territorial Registration Fee</p>
--	---