



TECHNICAL STANDARDS &
SAFETY AUTHORITY
14th Floor, Centre Tower
3300 Bloor Street West
Toronto, Ontario
Canada M8X 2X4

Show facsimile of manufacturer's logo or trademark, as it will
appear on the fitting, in the space below

'Apollo' Valves
Manufactured by Conbraco Industries Inc.

STATUTORY DECLARATION

Registration of Fittings

I, DAVID EDMONDS, SENIOR PRODUCT ENGINEER

(Name and Position, e.g. President, Plant Manager, Chief Engineer)

of CONBRACO INDUSTRIES, INC.

(Name of Manufacturer)

Located at 1418 S. PEARL STREET, PAGELAND, SC 29728, USA

(Plant Address)

843-672-6161

(Telephone No.)

843-672-1648

(Fax No.)



do solemnly declare that the fittings listed hereunder, which are subject to the **Technical Standards and Safety Act**, Boilers and Pressure Vessels Regulation, comply with all of the requirements of
ASME B31.3

(Title of recognized North American Standard)

which specifies the dimensions, materials of construction, pressure/temperature ratings, identification marking the fittings and service;



or are not covered by the provisions of a recognized North American standard and are therefore manufactured to comply with
as supported by the attached data which identifies the dimensions, material of construction, pressure/temperature ratings and the basis for such ratings, the marking of the fitting for identification and service.

I further declare that the manufacture of these fittings is controlled by a quality system meeting the requirements of ISO:9001:2008
which has been verified by the following authority, TUV

The items covered by this declaration, for which I seek registration, are category C - BALL VALVES type fittings. In support of
this application, the following information and/or test data are attached as follows:
SCOPE OF CRN, DRAWINGS, CALCULATIONS, REPORTS


(drawings, calculations, test reports, etc.)

Declared before me at Pageland, South Carolina in the County Chesterfield
the 26th day of January AD 2016

Commissioner for Oaths:

Nancy Strawn
(Printed name)

Nancy Strawn
(Signature)



[Signature]
(Signature of Declarer)

FOR OFFICE USE ONLY


To the best of my knowledge and belief, the application meets the requirements of the
Technical Standards and Safety Act, Boilers and Pressure Vessels Regulation, and
CSA Standard B51 and is accepted for registration in Category C

CRN: OC109085ADD10

Registered by: K. Ka

Dated: June 17/16

NOTE: This registration expires on Mar 7/2026



See three pages of attachments for scope
and two pages for manufacturing locations. KK
6/17/16

CONBRACO INDUSTRIES INC.
701 MATTHEWS-MINT HILL ROAD
MATTHEWS, NC
USA, 28105

CRN OC 109085ADD10

**Technical Standards & Safety Authority
Boilers & Pressure Vessels
Safety Program**

16-Jun-16

Page 1 of 3

FLOATING TYPE BALL VALVES - SCOPE OF CRN REGISTRATION

[illegible]

THIS IS PART OF
CRN 0C10908.5 ADD 10

Technical Standards & Safety Authority
Boilers & Pressure Vessels

Page 2 of 3

FLOATING TYPE BALL VALVES - SCOPE OF CRN REGISTRATION CONTINUED

Valve Series	Valve Models	Material Description	Material Specification	Design Code	Size Range	Connections	CRN MAWP at 100F (Note 1)	CRN MAWP at 406F (Note 1)	MDMT	Design Report #
70LF-100	70LF-100 70LF-140	Lead Free Bronze and Brass	ASTM B584-C89836 ASTM B927-C27451	ASME B31.3, MSS SP-110	1/4" thru 3"	NPT, Solder	600 psig	250 psig	- 20F	R-0605-2
70LF-200	70LF-200 70LF-240									
70LF-300	70LF-300 70LF-340									
70LF-400	70LF-400 70LF-440									
77C	77C-100 77C-140 77C-100-UL 77C-200 77C-240 77C-200-UL 77C-800	Bronze and Brass	ASTM B584-C84400 ASTM B283-C37700 ASTM B16-C36000	ASME B31.3 MSS SP-110	1/4" thru 2"	NPT, Solder	600 psig	425 psig	- 20F	R-0605-3
77CLF	77CLF-100 77CLF-140 77CLF-200 77CLF-240	Lead Free Bronze and Brass	ASTM B584-C89836 ASTM B927-C27451 ASTM B16-C36000	ASME B31.3, MSS SP-110	1/4" thru 2"	NPT, Solder	600 psig	250 psig	- 20F	R-0605-4
82	82-100 82-140 82-200 82-400	Bronze and Brass	ASTM B584-C84400 ASTM B16-C36000	ASME B31.3 MSS SP-110	1/4" thru 4"	NPT, Solder	600 psig	425 psig	- 20F	R-0605-5
82-LF	82LF-100 82LF-140 82LF-200 82LF-240	Lead Free Bronze and Brass	ASTM B584-C89836 ASTM B927-C27451 ASTM B16-C36000	ASME B31.3, MSS SP-110	1/4" thru 4"	NPT, Solder	600 psig	250 psig	- 20F	R-0605-6
95	95A 95-100 95-200	Bronze and Brass	ASTM B584-C84400 ASTM B283-C37700 ASTM B62-C83600 ASTM B16-C36000	ASME B31.3 MSS SP-110	1/2" thru 1"	NPT, Solder	600 psig	425 psig	- 20F	R-0605-7
95	95ALF	Lead Free Bronze and Brass	ASTM B584-C89836 ASTM B927-C27451 ASTM B16-C36000	ASME B31.3, MSS SP-110	1/2" thru 1"	NPT, Solder	600 psig	250 psig	- 20F	R-0605-8
71-AR	71-AR	Bronze and Brass	ASTM B584-C84400 ASTM B16-C36000	ASME B31.3 MSS SP-110	3/4" thru 3"	NPT, Solder	600 psig	425 psig	- 20F	R-0605-9

FLOATING TYPE BALL VALVES - SCOPE OF CRN REGISTRATION CONTINUED

Valve Series	Valve Models	Material Description	Material Specification	Design Code	Size Range	End Connections	CRN MAWP at 100F (Note 1)	CRN MAWP at 406F (Note 1)	MDMT	Design Report #
77-AR	77-AR	Bronze and Brass	ASTM B584-C84400 ASTM B16-C36000	ASME B31.3 MSS SP-110	1/4" thru 2"	NPT, Solder	600 psig	425 psig	- 20F	R-0605-10
32-100	32-100	Bronze and Brass	ASTM B584-C84400 ASTM B16-C36000	ASME B31.3 MSS SP-110	1/4" thru 2"	NPT, Solder	400 psig	285 psig	- 20F	R-0605-11
32-200	32-200									
50GB	50GB GB50 GB50-A	Bronze and Brass	ASTM B584-C84400 ASTM B16-C36000	ASME B31.3 MSS SP-110	1/2" thru 2"	NPT, Solder	250 psig	250 psig	- 20F	R-0605-12
70-600	70-600 70-640	Bronze and Brass	ASTM B584-C84400 ASTM B283-C37700 ASTM B16-C36000	ASME B31.3 MSS SP-110	1/4" thru 2"	NPT, Solder	400 psig	285 psig	- 20F	R-0605-13
70-900	70-900									
7B	7B-100 7B-300 7B-800	Bronze and Brass	ASTM B584-C84400 ASTM B16-C36000	ASME B31.3 MSS SP-110	1/4" thru 2"	NPT, Solder	400 psig	285 psig	- 20F	R-0605-14
79	79 79-700	Brass	ASTM B283-C37700 ASTM B16-C36000 ASTM B75-C12200	ASME B31.3 ASME B31.5 MSS SP-110	3/8" thru 3-1/8"	Tube	500 psig	N/A	ASME B31.5 Grp. 2	R-0605-15

Note 1: The pressure-temperature ratings shown are the maximum CRN pressure-temperature ratings. In all cases the MAWP may be limited by the seat or seal material or other considerations. Please consult Conbraco / Apollo valve literature.

Note 2: See attached list of manufacturing locations applicable to this CRN.

THIS IS PART OF
CRN 0C10908.5 ADD10
Technical Standards & Safety Authority
Boilers & Pressure Vessels
Safety Program


CERTIFICATE

TUV Rheinland of North America, Inc.

1300 Massachusetts Avenue, Suite 103, Boxborough, MA 01719



Hereby certifies that



Conbraco Industries, Inc.



**701 Matthews-Mint Hill Road
Matthews, NC 28105**

has established and maintains a quality management system for the

**Design and Manufacture of Flow and Pressure Relief Valves for
Residential, Industrial and Medical Applications Under the Apollo
Trademark; The Provision of Contract Calibration Services**

An audit was performed and documented in Report No 2418.
Proof has been furnished that the requirements according to

ISO 9001:2008

are fulfilled.

Further clarification regarding the scope of this certificate and the applicability of
ISO 9001:2008 requirements may be obtained by contacting TRNA.

Certificate Registration No.

74 300 2418

Certificate Issue Date
December 01, 2015

Certificate Expiration Date
September 14, 2018

Revised 11/30/2015
Certification Decision 11/30/2015




Certification of Management Systems

APPENDIX

TUV Rheinland of North America, Inc.

1300 Massachusetts Avenue, Suite 103, Boxborough, MA 01719



This appendix lists the sites certified under Certificate Number

74 300 2418, valid until **September 14, 2018**

For



Conbraco Industries, Inc.




SITE ADDRESS	ACTIVITIES RELATING TO:
701 Matthews-Mint Hill Road Matthews, NC 28105	Corporate HQ; Sales and Customer Service
1418 S. Pearl Street Pageland, SC 29728	Design, Manufacturing, Calibration & Distribution and Customer Service
1509 South Van Lingle Mungo Blvd Pageland, SC 29728	Foundry & Machining Operations
125 Highway 501 East Conway, SC 29526	Foundry & Manufacturing Operations

This appendix is only valid in conjunction with the referenced certificate.

Revised 11/30/2015
Certification Decision Date 11/30/2015




Certification of Management Systems