



July 10, 2014

Attention: Tanya Francis
TECHNICAL STANDARDS & SAFETY AUTHORITY
3300 BLOOR STREET WEST
14 FLOOR CENTRE TOWER
TORONTO, ON M8X 2X4

The design submission, tracking number 2014-04206, originally received on May 20, 2014 was surveyed and accepted for registration as follows:

CRN : 0A16089.52 **Accepted on:** July 10, 2014

Reg Type: New Design **Expiry Date:** June 14, 2023

Drawing No. : PER ATTACHMENT A As Noted

Fitting type: CNG AND H2 REFUELING FITTINGS

Design registered in the name of : WEH GMBH VERBINDUNGSTECHNIK

The registration is conditional on your compliance with the following notes:

This registration is accepted based on our understanding that the fittings subject to this registration are to be used only in Compressed natural gas and Hydrogen refueling station pressure piping systems and ground storage vessels in accordance with CSA B51-14, Part 3.

It is our understanding that the proof tests performed for validations of the design of these fittings are in compliance with Clause 5.1.4 of CSA B51-14, Part 3.

This registration is valid only for fittings fabricated at the location(s) covered by the QC certificate attached to the accepted AB-41 Statutory Declaration form. This registration is valid only until the indicated expiry date only if the Manufacturer maintains a valid quality management system approved by an acceptable third-party agency until that date. Should the approval of the quality management system lapse before the expiry date indicated above, this registration shall become void.

An invoice covering survey and registration fees will be forwarded from our Revenue Accounts.

Enclosed are stamped prints for your reference.

Sincerely,

PETRUSEVSKI, LJUPCO (LOU)

November 12, 2014

ANDREAS WILLFORT
WEH GMBH PRECISION CONNECTORS
JOSEF-HENLE STR 1
IIIERTISSEN BAVARIA 89257
DE

Service Request Type.: BPV-National AB
Service Request No.: 1396050
Your Reference No.: Z-84777, Z-61298, Z-66500, Z-109544, Z-20260, Z-104034, Z-55562
Registered to.: WEH GMBH PRECISION CONNECTORS

Dear ANDREAS WILLFORT,

Please find enclosed the original response from AB, registered under the CRN No.: 0A16089.52.

As all jurisdictional fees are handled by the Technical Standards and Safety Authority (TSSA), you do not pay any jurisdictions directly.

Should you have any questions or require further assistance, I will be happy to assist you. For general enquiries, please contact a Customer Service Advisor at 1.877.682.TSSA (8772) or e-mail customerservices@tssa.org. When contacting TSSA regarding this file, please refer to the Service Request number provided above.

Yours truly,

Tanya Francis
Administrative Assistant_ BPV Engineering
Tel. : 416-734-3423
Fax : 416-231-6183
Email : tfrancis@tssa.org



the pressure equipment safety authority

STATUTORY DECLARATION
Registration of Fittings



I, Wiest Reinhold,

Managing Director

(company title, e.g. vice president, plant manager, chief engineer) (must be in a position of authority)

of WEH GmbH Verbindungstechnik

(name of manufacturer)

located at Josef-Henle Str.1, D-89257 Illertissen, Germany

(plant address)

do solemnly declare that the fittings listed hereunder, which are subject to the Safety Codes Act (check one)

comply with the requirements of _____ which specifies the dimensions, (title of recognized North American Standard)

are not covered by the provisions of a recognized North American standard and are therefore manufactured to comply with PED 97/23/EC III Modul H as supported by the attached data which identifies the dimensions, materials of construction, pressure/temperature ratings and the basis for such ratings, and the marking of the fittings for identification.

I further declare that the manufacture of these fittings is controlled by a quality control program which has been verified by the following authority, ISO 9001/2008 as being suitable for the manufacture of these fittings to the stated standard. The fittings covered by this declaration, for which I seek registration, are _____

In support of this application, the following information, calculations and/or test data are attached:

Drawing Z-55562, Gas Catalogue 20, TW54 Operating Instructions, TW54 Datasheet, TW54 Conformity Declaration

DECLARED before me at 23rd in the _____ of _____

this 23rd day of March, 2012
(Month) (Year)

(print) _____

(sign) _____

(A Commissioner for Oaths)

Wiest Reinhold
(Signature of Applicant)

For Office Use Only

See Acceptance Letter for the comments and/or conditions of registration.

To the best of my knowledge and belief, the application meets the requirements of the Safety Codes Act and CSA Standard B51, Clause 4.2, and is accepted for registration in Category A

Registration Number: 0A16089.52

Date Registered: JUL 10 2014

(For the Administrator/Chief Inspector of Alberta)

Expiry Date: JUNE 14, 2023

URNr. 0753 /2012

I, the undersigned, hereby certify that this document was signed before me the 23th day of march 2012 by

Mr. Reinhold **Wiest**

born on 24th day of february 1955,
of 89257 Illertissen, Auer Straße 37, Germany,
acting on behalf of

Weh GmbH, Verbindungstechnik

having its place of business at Illertissen (89257 Illertissen,
Josef-Henle-Straße 1, Germany).

0 A 1 6 0 8 9 . 5 2


Mr. Reinhold Wiest is personally known to me.

Upon an inspection of the commercial register
(Amtsgericht Memmingen, HRB 3086) on 23th day of march 2012

I further certify that Mr. Reinhold Wiest is fully authorized to represent
the said corporation, acting as its individual authorized Managing Director.

Illertissen, 23th day of march 2012

Value: € 20.000,--



Notary Dr. Reinhard Kössinger

A handwritten signature in black ink, appearing to be 'RK' with a flourish.

ATTACHMENT A

SCOPE OF REGISTRATION for OA16089.5

This registration comprised of the following:

Drawing #	WEH Catalogue #
Z-20260	TVR1
Z-20880	TK22
Z-55562	TW54 Proof test data submitted is for dwg Z-63953 the TW54B which differs from Z-55562 by handle actuation method, no change to pressure boundary
Z-55739	TW57B
Z-61293	TW157
Z-66500	TW157 Note: Common proof test for both Z-61293 and Z-66500 which are both TW157 and differ in parts outside the pressure boundary only
Z-84777	TN1
Z-104034	TW152
Z-109544	TN5

There are 3 designs which were registered in SK and QC which have separate CRNs and are sent under separate cover

These are:

Z-85507,	TW57B	OA15073.5
Z-62946,	TW52	OA15075.5 and
Z-72192,	TW42	OA13109.5

All designs are qualified by proof tests, witnessed by a qualified TUV inspector. The materials of construction are listed in the packages. MAWPs are limited to the nominal pressures quoted on their respective declarations of conformance

ASCA
SAFETY CODES ACT - PROVINCE OF ALBERTA
REGISTRATION OF FITTINGS
REGISTRATION NO. 0 A 1 6 0 8 9 5 2
DWG. NO. or CAT. NO. Per Attachment A *As Noted*
TYPE OF FITTINGS CNG + HZ Refueling Fitting
Date JUL 10 2014 INITIALS [Signature]
LUPCO PETRUSEVSKI
DESIGN SURVEYOR

See Acceptance Letter for the comments and/or conditions of registration.

