

REGISTRATION OF ALTERATION

31-Mar-22

Round Engineering Inc.
10 Segwun Rd.
Waterdown, Ontario
L8B 0K6

Attention: Scott Islip

File Number: 54278 [0V]

Re: Company Performing Alteration: API Heat Transfer

Manufacturer: Basco Div., A.P.I. Inc.

Item: Tube Bundle c/w Stationary and Floating Tubesheets

Manufacturer's Serial Number: 900265-011

Drawing Number: 2525-08-066-038 Rev. 1

TSASK Codes and Standards Compliance has registered the design listed above in accordance with The Boiler and Pressure Vessel Act and Regulations. The Canadian Registration Number (CRN) is:

A1473.3

This item was registered with the following design conditions:


MAWP:	517 kPa	Design Temp:	268 °C
MDMT:	-7 °C	Corrosion Allowance:	0 mm

Please note that every piece of equipment must be constructed in strict accordance with the registered design.

This letter is not an approval for the commencement of the alteration. Please be advised that an alteration nameplate is required. Contact your local TSASK inspector for approval to begin work and to identify any additional requirements that may be imposed by the inspector. Please ensure that the contractor performing this work has a quality program approved by TSASK for use in the Province of Saskatchewan.

Should you require anything further, please do not hesitate to contact the Codes and Standards Compliance Office at your convenience.

Yours truly,


Williams Uju, P.Eng.
Codes and Standards Compliance

Cc: Equipment Services
Dave Aspinall / Ben Blain / Samiullah Ansari (District Inspector)

Remarks:

The MAWP and design temperature of the tubeside are 1034 kPa and 93 C, respectively.

Original vessel drawing #: 70A15A08066 Rev. 4.

An alteration nameplate shall be attached to the vessel.