

June 14, 2022

Attention: Scott Islip
ROUND ENGINEERING INC
10 SEGWUN ROAD
WATERDOWN, ON L8B 0K6

The design submission, tracking number 2022-02815, originally received on May 19, 2022 was surveyed and accepted for registration as follows:

CRN : Z6564.2

Accepted on: June 14, 2022

Reg Type: NEW DESIGN

Drawing No. : CT-1068, CT-1069

Design registered in the name of : COLUMBIA BOILER COMPANY

Description	MAWP	Design Temperature
MAWP	1034kPa	170 °C

The registration is conditional on your compliance with the following notes:

Registration is accepted on the basis that the design is as per ASME Section I, 2021 edition.


An invoice covering survey and registration fees will be forwarded from our Revenue Accounts.

If you have any question don't hesitate to contact me by phone at (780) 433-0281 ext 3362 or fax (780) 437-7787 or e-mail Blair@absa.ca.

Sincerely,



BLAIR, JODY, P. Eng.



Registered by: ONSHCHENKO, TETYANA, P. Eng.
DOP Cert. No. D00010125