

February 28, 2025

**Attention:** Cecylia Garbacz  
TECHNICAL STANDARDS & SAFETY AUTHORITY  
345 CARLINGVIEW DRIVE  
TORONTO, ON M9W 6N9

The design submission, Tracking Number 2025-01066, Web Portal Number 2025-S0883, originally received on February 18, 2025 was surveyed and accepted for registration as follows:

**CRN :** 0A24088.52 **Accepted on:** February 28, 2025  
**Reg Type:** ADDITION TO ACC. FITTING **Expiry Date:** July 21, 2032  
**Drawing No. :** Update of company logo only with no changes in the Scope  
**Fitting type:** CAST/WROUGHT COPPER ALLOY PIPE FITTING  
Design registered in the name of : VERYLIKE CO LTD

**The registration is conditional on your compliance with the following notes:**

*\*\* Design Report #: R-1504 Rev 0*

*\*\* The pipe fitting material, dimensions, marking, wall thickness and tolerances shall be strictly complied with ASME B16.18 and B16.22*

*As indicated on AB-41 Statutory Declaration or AB-351 Declaration of Conformity form and submitted documentation, the code of construction is other engineering analysis.*

- It is our understanding that the fitting(s), included as the scope of this submission, that is(are) subject to the Safety Codes Act shall comply with the requirements of the indicated Standard or Code of Construction on the AB-41 Statutory Declaration or AB-351 Declaration of Conformity as supported by the attached data which identifies the dimensions, materials of construction, press./temp. ratings and the basis for such ratings, and the identification marking of the fittings.*
- This registration is valid only for fittings fabricated at the location(s) covered by the QC certificate attached to the accepted AB-41 Statutory Declaration or AB-351 Declaration of Conformity form.*
- This registration is valid only until the indicated expiry date and only if the Manufacturer maintains a valid quality management system approved by an acceptable third-party agency, and maintains a valid Certification of Authorization Permit if required by the jurisdiction where manufacturing takes place, until that date.*
- Should the approval of the quality management system lapse before the expiry date indicated above, this registration shall become void.*

An invoice covering survey and registration fees will be forwarded from our Revenue Accounts.

If you have any question don't hesitate to contact me by phone at (587) 686-9390 or fax (780) 437-7787 or e-mail Robb@absa.ca.

Sincerely,



ROBB, BENJAMIN



Registered by: RADISAVLJEVIC, ZANA, P. Tech. (Eng.)  
DOP Cert. No. D00003136

**STATUTORY DECLARATION  
Registration of Fittings**  
Single or Multiple Fitting Designs within one Fitting Category

I, Robbie Hung, General Manager  
(name of applicant) (position title) (must be in a position of authority)  
of Verylike Co., Ltd.  
(name of manufacturer)

located at No. 335, Sec. 4, Lu-Ho Rd., Lu-Kang, Changhua, Taiwan (50543)  
(plant address)



do solemnly declare that the fittings listed hereunder, which are subject to the Safety Codes Act (select only one)

- comply with the requirements of ASME B16.18, B16.22 which specifies the dimensions, materials of construction, pressure/temperature ratings and identification marking of the fittings, or  
(title of recognized North American Standard)
- are not covered by the provisions of a recognized North American standard and are therefore manufactured to comply with \_\_\_\_\_ as supported by the attached data which identifies the dimensions, materials of construction, pressure/temperature ratings and the basis for such ratings, and the identification marking of the fittings.  
(title of code of construction or other applicable document)

I further declare that the manufacture of these fittings is controlled by a quality control program which has been verified as described in the below Table as being suitable for the manufacturing of these fittings to the stated standard, regulation, code, guideline or other applicable document. The fittings covered by the declaration for which I seek registration are as provided in the Supplementary Sheet(s) attached.

**Quality Program Verification and Manufacturing Sites**

A copy of the Quality Certificate from each manufacturing site must be included

Item #	Product Description, Model or Series	Quality Program	Scope of Certification	Expiry Date	Verifying Organization	Location(s) Plant Name and address
1.	Pipe Fittings	ISO 9001:2015	Manufacture and Sales	2027-10-17	EUROCERT	Changhua, Taiwan
2.						

In support of this application, the following information, calculations and/or test data are attached:

Scope of CRN, Drawings, Reports

Kell Hing  
(Signature of the Declarer)

5/11/2024  
(Date)

DECLARED before me at Lu-kang in the Country of Changhua  
(city) (province, territory, or state)  
this 5 day of 11, 2024  
(Month) (Year)

(print) \_\_\_\_\_  
(a Commissioner of Oaths or Notary Public)

(sign) \_\_\_\_\_  
(a Commissioner of Oaths or Notary Public)

\_\_\_\_\_  
(expiry date (mm/dd/yy))

Commissioner of Oaths / Notary Public in and for: \_\_\_\_\_  
(province, territory, or state)

**For ABSA Office Use Only:**

NOTES: **\*\* Cast/Wrought Copper Alloy Pipe Fitting**

**\*\* See attached Scope of CRN Registration**

To the best of my knowledge and belief, the application meets the requirements of the Safety Codes Act and CSA Standard B51, Part 1, Clause 4.2, and is accepted for registration in Category A.

CRN: \_\_\_\_\_

Registered Date: 2025-02-28

Expiry Date: 2032-07-21

Signature: \_\_\_\_\_

(Signature of the Administrator/SCO)

The information you provide is necessary only for the administration of the programs as required by the Alberta Safety Codes Act and Regulations in the Pressure Equipment Discipline

2025-01066

**ABSA**

SAFETY CODES ACT - PROVINCE OF ALBERTA

**ACCEPTED: OA24088.52**

**See acceptance letter for conditions of registration.**

Date: 2025-02-28

Registered by:

ZANA RADISAVLJEVIC, P. Tech. (Eng.)

BENJAMIN ROBB

DOP: D00003136

Zana Radisavljevic

BOR

This stamp and signature have been affixed electronically to this registered design as required by Section 20(1) of the Pressure Equipment Safety Regulation, in accordance with the Electronic Transactions Act

## 見證書

申請人：全好有限公司，公司統一編號：22213442，公司  
登記營業地址：彰化縣鹿港鎮頂番里鹿和路四段 335 號。

法定代理人：洪瑞忠，男，身分證字號：N123727471

見證事項：印鑑章

茲證明全好有限公司法定代理人洪瑞忠於二〇二四年  
十一月五日在本見證人面前，於本見證書前附英文文  
件上親自加蓋全好有限公司及法定代理人之印鑑章。

見證人：劉妍孝律師



二〇二四年十一月五日

## Notarial Certificate

Applicant: VERYLIKE CO., LTD

Government Uniform Invoice number: 22213442

Location: No. 335, Sec. 4, Lu-Ho Rd., Lu-Kang, Changhua, Taiwan  
(50543)

Legal representative: Hung Jui Chung, male, ID number: N123727471

Notarization matter: The Seal of the witness

Entrusted agent: Lui Yan Xiao lawyer

This is to certify that the entrusted agent has affixed the seal on the  
English documents before the notary public on November , 2024

Entrusted agent: Lui Yan Xiao lawyer

November 5 , 2024



# VERYLIKE

## SCOPE OF CRN REGISTRATION CONTINUED

VERYLIKE Item Number Listing							
Item No.	Size	Item No.	Size	Item No.	Size	Item No.	Size
71314	3/4" X 1/2" X 3/4"	71337	2" X 2" X 1"	71507	1 1/4"	76001	1 1/4" X 3/4"
71320	1/2"	71339	1 1/4" X 1 1/4" X 1"	71508	1 1/2"	71467	3/4"
71322	3/4"	71320WD	1/2"	71509	2"	71468	1"
71323	3/4" X 3/4" X 1/2"	71340	1/2"	71512	4"	71469	1/2"
71324	1/2" X 1/2" X 3/4"	71342	3/4"	71551	3/4" X 1/2"	72505	3/4"
71326	1" X 1" X 1/2"	71344	1" X 1/2" X 1"	71604	1/2"	71606W	1"
71327	1" X 1" X 3/4"	71345	1" X 3/4" X 1"	71605	3/4"	71607W	1 1/4"
71328	1 1/4" X 1 1/4" X 1/2"	71390	1/2"	71606	1"	71608W	1 1/2"
71329	1 1/4" X 1 1/4" X 3/4"	71504	1/2"	71607	1 1/4"	71609W	2"
71335	1 1/2" X 1 1/2" X 1"	71505	3/4"	71608	1 1/2"		
71336	1"	71506	1"	71609	2"		

**Note 1:** MDMT = Minimum Design Metal Temperature.

**Note 2:** Alternative material grades in accordance with ASME B16.18 para. 6 and ASME B16.22 para. 6 may be also be supplied.

**Note 3:** Pressure-temperature ratings of brazed joints are in accordance with ASME B16.18 Table 3.1-1 and ASME B16.22 Table 3.1.1-2 which are shown above. For solder joints the safe pressure-temperature rating of a solder-joint piping system is dependent, not only on the valve, fitting and tubing strength, but also on the composition of the solder used for the joints. Therefore for solder joints the pressure-temperature ratings of the system shall be the lowest of the values shown in ASME B16.18 Table 3.1-1 and ASME B16.22 Table 3.1.1-2 above or that of the solder joint. Pressure-temperature limitations for solder joints made with typical commercial solders are given in Non Mandatory Appendix A of ASME B16.18 and Table I-1 of ASME B16.22. It shall be the responsibility of the user to select a solder composition that is compatible with the service conditions, as well as to assure the adequacy of workmanship employed in making the joints.

**Note 4:** For low temperature operation the products shall conform to the rules of the applicable codes under which they are used.

**Note 5:** The internal pressure rating applies to the largest opening of the fitting.