

## REGISTRATION OF A BOILER OR PRESSURE VESSEL DESIGN

08-Dec-22

TSSA  
345 Carlingview Drive  
Toronto, Ontario  
M9W 6N9

**Attention: Cecylia Garbacz**

**File Number: 63347 [ 0V]**

**Re: Manufacturer: Watson McDaniel**  
**Item: PMPC Tank**  
**Drawing Number: 2189100 Sheets 1 & 2 Rev. I & 0197900 Rev. E**

TSASK Codes and Standards Compliance has registered the design listed above in accordance with The Boiler and Pressure Vessel Act and Regulations. The Canadian Registration Number (CRN) is:

**R8690.53**

This item was registered with the following design conditions:

<b>MAWP:</b> 1379 kPa	<b>Design Temp:</b> 343 °C
<b>MDMT:</b> -29 °C	<b>Corrosion Allowance:</b> 1.6 mm

Please note that every piece of equipment must be constructed in strict accordance with the registered design.

In addition to stamping every unit with the CRN given, and as required in CSA B51, a Manufacturer's Data Report shall be forwarded to this office at the time the unit is shipped. The Manufacturer's Data Report form is available on the TSASK website at [www.tsask.ca](http://www.tsask.ca).

Should you require anything further, please do not hesitate to contact the Codes and Standards Compliance Office at your convenience.

Yours truly,



Athan Syrgiannis, P.Eng.  
Codes and Standards Compliance

**Remarks:**

CRN issuance based upon review and registration by another province.

Design Report R-1548 Rev. 0 (22-Aug-22) is included in this registration.