

March 14, 2023

Attention: Scott Islip
ROUND ENGINEERING INC
10 SEGWUN ROAD
WATERDOWN, ON L8B 0K6

The design submission, Tracking Number 2023-01324, Web Portal Number 2023-S0766, originally received on March 03, 2023 was surveyed and accepted for registration as follows:

CRN : 0H13343.2 **Accepted on:** March 14, 2023
Reg Type: RENEWAL **Expiry Date:** March 14, 2033
Drawing No. : 300-0000364961 Rev 1 As Noted
Fitting type: HVAC AIR COOLED EXCHANGER
Design registered in the name of : GUNTNER DE MEXICO SA DE CV

Description	MAWP	Design Temperature	MDMT
Internal Pressure	11997 kPa	140 °C	-100 °C

The registration is conditional on your compliance with the following notes:


- This registration has been issued based on the understanding that this equipment will be placed in refrigeration or air conditioning systems ONLY. The units will have to be marked and documented as required by Code ("UM").

- As indicated on AB-41 Statutory Declaration or AB-351 Declaration of Conformity form and submitted documentation, the code of construction is SECTION VIII, DIV. 1. It is our understanding that the fitting(s), included as the scope of this submission, that is(are) subject to the Safety Codes Act shall comply with the requirements of the indicated Standard or Code of Construction on the AB-41 Statutory Declaration or AB-351 Declaration of Conformity as supported by the attached data which identifies the dimensions, materials of construction, press./temp. ratings and the basis for such ratings, and the identification marking of the fittings. This registration is valid only for fittings fabricated at the location(s) covered by the QC certificate attached to the accepted AB-41 Statutory Declaration or AB-351 Declaration of Conformity form. This registration is valid only until the indicated expiry date and only if the Manufacturer maintains a valid quality management system approved by an acceptable third-party agency, and maintains a valid Certification of Authorization Permit if required by the jurisdiction where manufacturing takes place, until that date. Should the approval of the quality management system lapse before the expiry date indicated above, this registration shall become void.

An invoice covering survey and registration fees will be forwarded from our Revenue Accounts.

If you have any question don't hesitate to contact me by phone at (780) 433-0281 ext 3369 or fax (780) 437-7787 or e-mail Radisavljevic@absa.ca.

Sincerely,



RADISAVLJEVIC, ZANA, P. Tech. (Eng.)
DOP Cert. No. D00003136

STATUTORY DECLARATION
Registration of Fittings
Single or Multiple Fitting Designs within one Fitting Category

I, Jamison Dithardt, Product and Solutions Development
(name of applicant) (position title) (must be in a position of authority)
of GUNTNER DE MEXICO, S.A. DE CV
(name of manufacturer)
located at Av. Rogelio Gonzalez Caballero No. 1000, Parque Industrial Stiva
Aeropuerto, 66600 Apodaca, N.L., Mexico
(plant address)

In this space, show facsimile of manufacturer's logo or trademark as it will appear on the fitting.



do solemnly declare that the fittings listed hereunder, which are subject to the Safety Codes Act (select only one)

- ☒ comply with the requirements of ASME Section VIII-1 which specifies the dimensions, (title of recognized North American Standard)
materials of construction, pressure/temperature ratings and identification marking of the fittings, or
- ☐ are not covered by the provisions of a recognized North American standard and are therefore
manufactured to comply with _____ as supported by the (title of code of construction or other applicable document)
attached data which identifies the dimensions, materials of construction, pressure/temperature ratings and the basis for such ratings, and the identification marking of the fittings.

I further declare that the manufacture of these fittings is controlled by a quality control program which has been verified as described in the below Table as being suitable for the manufacturing of these fittings to the stated standard, regulation, code, guideline or other applicable document. The fittings covered by the declaration for which I seek registration are as provided in the Supplementary Sheet(s) attached.

Quality Program Verification and Manufacturing Sites

A copy of the Quality Certificate from each manufacturing site must be included

Item #	Product Description, Model or Series	Quality Program	Scope of Certification	Expiry Date	Verifying Organization	Location(s) Plant Name and address
1.	Heat Exchanger	ISO 9001:2015	See Scope of CRN Registration	January 19, 2023	TUV	Mexico
2.						

In support of this application, the following information, calculations and/or test data are attached:

Scope of CRN, Drawings, Calculations, Reports

Jason Franklin
(Signature of the Declarer)


1/24/23
(Date)

DECLARED before me at Oak Park in the State of Illinois
(city) (province, territory, or state)

this 24 day of January, 2023
(Month) (Year)

(print) Jason Franklin
(a Commissioner of Oaths or Notary Public)

(sign) Jason Franklin
(a Commissioner of Oaths or Notary Public)



07/16/2023
(expiry date (mm/dd/yy))

Commissioner of Oaths / Notary Public in and for: Illinois
(province, territory, or state)

For ABSA Office Use Only:

NOTES: _____

To the best of my knowledge and belief, the application meets the requirements of the Safety Codes Act and CSA Standard B51, Part 1, Clause 4.2, and is accepted for registration in Category H.

CRN: 0H13343.2

Registered Date: 2023-03-14

Expiry Date: 2033-03-14

Signature: _____
(Signature of the Administrator/SCO)

The information you provide is necessary only for the administration of the programs as required by the Alberta Safety Codes Act and Regulations in the Pressure Equipment Discipline

2023-01324

ABSA

SAFETY CODES ACT - PROVINCE OF ALBERTA

ACCEPTED: 0H13343.2

See acceptance letter for conditions of registration.

Date: **2023-03-14** By: Zana Radisavljevic
ZANA RADISAVLJEVIC, P. Tech. (Eng.)
DOP: D00003136

This stamp and signature have been affixed electronically to this registered design as required by Section 20(1) of the Pressure Equipment Safety Regulation, in accordance with the Electronic Transactions Act.




SCOPE OF CRN REGISTRATION

Product Description	Drawing No.	Design Code	MAWP at MAWT	Material Specification	MDMT
Heat Exchanger	300-0000364961 Rev. 1	ASME Section VIII-1	120 barg at 140°C / 1740 psig at 284°F	Stainless Steel SA312-304/316 SA249-304/316 SA240-304/316	-100°C / - 148°F

Note 1: MAWP = Maximum Allowable Working Pressure, MAWT = Maximum Allowable Working Temperature, MDMT = Minimum Design Metal Temperature

Note 2: For low temperature operation the products shall conform to the rules of the applicable codes under which they are used.



This stamp and signature have been affixed electronically to this registered design as required by Section 20(1) of the Pressure Equipment Safety Regulation, in accordance with the Electronic Transactions Act.