

**REGISTRATION OF A PRESSURE FITTING DESIGN**

10-Oct-23

TSSA  
345 Carlingview Drive  
Toronto, Ontario  
M9W 6N9**Attention: Tanya Francis****File Number: 13832 [ 0 F]****Re: Manufacturer: Guntner de Mexico, S.A. de C.V.**  
**Item: Heat Exchanger**  
**Catalog or Drawing: 300-0000364961 Rev. 01**

TSASK Codes and Standards Compliance has registered the design listed above in accordance with The Boiler and Pressure Vessel Act and Regulations and CSA B51. The Canadian Registration Number (CRN) is:

**0H13343.23      Expiry Date: March 14, 2033**

Please note that every fitting shall be constructed in strict accordance with the registered design.

Fitting registrations are required to be resubmitted for validation after ten (10) years from the registration date in accordance with CSA B51, Clause 4.2.1.

Should you require anything further, please do not hesitate to contact the Codes and Standards Compliance Office at your convenience.

Yours truly,

Athan Syrgiannis, P.Eng.  
Codes and Standards Compliance**Remarks:**

A valid quality control program must be maintained at the production facility for the fitting registration to remain valid until the expiry date.

**Statutory Declaration (Registration of Fittings)**

**TSK-1008**

**I. Declaration Information**

I, JAMISON DITTHARDT  
PRODUCT AND SOLUTIONS DEVELOPMENT MANAGER  
(company title, e.g. vice president, plant manager, chief engineer)  
(must be in a position of authority in the manufacturing plant where the fitting is produced)

of: GUNTNER DE MEXICO, S.A. DE C.V.

located at: Av. Rogelio Gonzalez Caballero No. 1000, Parque Industrial Stiva  
Aeropuerto, 66600 Apodaca, N.L., Mexico  
(Plant Address – Apt/Street) (City,Prov) (Postal Code)

In this space, show facsimile of manufacturer's logo or trademark as it will appear on the fitting.



do solemnly declare that the fittings listed hereinunder, which are subject to the **Saskatchewan Boiler and Pressure Vessel Safety Act** (check one)

- ☒ Comply with the requirements of ASME SECTION VIII-1 which specifies the dimensions,  
(title of recognized North American Standard)  
Materials of construction, pressure / temperature ratings and identification marking of the fittings, or
- ☐ Are not covered by the provisions of a recognized North American standard and are therefore manufactured to comply with \_\_\_\_\_ as supported by the attached data which identifies the dimensions, materials of construction, pressure / temperature ratings and the basis for such ratings, and the marking of the fittings for identification.

I further declare that the manufacturer of these fittings is controlled by a quality control program which has been verified by the following authority, TUV-SUD ISO 9001:2015 as being suitable for the manufacturer of these fittings to the stated standard. The fittings covered by this declaration, for which I seek registration, are CATEGORY H - HEAT EXCHANGER

In support of this application, the following information, calculations and / or test data are attached:

SCOPE OF CRN, DRAWINGS, CALCULATIONS, REPORTS

**II. Declaration**

DECLARED before me at Oak Park In the State of Illinois  
this 24 day of January, 2023

(print name)

Jason Franklin  
(Signature of Commissioner of Oaths)



Jamison Ditthardt  
(Signature)

**III. Office Use Only**

To the best of my knowledge and belief, the application meets the requirements of the **Boiler and Pressure Vessel Safety Act** and CSA B51, Clause 4.2, and is accepted for registration in Category \_\_\_\_\_



**Technical  
Safety Authority  
of Saskatchewan**

Registration No. 0H13343.23

File No. 13832

Registered

Date: October 10, 2023

Expiry Date: March 14, 2023

Codes & Standards Compliance Office

(Date Registered – MM DD YYYY)  
(For the Administrator / Chief Inspector)

(Expiry Date – MM DD YYYY)

TSK-1008  
Rev. 10/2019

**GUNTNER DE MEXICO S.A. DE C.V.**  
ROGELIO GONZALEZ CABALLERO NO. 1000  
PARQUE INDUSTRIAL STIVA AEROPUERTO  
APODACA, NUEVO LEON  
MEXICO CP 66600



02-Mar-23

Page 1 of 1

### **SCOPE OF CRN REGISTRATION**

<b>Product Description</b>	<b>Drawing No.</b>	<b>Design Code</b>	<b>MAWP at MAWT</b>	<b>Material Specification</b>	<b>MDMT</b>
Heat Exchanger	300-0000364961 Rev. 1	ASME Section VIII-1	120 barg at 140°C / 1740 psig at 284°F	Stainless Steel SA312-304/316 SA249-304/316 SA240-304/316	-100°C / - 148°F

**Note 1:** MAWP = Maximum Allowable Working Pressure, MAWT = Maximum Allowable Working Temperature, MDMT = Minimum Design Metal Temperature

**Note 2:** For low temperature operation the products shall conform to the rules of the applicable codes under which they are used.

	<b>Technical Safety Authority of Saskatchewan</b>
Registration No.	0H13343.23
File No.	13832
	<input checked="" type="checkbox"/> Registered
Date:	October 10, 2023
Expiry Date:	March 14, 2033
Codes & Standards Compliance Office	