

ROUND ENGINEERING INC
10 SEGWUN ROAD
WATERDOWN ON L8B 0K6

Date: March 31, 2023
Account #: 59067
Journal #: 82468
Our File #: 5654280

Attn: SCOTT ISLIP

Re: Application for Design Registration

The design, as detailed in your, Melco Trucelium R-1872, for a Pressure Vessel is accepted for registration as follows:

Registered To: MELCO STEEL INC

CRN: Z5054.21

MDMT: -20 deg F

MAWT: 300 deg F

MAWP: 30 psig

Drawing #: 4507-01-V, 4507-01-D

Drawing Revision: Rev. 2, Rev. 0

Conditions of Registration:

1- This registration is unit specific and applies only to the "Used Vessel" identified below, based on the condition that there is no evidence of internal/external erosion or damage such as corrosion, thinning, dents, cracking, overheating or as any other kind to the vessel;

Manufacturer: Melco Steel, Inc
Manufacturer's Serial No.: 4507
NB number: 1633
Year Built: 2021
Code: ASME Sec. VIII, Div. 1, 2019

2- Before installation/operation; the installation site local area Technical Safety BC Boiler Safety Officer shall be notified, by owner/user or their agents, of all observations, comments, and recommendations of inspection report and memorandum letter, for this registration.

3- This design was registered based on a design registration performed by the province of initial registration. Any additional conditions of registration stated in ABSA CRN# Z5054.2 registration shall apply to BC registration.

Contact me if you have any questions. The invoice for the registration will be forwarded under separate cover.

Chelsea Pothier

chelsea.pothier@technicalsaftybc.ca
Design Engineer-in-Training

CC: