

Figure D.6

Declaration of Conformity form for application for registration of fittings in Canada

(See Clauses 5.4.2 and D.1.)

PROVINCE OF PRINCE EDWARD ISLAND

C.R.N.: OC 1469.9
 DATE: AAC 22/28



SIGNED: [Signature]
 INSPECTION SERVICES SECTION
 BOILER/PRESSURE VESSEL BRANCH
 CRN: 0C1469.9

DECLARATION OF CONFORMITY
 REGISTRATION OF FITTINGS
 DÉCLARATION DE CONFORMITÉ
 ENREGISTREMENT D'ACCESSOIRES

Declaration No: Unique Identifier assigned by manufacturer	R-2327A	Revision:	0
--	---------	-----------	---

Manufacturer	(Name and Address) Parker Hannifin Corporation - Sporlan Division 206 Lange Drive, Washington, Missouri 63090 USA
--------------	---

Table 1 Scope of Fitting Designs:

Item No.	Type / Model / Size	Product Description	Material of Construction	MDMT	Rated Pressure*			References: Catalog (pages) or Drawing(s) (revision level included)
					At Ambient Temperature	At Maximum Temperature		
1.	CDS(T)-2	Electric	ASTM B283	-50F	CDS(T)-2: 548 psig	424 psig	at 240F	June 2025 /
2.	CDS(T)-4	Pressure	UNS C37700		CDS(T)-4: 548 psig	424 psig	at 240F	Bulletin 100-40
3.	CDS(T)-7	Regulator	B16-C35000		CDS(T)-7: 541 psig	418 psig	at 240F	CRN Design Report
4.	CDS(T)-9		B76-C12000		CDS(T)-9: 613 psig	474 psig	at 240F	R-2327A Rev. 0
5.	CDS(T)-17		H80		CDS(T)-17: 412 psig	319 psig	at 240F	

Table 2 Codes, Standards, Guidelines, and Other Applicable Documents

Item No.	Title of Code(s), Standard(s), Guideline(s), or Other Applicable Document(s)	Edition / Revision	Item No.	Title of Code(s), Standard(s), Guideline(s), or Other Applicable Document(s)	Edition / Revision
1	UL 207, Refrigerant-Containing Components and Accessories	9th Ed., 2022/08/06	4	CSA C22.2 NO. 140.3-15, Refrigerant-containing components for use in electrical equipment	3rd Ed., 2015/03/01
2	ASME B31.5	2022	5		
3			6		

Table 3 Quality Program Verification and Manufacturing Sites

Item No.	Location(s) Plant Name and Address / Site(s)	Quality Program Certificate Number	Expiry Date	Verifying Organization
1	Parker Hannifin Corporation Plant 3 216 Lange Drive, Washington, MO 63090, USA	FM 793677	2027-11-24	bsi (The British Standards Institution)

A copy of the Quality Certificate from each manufacturing site must be included.

As an official of the manufacturer with authority, and having responsibility for the conformity and regulatory compliance of the fittings, I hereby declare that the information and statements made in this declaration of conformity are true and accurate.

I declare, under our sole responsibility, that the design, construction, certification, and marking of the fitting(s) listed in Table 1*, are subject to a conformity assessment process and quality program that has been verified, as described in Table 3**.

I certify that the fitting(s) listed in Table 1* conform to: the provisions of the acts and regulations of the provinces and territories where the fitting(s) are registered; CSA B51; and the codes, standards, guidelines, or other applicable documents listed in Table 2**.

I further declare that there is a process in place for the retention of this declaration of conformity for not less than 10 years from the issuance of the Canadian Registration Number (CRN).

Signed for and on behalf of Sporlan Division of Parker Hannifin Corp. Washington Missouri, USA
 (Manufacturer) (City) (State / Province / Country)
John Withouse Sr. Principal Engineer [Signature] 2026-3-27
 (Name, please print) (Function or Title) (Signature of Declarer) (Date)

Figure D.6 Declaration of Conformity form for application for registration of fittings in Canada

(See CSA B51:24 and D.1)



NOVA SCOTIA
Date April 23/26

C.R.N. OC1469.98

Dwg. as described

Signed [Signature]

CRN: OC146909 / 1
Part

**DECLARATION OF CONFORMITY
REGISTRATION OF FITTINGS
DÉCLARATION DE CONFORMITÉ
ENREGISTREMENT D'ACCESSOIRES**

Declaration No: Unique Identifier assigned by manufacturer	R-2327A	Revision:	0
--	---------	-----------	---

Manufacturer	(Name and Address) Parker Hannifin Corporation - Sporlan Division 206 Lange Drive, Washington, Missouri 63090 USA
--------------	---

***Table 1 Scope of Fitting Designs**

Item No.	Type / Model / Size	Product Description	Material of Construction	MDMT	Rated Pressure			References: Catalog (pages) or Drawing(s) (revision level included)
					At Ambient Temperature	At Maximum Temperature		
1	CDS(T)-2	Electric	ASTM B283	-50F	CDS(T)-2: 548 psig	424 psig	at 240F	June 2025 /
2	CDS(T)-4	Pressure	UNS C37700		CDS(T)-4: 548 psig	424 psig	at 240F	Bulletin 100-40
3	CDS(T)-7	Regulator	B16-C35000		CDS(T)-7: 541 psig	418 psig	at 240F	CRN Design Report
4	CDS(T)-9		B75-C12000		CDS(T)-9: 613 psig	474 psig	at 240F	R-2327A Rev. 0
5	CDS(T)-17		H80		CDS(T)-17: 412 psig	319 psig	at 240F	

****Table 2 Codes, Standards, Guidelines, and Other Applicable Documents**

Item No.	Title of Code(s), Standard(s), Guideline(s), or Other Applicable Document(s)	Edition / Revision	Item No.	Title of Code(s), Standard(s), Guideline(s), or Other Applicable Document(s)	Edition / Revision
1	UL 207, Refrigerant-Containing	9th Ed.	4	CSA C22.2 NO. 140.3-15 Refrigerant	3rd Ed.
2	Components and Accessories	2022/08/06	5	-containing components for use in	2015/03/01
3	CSA B52	2023	6	electrical equipment	
	ASME B31.5	2022			

*****Table 3 Quality Program Verification and Manufacturing Sites**

Item No.	Location(s) Plant Name and Address / Site(s)	Quality Program Certificate Number	Expiry Date	Verifying Organization
1	Parker Hannifin Corporation Plant 3 215 Lange Drive, Washington, MO 63090, USA	FM 793677	2027-11-24	bsi (The British Standards Institution)

A copy of the Quality Certificate from each manufacturing site must be included.

As an official of the manufacturer with authority, and having responsibility for the conformity and regulatory compliance of the fittings, I hereby declare that the information and statements made in this declaration of conformity are true and accurate.

I declare, under our sole responsibility, that the design, construction, certification, and marking of the fitting(s) listed in Table 1*, are subject to a conformity assessment process and quality program that has been verified, as described in Table 3***.

I certify that the fittings (s) listed in Table 1* conform to: the provisions of the acts and regulations of the provinces and territories where the fitting(s) are registered; CSA B51; and the codes, standards, guidelines, or other applicable documents listed in Table 2**.

I further declare that there is a process in place for the retention of this declaration of conformity for not less than 10 years from the issuance of the Canadian Registration Number (CRN).

Signed for and on behalf of Sporlan Division of Parker Hannifin Corp., Washington, Missouri, USA
(Manufacturer) (City) (State / Province / Country)

John Withouse, Sr. Principal Engineer
(Name, please print) (Function or Title)

[Signature]
(Signature of Declarer)

2026-3-27
(Date)

Figure D.6 **New Brunswick**

Declaration of Conformity form for application for registration of fittings in Canada
(See Clauses 5.4.2 and D.1.)



CRN: 0C1469.9

REGISTRATION ONLY
CRN 0C1469.97

John Withouse
CHIEF BOILER INSPECTOR
DATE 4/23/26
**DECLARATION OF CONFORMITY
REGISTRATION OF FITTINGS
DECLARATION DE CONFORMITÉ
ENREGISTREMENT D'ACCESSOIRES**

Declaration No: Unique Identifier assigned by manufacturer	R-2327A	<input type="checkbox"/> BLRs	<input type="checkbox"/> Revision: 0
		<input checked="" type="checkbox"/> FITTINGS	<input type="checkbox"/> NUCLEAR COMPONENTS

Manufacturer	(Name and Address) Parker Hannifin Corporation - Sporlan Division 206 Lange Drive, Washington, Missouri 63090 USA
---------------------	---

***Table 1 Scope of Fitting Designs**

Item No.	Type / Model / Size	Product Description	Material of Construction	MDMT	Rated Pressure			References: Catalog (pages) or Drawing(s) (revision level included)
					At Ambient Temperature	At Maximum Temperature		
1.	CDS(T)-2	Electric	ASTM B283	-50F	CDS(T)-2: 548 psig	424 psig	at 240F	June 2025 /
2.	CDS(T)-4	Pressure	UNS C37700		CDS(T)-4: 548 psig	424 psig	at 240F	Bulletin 100-40
3.	CDS(T)-7	Regulator	B16-C35000		CDS(T)-7: 541 psig	418 psig	at 240F	CRN Design Report
4.	CDS(T)-9		B75-C12000		CDS(T)-9: 613 psig	474 psig	at 240F	R-2327A Rev. 0
5.	CDS(T)-17		H80		CDS(T)-17: 412 psig	319 psig	at 240F	

****Table 2 Codes, Standards, Guidelines, and Other Applicable Documents**

Item No.	Title of Code(s), Standard(s), Guideline(s), or Other Applicable Document(s)	Edition / Revision	Item No.	Title of Code(s), Standard(s), Guideline(s), or Other Applicable Document(s)	Edition / Revision
1	UL 207, Refrigerant-Containing	9th Ed.,	4	CSA C22.2 NO. 140.3-15 Refrigerant	3rd Ed.,
2	Components and Accessories	2022/08/06	5	-containing components for use in	2015/03/01
3	CSA B52	2023	6	electrical equipment	
	ASME B31.5	2022			

*****Table 3 Quality Program Verification and Manufacturing Sites**

Item No.	Location(s) Plant Name and Address / Site(s)	Quality Program Certificate Number	Expiry Date	Verifying Organization
1	Parker Hannifin Corporation Plant 3 215 Lange Drive, Washington, MO 63090, USA	FM 793677	2027-11-24	bsi (The British Standards Institution)

A copy of the Quality Certificate from each manufacturing site must be included.

As an official of the manufacturer with authority, and having responsibility for the conformity and regulatory compliance of the fittings, I hereby declare that the information and statements made in this declaration of conformity are true and accurate.

I declare, under our sole responsibility, that the design, construction, certification, and marking of the fitting(s) listed in Table 1*, are subject to a conformity assessment process and quality program that has been verified, as described in Table 3***.

I certify that the fittings (s) listed in Table 1* conform to: the provisions of the acts and regulations of the provinces and territories where the fitting(s) are registered; CSA B51; and the codes, standards, guidelines, or other applicable documents listed in Table 2**.


I further declare that there is a process in place for the retention of this declaration of conformity for not less than 10 years from the issuance of the Canadian Registration Number (CRN).

Signed for and on behalf of Sporlan Division of Parker Hannifin Corp., Washington, Missouri, USA
(Manufacturer) (City) (State / Province / Country)

John Withouse, Sr. Principal Engineer, John Withouse, 2026-3-27
(Name, please print) (Function or Title) (Signature of Declarer) (Date)

Figure D.6

Declaration of Conformity form for application for registration of fittings in Canada
(See Clauses 5.4.2 and D.1.)



Registered OC146990
 Date April 27, 2026
 Engineering and Inspection Services
 Registered by [Signature]
 UNDER THE AUTHORITY OF THE
 PUBLIC SAFETY ACT AND
 THE BOILER, PRESSURE VESSEL AND
 COMPRESSED GAS REGULATIONS
 CRN: 146990

DECLARATION OF CONFORMITY
 REGISTRATION OF FITTINGS
 DÉCLARATION DE CONFORMITÉ
 ENREGISTREMENT D'ACCESSOIRES

Declaration No: Unique identifier assigned by manufacturer	R-2327A	Revision:	0
--	---------	-----------	---

Manufacturer	(Name and Address) Parker Hannifin Corporation - Sporlan Division 206 Lange Drive, Washington, Missouri 63090 USA
--------------	---

Table 1 Scope of Fitting Designs

Item No.	Type / Model / Size	Product Description	Material of Construction	MDMT	Rated Pressure			References: Catalog (pages) or Drawing(s) (revision level included)
					At Ambient Temperature	At Maximum Temperature		
1	CDS(T)-2	Electric	ASTM B283	-50F	CDS(T)-2: 548 psig	424 psig	at 240F	June 2025 /
2	CDS(T)-4	Pressure	UNS C37700		CDS(T)-4: 548 psig	424 psig	at 240F	Bulletin 100-40
3	CDS(T)-7	Regulator	816-C35000		CDS(T)-7: 541 psig	418 psig	at 240F	CRN Design Report
4	CDS(T)-9		B75-C12000		CDS(T)-9: 613 psig	474 psig	at 240F	R-2327A Rev. 0
5	CDS(T)-17		H80		CDS(T)-17: 412 psig	319 psig	at 240F	

Table 2 Codes, Standards, Guidelines, and Other Applicable Documents

Item No.	Title of Code(s), Standard(s), Guideline(s), or Other Applicable Document(s)	Edition / Revision	Item No.	Title of Code(s), Standard(s), Guideline(s), or Other Applicable Document(s)	Edition / Revision
1	UL 207, Refrigerant-Containing	9th Ed.	4	CSA C22.2 NO. 140.3-15 Refrigerant	3rd Ed.
2	Components and Accessories	2022/08/08	5	-containing components for use in	2015/03/01
3	ASME B31.5	2022	6	electrical equipment	

Table 3 Quality Program Verification and Manufacturing Sites

Item No.	Location(s) Plant Name and Address / Site(s)	Quality Program Certificate Number	Expiry Date	Verifying Organization
1	Parker Hannifin Corporation Plant 3 219 Lange Drive, Washington, MO 63090, USA	PM 783877	2027-11-24	bsi (The British Standards Institution)

A copy of the Quality Certificate from each manufacturing site must be included.

As an official of the manufacturer with authority, and having responsibility for the conformity and regulatory compliance of the fittings, I hereby declare that the information and statements made in this declaration of conformity are true and accurate.

I declare, under our sole responsibility, that the design, construction, certification, and marking of the fitting(s) listed in Table 1*, are subject to a conformity assessment process and quality program that has been verified, as described in Table 3**.


I certify that the fitting(s) listed in Table 1* conform to the provisions of the acts and regulations of the provinces and territories where the fitting(s) are registered; CSA B51: and the codes, standards, guidelines, or other applicable documents listed in Table 2**.

I further declare that there is a process in place for the retention of this declaration of conformity for not less than 10 years from the issuance of the Canadian Registration Number (CRN).

Signed for and on behalf of Sporlan Division of Parker Hannifin Corp., Washington, Missouri, USA
 (Manufacturer) (City) (State / Province / Country)

John Withouse, Sr. Principal Engineer, [Signature], 2026-3-27
 (Name, please print) (Function or Title) (Signature of Declarer) (Date)

Figure D.6 Declaration of Conformity form for application for registration of fittings in Canada (See Clauses 5.4.2 and D.1.)



GRN: 0C1469.9

**DECLARATION OF CONFORMITY
REGISTRATION OF FITTINGS
DECLARATION DE CONFORMITÉ
ENREGISTREMENT D'ACCESSOIRES**

Declaration No: <small>Unique identifier assigned by manufacturer</small>	R-2327A	Revision: 0
---	---------	-----------------------

Manufacturer	(Name and Address) Parker Hannifin Corporation - Sporlan Division 206 Lange Drive, Washington, Missouri 63090 USA
---------------------	--

***Table 1 Scope of Fitting Designs**

Item No.	Type / Model / Size	Product Description	Material of Construction	MDMT	Rated Pressure			References: Catalog (pages) or Drawing(s) (revision level included)
					At Ambient Temperature	At Maximum Temperature		
1	CDS(T)-2	Electric	ASTM B283	-50F	CDS(T)-2: 548 psig	424 psig	at 240F	June 2025 /
2	CDS(T)-4	Pressure	UNS C37700		CDS(T)-4: 548 psig	424 psig	at 240F	Bulletin 100-40
3	CDS(T)-7	Regulator	B16-C35000		CDS(T)-7: 541 psig	418 psig	at 240F	CRN Design Report
4	CDS(T)-9		B75-C12000		CDS(T)-9: 613 psig	474 psig	at 240F	R-2327A Rev. 0
5	CDS(T)-17		H80		CDS(T)-17: 412 psig	319 psig	at 240F	

****Table 2 Codes, Standards, Guidelines, and Other Applicable Documents**

Item No.	Title of Code(s), Standard(s), Guideline(s), or Other Applicable Document(s)	Edition / Revision	Item No.	Title of Code(s), Standard(s), Guideline(s), or Other Applicable Document(s)	Edition / Revision
1	UL 207, Refrigerant-Containing Components and Accessories	9th Ed.	4	CSA C22.2 NO. 140.3-15 Refrigerant-containing components for use in electrical equipment	3rd Ed.,
2	CSA B52	2022/08/06	5		2015/03/01
3	ASME B31.5	2023	6		

*****Table 3 Quality Program Verification and Manufacturing Sites**

Item No.	Location(s) Plant Name and Address / Site(s)	Quality Program Certificate Number	Expiry Date	Verifying Organization
1	Parker Hannifin Corporation Plant 3 215 Lange Drive, Washington, MO 63090, USA	FM 793677	2027-11-24	bsi (The British Standards Institution)

A copy of the Quality Certificate from each manufacturing site must be included.

As an official of the manufacturer with authority, and having responsibility for the conformity and regulatory compliance of the fittings, I hereby declare that the information and statements made in this declaration of conformity are true and accurate.


I declare, under our sole responsibility, that the design, construction, certification, and marking of the fitting(s) listed in Table 1*, are subject to a conformity assessment process and quality program that has been verified, as described in Table 3***.

I certify that the fitting(s) listed in Table 1* conform to: the provisions of the acts and regulations of the provinces and territories where the fitting(s) are registered; CSA B51; and the codes, standards, guidelines, or other applicable documents listed in Table 2**.

I further declare that there is a process in place for the retention of this declaration of conformity for not less than 10 years from the issuance of the Canadian Registration Number (CRN).

Signed for and on behalf of Sporlan Division of Parker Hannifin Corp., Washington, Missouri, USA
(Manufacturer) (City) (State / Province / Country)
John Withouse Sr. Principal Engineer *John Withouse* 2026-3-27
(Name, please print) (Function or Title) (Signature of Declarer) (Date)

Figure D.6 Declaration of Conformity form for application for registration of fittings in Canada



**DECLARATION OF CONFORMITY
REGISTRATION OF FITTINGS
DÉCLARATION DE CONFORMITÉ
ENREGISTREMENT D'ACCESSOIRES**

Declaration No: Unique identifier assigned by manufacturer	R-2327A	Revision:	0
--	---------	------------------	---

Manufacturer	(Name and Address) Parker Hannifin Corporation - Sporlan Division 206 Lange Drive, Washington, Missouri 63090 USA
---------------------	---

***Table 1 Scope of Fitting Designs**

Item No.	Type / Model / Size	Product Description	Material of Construction	MDMT	Rated Pressure			References: Catalog (pages) or Drawing(s) (revision level included)
					At Ambient Temperature	At Maximum Temperature		
1	CDS(T)-2	Electric	ASTM B283	-50F	CDS(T)-2: 548 psig	424 psig at 240F	June 2025 /	
2	CDS(T)-4	Pressure	UNS C37700		CDS(T)-4: 548 psig	424 psig at 240F	Bulletin 100-40	
3	CDS(T)-7	Regulator	B16-C35000		CDS(T)-7: 541 psig	418 psig at 240F	CRN Design Report	
4	CDS(T)-9		B75-C12000		CDS(T)-9: 613 psig	474 psig at 240F	R-2327A Rev. 0	
5	CDS(T)-17		H80		CDS(T)-17: 412 psig	319 psig at 240F		

****Table 2 Codes, Standards, Guidelines, and Other Applicable Documents**

Item No.	Title of Code(s), Standard(s), Guideline(s), or Other Applicable Document(s)	Edition / Revision	Item No.	Title of Code(s), Standard(s), Guideline(s), or Other Applicable Document(s)	Edition / Revision
1	UL 207, Refrigerant-Containing Components and Accessories	9th Ed., 2022/08/06	4	CSA C22.2 NO. 140.3-15 Refrigerant-containing components for use in electrical equipment	3rd Ed., 2015/03/01
3	ASME B31.5	2022	6		

*****Table 3 Quality Program Verification and Manufacturing Sites**

Item No.	Location(s) Plant Name and Address / Site(s)	Quality Program Certificate Number	Expiry Date	Verifying Organization
1	Parker Hannifin Corporation Plant 3 215 Lange Drive, Washington, MO 63090, USA	FM 793677	2027-11-24	bsi (The British Standards Institution)

A copy of the Quality Certificate from each manufacturing site must be included.

As an official of the manufacturer with authority, and having responsibility for the conformity and regulatory compliance of the fittings, I hereby declare that the information and statements made in this declaration of conformity are true and accurate.

I declare, under our sole responsibility, that the design, construction, certification, and marking of the fitting(s) listed in Table 1*, are subject to a conformity assessment process and quality program that has been verified, as described in Table 3**.

I certify that the fittings (s) listed in Table 1* conform to: the provisions of the acts and regulations of the provinces and territories where the fitting(s) are registered; CSA B51; and the codes, standards, guidelines, or other applicable documents listed in Table 2**.

I further declare that there is a process in place for the retention of this declaration of conformity for not less than 10 years from the issuance of the Canadian Registration Number (CRN).

Signed for and on behalf of Sporlan Division of Parker Hannifin Corp. Washington Missouri, USA
 (Manufacturer) (City) (State / Province / Country)

John Withouse Sr. Principal Engineer John Withouse 2026-3-27
 (Name, please print) (Function or Title) (Signature of Declarer) (Date)

Figure D.6

Declaration of Conformity form for application for registration of fittings in Canada
(See Clauses 5.4.2 and D.1.)



CRN: 0C1469.9

DECLARATION OF CONFORMITY
REGISTRATION OF FITTINGS
DÉCLARATION DE CONFORMITÉ
ENREGISTREMENT D'ACCESSOIRES

Declaration No: Unique identifier assigned by manufacturer	R-2327A	Revision:	0
--	---------	-----------	---

Manufacturer	(Name and Address) Parker Hannifin Corporation - Sporlan Division 206 Lange Drive, Washington, Missouri 63090 USA
--------------	---

*Table 1 Scope of Fitting Designs

Item No.	Type / Modal / Size	Product Description	Material of Construction	MDMT	Rated Pressure			References: Catalog (pages) or Drawing(s) (revision level included)
					At Ambient Temperature	At Maximum Temperature		
1	CDS(T)-2	Electric	ASTM B283	-50F	CDS(T)-2: 548 psig	424 psig	at 240F	June 2025 /
2	CDS(T)-4	Pressure	UNS C37700		CDS(T)-4: 548 psig	424 psig	at 240F	Bulletin 100-40
3	CDS(T)-7	Regulator	B16-C35000		CDS(T)-7: 541 psig	418 psig	at 240F	CRN Design Report
4	CDS(T)-8		B75-C12000		CDS(T)-8: 613 psig	474 psig	at 240F	R-2327A Rev. 0
5	CDS(T)-17		H80		CDS(T)-17: 412 psig	319 psig	at 240F	

**Table 2 Codes, Standards, Guidelines, and Other Applicable Documents

Item No.	Title of Code(s), Standard(s), Guideline(s), or Other Applicable Document(s)	Edition / Revision	Item No.	Title of Code(s), Standard(s), Guideline(s), or Other Applicable Document(s)	Edition / Revision
1	UL 207, Refrigerant-Containing	9th Ed.,	4	CSA C22.2 NO. 140.3-15 Refrigerant	3rd Ed.,
2	Components and Accessories	2022/08/06	5	-containing components for use in	2015/03/01
3	CSA B52	2023	6	electrical equipment	
	ASME B31.5	2022			

***Table 3 Quality Program Verification and Manufacturing Sites

Item No.	Location(s) Plant Name and Address / Site(s)	Quality Program Certificate Number	Expiry Date	Verifying Organization
1	Parker Hannifin Corporation Plant 3 215 Lange Drive, Washington, MO 63090, USA	PM 793677	2027-11-24	bsi (The British Standards Institution)

A copy of the Quality Certificate from each manufacturing site must be included.

As an official of the manufacturer with authority, and having responsibility for the conformity and regulatory compliance of the fittings, I hereby declare that the information and statements made in this declaration of conformity are true and accurate.

I declare, under our sole responsibility, that the design, construction, certification, and marking of the fitting(s) listed in Table 1*, are subject to a conformity assessment process and quality program that has been verified, as described in Table 3***.

I certify that the fitting(s) listed in Table 1* conform to the provisions of the acts and regulations of the provinces and territories where the fitting(s) are registered; CSA B51; and the codes, standards, guidelines, or other applicable documents listed in Table 2**.

I further declare that there is a process in place for the retention of this declaration of conformity for a period of _____ years from the issuance of the Canadian Registration Number (CRN).

Signed for and on behalf of Sporlan Division of Parker Hannifin Corp. Washington
(Manufacturer)
John Withouse Sr. Principal Engineer
(Name, please print) (Function or Title)

NUNAVUT
Boilers and
Pressure Vessels Act
Missouri, USA

REGISTERED
2026-3-27

CRN 0C1469.9N (Date)

Date 04/23/2026

Signed [Signature]
Chief Inspector

Territorial Registration Fee