

Figure D.6

Declaration of Conformity form for application for registration of fittings in Canada
(See Clauses 5.4.2 and D.1.)

CRN: 0F1472.9
ACCEPTED



PROVINCE OF PRINCE EDWARD ISLAND
C.R.N.: 0F1472.9
DATE: MAY 1/26

**DECLARATION OF CONFORMITY
REGISTRATION OF FITTINGS
DÉCLARATION DE CONFORMITÉ
ENREGISTREMENT D'ACCESSOIRES**

SIGNED: [Signature]
INSPECTION SERVICES SECTION

Declaration No: Unique identifier assigned by manufacturer	R-2327B	BOILER/PRESSURE VESSEL BRANCH	Revision:	0
--	---------	-------------------------------	-----------	---

Manufacturer	(Name and Address) Parker Hannifin Corporation - Sporlan Division 206 Lange Drive, Washington, Missouri 63090 USA
--------------	---

***Table 1 Scope of Fitting Designs**

Item No.	Type / Model / Size	Product Description	Material of Construction	MDMT	Rated Pressure			References: Catalog (pages) or Drawing(s) (revision level included)
					At Ambient Temperature	At Maximum Temperature		
1	PSPT Series	Pressure Transducer	Stainless Steel	-40F	652 psig	652 psig	at 267F	SD-362 / 82022
			ASTM A182 F304L		The above pressure is the maximum pressure. Transducers with a lower pressure range are available.			CRN Design Report R-2327B Rev. 0

****Table 2 Codes, Standards, Guidelines, and Other Applicable Documents**

Item No.	Title of Code(s), Standard(s), Guideline(s), or Other Applicable Document(s)	Edition / Revision	Item No.	Title of Code(s), Standard(s), Guideline(s), or Other Applicable Document(s)	Edition / Revision
1	UL 60730-2-6 Automated Electrical Controls - Part 2-6	Revision	4		
2		December 2, 2024	5		
3			6		

The following tests were performed: Pressure test at 5 (five) times 5Mpa (725.2 psig) = 25 Mpa = 3626 psig which meets UL 60730-2-6 Clause 18.102

*****Table 3 Quality Program Verification and Manufacturing Sites**

Item No.	Location(s) Plant Name and Address / Site(s)	Quality Program Certificate Number	Expiry Date	Verifying Organization
1	Sensata Technologies (Changzhou) Co., Ltd. No. 18, Chuangxin Road, Xinbei District Changzhou City, Jiangsu, China, 213031	36568-2008-AQ-RGC-RVA	May 11, 2027	DNV - Business Assurance

A copy of the Quality Certificate from each manufacturing site must be included. In accordance with CSA B51 paragraph 5.4.2.3 Parker Hannifin Corporation Sporlan Division is taking responsibility for the product manufactured at Sensata Technologies Inc.

As an official of the manufacturer with authority, and having responsibility for the conformity and regulatory compliance of the fittings, I hereby declare that the information and statements made in this declaration of conformity are true and accurate.

I declare, under our sole responsibility, that the design, construction, certification, and marking of the fitting(s) listed in Table 1*, are subject to a conformity assessment process and quality program that has been verified, as described in Table 3***.

I certify that the fitting(s) listed in Table 1* conform to: the provisions of the code and regulations of the provinces and territories where the fitting(s) are registered; CSA B51; and the codes, standards, guidelines, or other applicable documents listed in Table 2**.


I further declare that there is a process in place for the retention of this declaration of conformity for not less than 10 years from the issuance of the Canadian Registration Number (CRN).

Signed for and on behalf of Sporlan Division of Parker Hannifin Corp., Washington, Missouri, USA
(Manufacturer) (City) (State / Province / Country)

John Withouse, Sr, Principal Engineer, [Signature], 2026-4-15
(Name, please print) (Function or Title) (Signature of Declarer) (Date)

Figure D.6 Declaration of Conformity form for application for registration of fittings in Canada (See Clauses 5.4.2 and D.1.)

CRN: 0F1472.9



C.R.N. 0F1472.98
Dwg. as described

**DECLARATION OF CONFORMITY
REGISTRATION OF FITTINGS
DÉCLARATION DE CONFORMITÉ
ENREGISTREMENT D'ACCESSOIRES**

Declaration No: <small>Unique identifier assigned by manufacturer</small>	R-2327B	Signed <u>[Signature]</u> 1 of 1 Part	Revision:	0
---	---------	---	------------------	---

Manufacturer	(Name and Address) Parker Hannifin Corporation - Sporlan Division 206 Lange Drive, Washington, Missouri 63090 USA
---------------------	--

***Table 1 Scope of Fitting Designs**

Item No	Type / Model / Size	Product Description	Material of Construction	MDMT	Rated Pressure		References: Catalog (pages) or Drawing(s) (revision level included)
					At Ambient Temperature	At Maximum Temperature	
1	PSPT Series	Pressure Transducer	Stainless Steel	-40F	652 psig	652 psig at 257F	SD-382 / B2022
			ASTM A182 F304L		The above pressure is the maximum at pressure. Transducers with a lower pressure range are available.		CRN Design Report R-2327B Rev. 0

****Table 2 Codes, Standards, Guidelines, and Other Applicable Documents**

Item No.	Title of Code(s), Standard(s), Guideline(s), or Other Applicable Document(s)	Edition / Revision	Item No.	Title of Code(s), Standard(s), Guideline(s), or Other Applicable Document(s)	Edition / Revision
1	UL 60730-2-6 Automated Electrical Controls - Part 2-6	Revision	4		
2		December 2, 2024	5		
3			6		

The following tests were performed: Pressure test at 5 (five) times 5Mpa (725.2 psig) = 25 Mpa = 3626 psig which meets UL 60730-2-6 Clause 18.102

*****Table 3 Quality Program Verification and Manufacturing Sites**

Item No.	Location(s) Plant Name and Address / Site(s)	Quality Program Certificate Number	Expiry Date	Verifying Organization
1	Sensata Technologies (Changzhou) Co., Ltd. No. 18, Chuangxin Road, Xinbei District Changzhou City, Jiangsu, China, 213031	38566-2008-AQ-RGC-RVA	May 11, 2027	DNV - Business Assurance

A copy of the Quality Certificate from each manufacturing site must be included. In accordance with CSA B51 paragraph 5.4.2.3 Parker Hannifin Corporation Sporlan Division is taking responsibility for the product manufactured at Sensata Technologies Inc.

As an official of the manufacturer with authority, and having responsibility for the conformity and regulatory compliance of the fittings, I hereby declare that the information and statements made in this declaration of conformity are true and accurate.

I declare, under our sole responsibility, that the design, construction, certification, and marking of the fitting(s) listed in Table 1*, are subject to a conformity assessment process and quality program that has been verified, as described in Table 3**.

I certify that the fittings (s) listed in Table 1* conform to the provisions of the acts and regulations of the provinces and territories where the fitting(s) are registered; CSA B51; and the codes, standards, guidelines, or other applicable documents listed in Table 2**.

I further declare that there is a process in place for the retention of this declaration of conformity for not less than 10 years from the issuance of this Canadian Registration Number (CRN).

Signed for and on behalf of Sporlan Division of Parker Hannifin Corp., Washington, Missouri, USA
(Manufacturer) (City) (State / Province / Country)

John Withouse, Sr. Principal Engineer, [Signature], 2026-4-15
(Name, please print) (Function or Title) (Signature of Declarer) (Date)

Figure D.6

Declaration of Conformity form for application for registration of fittings in Canada
(See Clauses 5.4.2 and D.1.)



CRN: OF1472.9

New Brunswick / Nouveau Brunswick

DEPT OF JUSTICE PUBLIC SAFETY
BOILER & PRESSURE VESSEL ACT

REGISTRATION ONLY
OF1472.97

DECLARATION OF CONFORMITY
REGISTRATION OF FITTINGS
DECLARATION DE CONFORMITÉ
ENREGISTREMENT D'ACCESSOIRES

Declaration No: Unique identifier assigned by manufacturer: R-2327B CRN: OF1472.97 Revision: 0

Manufacturer (Name and Address): Parker Hannifin Corporation - Sporlan Division
206 Lange Drive, Washington, Missouri 63090 USA

DATE: 5/11/20

CHIEF BOILER INSPECTOR

*Table 1 Scope of Fitting Designs

Item No	Type / Model / Size	Product Description	Material of Construction		Rated Pressure		References: Catalog (pages) or Drawing(s) (revision level included)
			<input checked="" type="checkbox"/> FITTINGS	<input type="checkbox"/> NUCLEAR COMPONENTS	At Ambient Temperature	At Maximum Temperature	
1	PSPT Series	Pressure Transducer	Stainless Steel	-40F	652 psig	652 psig at 257F	SD-362 / 82022
			ASTM A182		The above pressure is the maximum pressure. Transducers with a lower pressure range are available.		CRN Design Report R-2327B Rev. 0
			F304L				

**Table 2 Codes, Standards, Guidelines, and Other Applicable Documents

Item No	Title of Code(s), Standard(s), Guideline(s), or Other Applicable Document(s)	Edition / Revision	Item No	Title of Code(s), Standard(s), Guideline(s), or Other Applicable Document(s)	Edition / Revision
1	UL 60730-2-6 Automated Electrical Controls - Part 2-6	Revision	4		
2		December 2, 2024	5		
3			6		

The following tests were performed: Pressure test at 5 (five) times 5Mpa (725.2 psig) = 25 Mpa = 3626 psig which meets UL 60730-2-6 Clause 18.102

***Table 3 Quality Program Verification and Manufacturing Sites

Item No.	Location(s) Plant Name and Address / Site(s)	Quality Program Certificate Number	Expiry Date	Verifying Organization
1	Sensata Technologies (Changzhou) Co., Ltd. No. 18, Chuangxin Road, Xinbei District Changzhou City, Jiangsu, China, 213031	36568-2008-AQ-RGC-RvA	May 11, 2027	DNV - Business Assurance

A copy of the Quality Certificate from each manufacturing site must be included. In accordance with CSA B51 paragraph 5.4.2.3 Parker Hannifin Corporation Sporlan Division is taking responsibility for the product manufactured at Sensata Technologies Inc.

As an official of the manufacturer with authority, and having responsibility for the conformity and regulatory compliance of the fittings, I hereby declare that the information and statements made in this declaration of conformity are true and accurate.

I declare, under our sole responsibility, that the design, construction, certification, and marking of the fitting(s) listed in Table 1*, are subject to a conformity assessment process and quality program that has been verified, as described in Table 3***.

I certify that the fittings (s) listed in Table 1* conform to the provisions of the acts and regulations of the provinces and territories where the fitting(s) are registered: CSA B51: and the codes, standards, guidelines, or other applicable documents listed in Table 2**.

I further declare that there is a process in place for the retention of this declaration of conformity for not less than 10 years from the issuance of the Canadian Registration Number (CRN).

Signed for and on behalf of Sporlan Division of Parker Hannifin Corp., Washington, Missouri, USA

John Withouse (Name, please print) Sr. Principal Engineer (Function or Title) John Withouse (Signature of Declarer) 2026-4-15 (Date)

Figure D.6 Declaration of Conformity form for application for registration of fittings in Canada (See Clauses 5.4.2 and D.1.)

CRN
CRN 1472.9
Labrador



Registered 0F1472.90
Date May 1, 2026
Engineering and Inspection Services
Registered by [Signature]

**DECLARATION OF CONFORMITY
REGISTRATION OF FITTINGS
DÉCLARATION DE CONFORMITÉ
ENREGISTREMENT D'ACCESSOIRES**

UNDER THE AUTHORITY OF THE
PUBLIC SAFETY ACT AND
THE BOILER, PRESSURE VESSEL AND
COMPRESSED GAS REGULATIONS

Declaration No: <small>Unique identifier assigned by manufacturer</small>	R-2327B	Revision:	0
---	----------------	------------------	----------

Manufacturer	<small>(Name and Address)</small> Parker Hannifin Corporation - Sporlan Division 206 Lange Drive, Washington, Missouri 63090 USA
---------------------	--

***Table 1 Scope of Fitting Designs**

Item No.	Type / Model / Size	Product Description	Material of Construction	MDMT	Rated Pressure		References: Catalog (pages) or Drawing(s) (revision level included)
					At Ambient Temperature	At Maximum Temperature	
1	PSPT Series	Pressure Transducer	Stainless Steel	-40F	652 psig	652 psig at 257F	SD-382 / 82022
			ASTM A182 F304L		The above pressure is the maximum pressure. Transducers with a lower pressure range are available.		CRN Design Report R-2327B Rev. 0

****Table 2 Codes, Standards, Guidelines, and Other Applicable Documents**

Item No.	Title of Code(s), Standard(s), Guideline(s), or Other Applicable Document(s)	Edition / Revision	Item No.	Title of Code(s), Standard(s), Guideline(s), or Other Applicable Document(s)	Edition / Revision
1	UL 60730-2-6 Automated Electrical Controls - Part 2-6	Revision	4		
2		December 2, 2024	5		
3			6		

The following tests were performed: Pressure test at 5 (five) times 5Mpa (725.2 psig) = 25 Mpa = 3626 psig which meets UL 60730-2-6 Clause 18.102

*****Table 3 Quality Program Verification and Manufacturing Sites**

Item No.	Location(s) Plant Name and Address / Site(s)	Quality Program Certificate Number	Expiry Date	Verifying Organization
1	Sensata Technologies (Changzhou) Co., Ltd. No. 18, Chuangxin Road, Xinbei District Changzhou City, Jiangsu, China, 213031	36568-2008-AQ-RGC-RVA	May 11, 2027	DNV - Business Assurance

A copy of the Quality Certificate from each manufacturing site must be included in accordance with CSA B51 paragraph 5.4.2.3 Parker Hannifin Corporation Sporlan Division is taking responsibility for the product manufactured at Sensata Technologies Inc.

As an official of the manufacturer with authority, and having responsibility for the conformity and regulatory compliance of the fittings, I hereby declare that the information and statements made in this declaration of conformity are true and accurate.

I declare, under our sole responsibility, that the design, construction, certification, and marking of the fitting(s) listed in Table 1*, are subject to a conformity assessment process and quality program that has been verified, as described in Table 3*.**


I certify that the fittings (s) listed in Table 1* conform to the provisions of the acts and regulations of the provinces and territories where the fitting(s) are registered; CSA B51; and the codes, standards, guidelines, or other applicable documents listed in Table 2**

I further declare that there is a process in place for the rotation of this declaration of conformity for not less than 10 years from the issuance of the Canadian Registration Number (CRN)

Signed for and on behalf of Sporlan Division of Parker Hannifin Corp. Washington, Missouri, USA
(Manufacturer) (City) (State / Province / Country)
John Withouse Sr. Principal Engineer [Signature] 2026-4-15
(Name, please print) (Function or Title) (Signature of Declarer) (Date)

Figure D.6 Declaration of Conformity form for application for registration of fittings in Canada (See Clauses 5.4.2 and D.1.)

CRN: 0F1472.9



**DECLARATION OF CONFORMITY
REGISTRATION OF FITTINGS
DÉCLARATION DE CONFORMITÉ
ENREGISTREMENT D'ACCESSOIRES**

Declaration No: <small>Unique identifier assigned by manufacturer</small>	R-2327B	Revision:	0
---	---------	------------------	---

Manufacturer	(Name and Address) Parker Hannifin Corporation - Sporlan Division 206 Lange Drive, Washington, Missouri 63090 USA
---------------------	--

***Table 1 Scope of Fitting Designs**

Item No	Type / Model / Size	Product Description	Material of Construction	MDMT	Rated Pressure			References: Catalog (pages) or Drawing(s) (revision level included)
					At Ambient Temperature	At Maximum Temperature		
1	PSPT Series	Pressure Transducer	Stainless Steel	-40F	652 psig	652 psig	at 257F	SD-362 / 82022
			ASTM A182		The above pressure is the maximum pressure. Transducers with a lower pressure range are available.			CRN Design Report R-2327B Rev. 0
			F304L					

****Table 2 Codes, Standards, Guidelines, and Other Applicable Documents**

Item No.	Title of Code(s), Standard(s), Guideline(s), or Other Applicable Document(s)	Edition / Revision	Item No.	Title of Code(s), Standard(s), Guideline(s), or Other Applicable Document(s)	Edition / Revision
1	UL 60730-2-6 Automated Electrical Controls	Revision	4		
2		December 2, 2024	5		
3			6		

The following tests were performed: Pressure test at 5 (five) times 5Mpa (725.2 psig) = 25 Mpa = 3626 psig which meets UL 60730-2-6 Clause 18.102

*****Table 3 Quality Program Verification and Manufacturing Sites**

Item No.	Location(s) Plant Name and Address / Site(s)	Quality Program Certificate Number	Expiry Date	Verifying Organization
1	Sensata Technologies (Changzhou) Co., Ltd. No. 18, Chuangxin Road, Xinbei District Changzhou City, Jiangsu, China, 213031	36568-2008-AQ-RGC-RvA	May 11, 2027	DNV - Business Assurance

A copy of the Quality Certificate from each manufacturing site must be included. In accordance with CSA B51 paragraph 5.4.2.3 Parker Hannifin Corporation Sporlan Division is taking responsibility for the product manufactured at Sensata Technologies Inc.

As an official of the manufacturer with authority, and having responsibility for the conformity and regulatory compliance of the fittings, I hereby declare that the information and statements made in this declaration of conformity are true and accurate.

I declare, under our sole responsibility, that the design, construction, certification, and marking of the fitting(s) listed in Table 1*, are subject to a conformity assessment process and quality program that has been verified, as described in Table 3**.

I certify that the fittings (s) listed in Table 1* conform to the provisions of the acts and regulations of the provinces and territories where the fitting(s) are registered; CSA B51; and the codes, standards, guidelines, or other applicable documents listed in Table 2**.

I further declare that there is a process in place for the retention of this declaration of conformity for not less than 10 years from the issuance of the Canadian Registration Number (CRN).

Signed for and on behalf of Sporlan Division of Parker Hannifin Corp., Washington, Missouri, USA

(Manufacturer) (City) (State / Province / Country)

John Withouse Sr. Principal Engineer John Withouse 2026-4-15

(Name, please print) (Function or Title) (Signature of Declarer) (Date)

Figure D.6 Declaration of Conformity form for application for registration of fittings in Canada (See Clauses 5.4.2 and D.1.)

CRN: 0F1472.9



**DECLARATION OF CONFORMITY
REGISTRATION OF FITTINGS
DÉCLARATION DE CONFORMITÉ
ENREGISTREMENT D'ACCESSOIRES**

Declaration No: <small>Unique identifier assigned by manufacturer</small>	R-2327B	VESSEL ACT. C.R.N. <u>DF1472.9T</u>	Revision:	0
---	---------	--	------------------	---

Manufacturer	<small>(Name and Address)</small> Parker Hannifin Corporation - Sporlan Division 206 Lange Drive, Washington, Missouri 63090 USA
---------------------	--

***Table 1 Scope of Fitting Designs**

Item No	Type / Model / Size	Product Description	Material of Construction	MDMT	Rated Pressure		References: Catalog (pages) or Drawing(s) (revision level included)
					At Ambient Temperature	At Maximum Temperature	
1	PSPT Series	Pressure Transducer	Stainless Steel	-40F	652 psig	652 psig at 257F	SD-362 / 82022
			ASTM A182		The above pressure is the maximum at pressure. Transducers with a lower pressure range are available.		CRN Design Report R-2327B Rev. 0
			F304L				

****Table 2 Codes, Standards, Guidelines, and Other Applicable Documents**

Item No.	Title of Code(s), Standard(s), Guideline(s), or Other Applicable Document(s)	Edition / Revision	Item No.	Title of Code(s), Standard(s), Guideline(s), or Other Applicable Document(s)	Edition / Revision
1	UL 60730-2-6 Automated Electrical Controls	Revision	4		
2		December 2, 2024	5		
3			6		

The following tests were performed: Pressure test at 5 (five) times 5Mpa (725.2 psig) = 25 Mpa = 3626 psig which meets UL 60730-2-6 Clause 18.102

*****Table 3 Quality Program Verification and Manufacturing Sites**

Item No.	Location(s) Plant Name and Address / Site(s)	Quality Program Certificate Number	Expiry Date	Verifying Organization
1	Sensata Technologies (Changzhou) Co., Ltd. No. 18, Chuangxin Road, Xinbei District Changzhou City, Jiangsu, China, 213031	36568-2008-AQ-RGC-RvA	May 11, 2027	DNV - Business Assurance

A copy of the Quality Certificate from each manufacturing site must be included. In accordance with CSA B51 paragraph 5.4.2.3 Parker Hannifin Corporation Sporlan Division is taking responsibility for the product manufactured at Sensata Technologies Inc.

As an official of the manufacturer with authority, and having responsibility for the conformity and regulatory compliance of the fittings, I hereby declare that the information and statements made in this declaration of conformity are true and accurate.

I declare, under our sole responsibility, that the design, construction, certification, and marking of the fitting(s) listed in Table 1*, are subject to a conformity assessment process and quality program that has been verified, as described in Table 3***.

I certify that the fittings (s) listed in Table 1* conform to the provisions of the acts and regulations of the provinces and territories where the fitting(s) are registered, CSA B51; and the codes, standards, guidelines, or other applicable documents listed in Table 2**.

I further declare that there is a process in place for the retention of this declaration of conformity for not less than 10 years from the issuance of the Canadian Registration Number (CRN).

Signed for and on behalf of Sporlan Division of Parker Hannifin Corp., Washington, Missouri, USA

(Manufacturer) (City) (State / Province / Country)

John Withouse, Sr. Principal Engineer, John Withouse, 2026-4-15

(Name, please print) (Function or Title) (Signature of Declarer) (Date)

Figure D.6 Declaration of Conformity form for application for registration of fittings in Canada (See Clauses 5.4.2 and D.1.)

CRN: 0F1472.9



**DECLARATION OF CONFORMITY
REGISTRATION OF FITTINGS
DÉCLARATION DE CONFORMITÉ
ENREGISTREMENT D'ACCESSOIRES**

Declaration No: <small>Unique Identifier assigned by manufacturer</small>	R-2327B	Revision:	0
---	---------	------------------	---

Manufacturer	(Name and Address) Parker Hannifin Corporation - Sporlan Division 206 Lange Drive, Washington, Missouri 63090 USA
---------------------	---

***Table 1 Scope of Fitting Designs**

Item No.	Type / Model / Size	Product Description	Material of Construction	MDMT	Rated Pressure			References: Catalog (pages) or Drawing(s) (revision level included)
					At Ambient Temperature	At Maximum Temperature		
1	PSPY Series	Pressure Transducer	Stainless Steel	-40F	652 psig	652 psig	at 257F	SD-362 / 82022
			ASTM A182 F304L		The above pressure is the maximum at pressure. Transducers with a lower pressure range are available.			CRN Design Report R-2327B Rev. 0

****Table 2 Codes, Standards, Guidelines, and Other Applicable Documents**

Item No.	Title of Code(s), Standard(s), Guideline(s), or Other Applicable Document(s)	Edition / Revision	Item No.	Title of Code(s), Standard(s), Guideline(s), or Other Applicable Document(s)	Edition / Revision
1	UL 60730-2-6 Automated Electrical Controls - Part 2-6	Revision	4		
2		December 2, 2024	5		
3			6		

The following tests were performed: Pressure test at 5 (five) times 5Mpa (725.2 psig) = 25 Mpa = 3626 psig which meets UL 60730-2-6 Clause 18.102

*****Table 3 Quality Program Verification and Manufacturing Sites**

Item No.	Location(s) Plant Name and Address / Site(s)	Quality Program Certificate Number	Expiry Date	Verifying Organization
1	Sensata Technologies (Changzhou) Co., Ltd. No. 18, Chuangxin Road, Xinbei District Changzhou City, Jiangsu, China, 213031	36568-2008-AQ-RGC-RVA	May 11, 2027	DNV - Business Assurance

A copy of the Quality Certificate from each manufacturing site must be included. In accordance with CSA B51 paragraph 5.4.2.3 Parker Hannifin Corporation Sporlan Division is taking responsibility for the product manufactured at Sensata Technologies Inc.

As an official of the manufacturer with authority, and having responsibility for the conformity and regulatory compliance of the fittings, I hereby declare that the information and statements made in this declaration of conformity are true and accurate.

I declare, under our sole responsibility, that the design, construction, certification, and marking of the fitting(s) listed in Table 1*, are subject to a conformity assessment process and quality program that has been verified, as described in Table 3***.

I certify that the fittings (s) listed in Table 1* conform to the provisions of the acts and regulations of the province and territories where the fittings are registered; CSA B51: and the codes, standards, guidelines, or other applicable documents listed in Table 2**.

I further declare that there is a process in place for the retention of this declaration of conformity for not less than 10 years from the issuance of the Canadian Registration Number (CRN).

Signed for and on behalf of Sporlan Division of Parker Hannifin Corp. Washington, Missouri, USA
(Manufacturer) (City) (State / Province) (Country)

John Withouse Sr. Principal Engineer
(Name, please print) (Function or Title)

2026-4-15
(Date)

REGISTERED
CRN 0F1472.9N
Date 05/10/2024

Territorial Registration Fee