



345 Carlingview Drive
Toronto, Ontario M9W 6N9
Tel.: 416.734.3300
Fax: 416.231.1626
Toll Free: 1.877.682.8772

www.tssa.org

June 30, 2026

ROUND ENGINEERING INC
10 SEGWUN RD
WATERDOWN ON L8B 0K6

Workorder Type: Registration - Fitting(Conventional)
Workorder No: 15065915
Your Reference No.: R-2384
Registered to: API HEAT TRANSFER

Dear SCOTT ISLIP,

Technical Standards and Safety Authority (TSSA) is pleased to inform you that your submission has been reviewed and registered as follows:

CRN : 0H26724.5
Main Design No.: 1568-05-072-000Rev6
Expiry Date: Jun 30, 2036

Please be advised that a valid quality control system must be maintained for the fitting registration to remain valid until the expiry date.

The stamped copy of the approved registration and the invoice are mailed separately (There will be no hard copies for electronic submissions). Should you have any questions or require further assistance, please contact a Customer Service Advisor at 1.877.682.TSSA (8772) or e-mail customerservices@tssa.org. We will be happy to assist you. When contacting TSSA regarding this file, please refer to the Service Request number provided above.

Yours truly,

Charley Dong
Engineer, BPV
Tel. : +1 416-734-3436
Email : cdong@tssa.org



Technical Standards & Safety Authority
 345 Carlingview Drive
 Toronto, Ontario
 M9W 6N9
 www.tssa.org

(Show facsimile of logo or trademark, as it will appear on the fitting as evidence of certification)



DECLARATION OF CONFORMITY REGISTRATION OF FITTINGS

H

Charley Dong
 June 30, 2026
 CRN expires on June 30, 2036
 Also see "Part of CRN"

Technical Standards and Safety Authority
 FOR TSSA OFFICE USE ONLY
 Boilers and Pressure Vessels Safety Program

REGISTERED

C.R.N.: 0H26724.5

Signed: *Charley Dong*

Date: June 30, 2026.

Declaration No.: (document nr. as issued by the manufacturer)

R-2384

Revision:

0

Manufacturer (Name and Address)

API Heat Transfer, 2777 Walden Avenue, Buffalo, New York, 14225, USA

***Table 1 Scope of Fitting Designs**

Item No.	Type / Model	Product Description	Material of Construction	MDMT	Rated Pressure		References: Catalog (pages) or Drawing(s)
					At Ambient Temperature	At Maximum Temperature	
1	Category H/ 5-Y-72-MAHTR-4-S-SS/ 5.56" Shell OD	Heat Exchanger	SA-312 TP316, SA-351-CF8M, SA-249-316, SA240-316	-20F	Shell side: 240 psig Tube Side: 160 psig	240 psig at 400F 160 psig at 400F at at	Drawing 1568-05-072-000 Rev. 6

****Table 2 Codes, Standards, Guidelines, and Other Applicable Documents**

Item No.	Title of Code(s), Standard(s), Guideline(s), or Other Applicable Document(s)	Edition / Revision	Item No.	Title of Code(s), Standard(s), Guideline(s), or Other Applicable Document(s)	Edition / Revision
1	ASME Section VIII-1	2025	4		
2			5		
3			6		

*****Table 3 Quality Program Verification and Manufacturing Sites**

Item No.	Location(s) Plant Name and Address / Site(s)	Quality Program Certificate Number	Expiry Date	Verifying Organization
1	Buffalo, New York, 14225, USA	4841	12/29/27	ASME
2				
3				

A copy of the Quality Certificate from each manufacturing site must be included.

Remarks	(other relevant information)
---------	------------------------------

As an official of the manufacturer with authority, and having responsibility for the conformity and regulatory compliance of the fittings, I hereby declare that the information and statements made in this declaration of conformity are true and accurate.

I declare, under our sole responsibility, that the design, construction, certification, and marking of the fitting(s) listed in Table 1*, are subject to a conformity assessment process and quality program that has been verified, as described in Table 3***.

I certify that the fittings (s) listed in Table 1* conform to: the provisions of the acts and regulations of the provinces and territories where the fitting(s) are registered; CSA B51; and the codes, standards, guidelines, or other applicable documents listed in Table 2**.

I further declare that there is a process in place for the retention of this declaration of conformity for not less than 10 years from the issuance of the Canadian Registration Number (CRN).

Signed for and on behalf of API Heat Transfer in the Buffalo of New York
 (Manufacturer) (City) (State / Province, Country)

Bruce Hindle, Director of Engineering *B. Hindle* 06/30/2026
 (Name, please print) (Function or Title) (Signature of Declarer) (Date)