Technical Safety Authority of Saskatchewan

2202 2nd Avenue
Regina, SK S4R 1K3 Canada
1 (866) 530-8599
info@tsask.ca
www.tsask.ca

REGISTRATION OF A PRESSURE FITTING DESIGN

October 22, 2026

Round Engineering Inc.
10 Segwun Road
Waterdown, ON
Canada
L8B 0K6

Attention: Scott Islip **File Number: 105846**

Re: Manufacturer: **Conex Universal Limited**

Item: **Piping fittings**

Catalog or Drawing: **SCOPE OF CRN REGISTRATION, Dated August 31, 2026**

TSASK Codes and Standards Compliance has registered the design listed above in accordance with The Boiler and Pressure Vessel Act and Regulations and CSA B51. The Canadian Registration Number (CRN) is:

0A1489.93 **Expiry Date: 2036-09-11**

Please note that every fitting shall be constructed in strict accordance with the registered design.

Fitting registrations are required to be resubmitted for validation after ten (10) years from the registration date in accordance with CSA B51, Clause 4.2.1.

Should you require anything further, please do not hesitate to contact the Codes and Standards Compliance Office at your convenience.

Yours truly,

Williams Uju, P.Eng.

Codes and Standards Compliance

Remarks:

A valid quality control program must be maintained at the production facility for the fitting registration to remain valid until the expiry date.

Figure D.6
Declaration of Conformity form for application for registration of fittings in Canada
(See Clauses 5.4.2 and D.1.)

(Show facsimile of logo or trademark, as it will appear on the fitting as evidence of certification)

Conex Bänninger >B< MaxiPro OR Parker ZoomLock MAX

Technical Safety Authority of Saskatchewan
Registration No. 0A1489.93
File No. 105846
Registered
Date: October 22, 2026
Expiry Date: September 11, 2036
Codes & Standards Compliance Office

DECLARATION OF CONFORMITY
REGISTRATION OF FITTINGS
DÉCLARATION DE CONFORMITÉ
ENREGISTREMENT D'ACCESSOIRES

Declaration No: Unique identifier assigned by manufacturer	R-2372A	**Revision:**	0

Manufacturer	(Name and Address) Conex Universal Limited, Global House, 95 Vantage Point, The Pensnett Estate, Kingswinford, DY6 7FT, United Kingdon

***Table 1 Scope of Fitting Designs** SEE ATTACHED SCOPE OF CRN REGISTRATION

Item No.	Type / Model / Size	Product Description	Material of Construction	MDMT	Rated Pressure: At Ambient Temperature	Rated Pressure: At Maximum Temperature	References: Catalog (pages) or Drawing(s) (revision level included)
1	Category A / >B< Maxipro or ZoomLock 1/4",5/16",3/8" 1/2",5/8",3/4" 7/8", 1-1/8", 1-3/8", 1-5/8", 2-1/8"	Press Fittings	Copper Cu-DHP R290 In Accordance with EN 12735-1	-40F	AS PER ADDTIONAL SHEETS ATTACHED TO FORM	at	CRN Design Report R-2372A Rev. 0

****Table 2 Codes, Standards, Guidelines, and Other Applicable Documents**

Item No.	Title of Code(s), Standard(s), Guideline(s), or Other Applicable Document(s)	Edition / Revision	Item No.	Title of Code(s), Standard(s), Guideline(s), or Other Applicable Document(s)	Edition / Revision
1	ASME B31.5	2022	4		
2			5		
3			6		

*****Table 3 Quality Program Verification and Manufacturing Sites** SEE ATTACHED WORLDWIDE LOCATIONS APPENDIX

Item No.	Location(s) Plant Name and Address / Site(s)	Quality Program Certificate Number	Expiry Date	Verifying Organization
1	United Kingdom	FM 578065	2029-09-12	bsi
2	Spain	FM 27094	2027-07-01	bsi
3	Poland	FM 39649	2027-11-12	bsi

A copy of the Quality Certificate from each manufacturing site must be included.

As an official of the manufacturer with authority, and having responsibility for the conformity and regulatory compliance of the fittings, I hereby declare that the information and statements made in this declaration of conformity are true and accurate.

I declare, under our sole responsibility, that the design, construction, certification, and marking of the fitting(s) listed in Table 1*, are subject to a conformity assessment process and quality program that has been verified, as described in Table 3***.

I certify that the fittings (s) listed in Table 1* conform to: the provisions of the acts and regulations of the provinces and territories where the fitting(s) are registered; CSA B51; and the codes, standards, guidelines, or other applicable documents listed in Table 2**.

I further declare that there is a process in place for the retention of this declaration of conformity for not less than 10 years from the issuance of the Canadian Registration Number (CRN).

Signed for and on behalf of Conex Universal Limited (Manufacturer), Denton (City), Texas (State / Province / Country)

Amith Venkatesh (Name, please print), Technical Product Manager (Function or Title), Amith Venkatesh (Signature of Declarer), 10/15/2026 (Date)

CONEX UNIVERSAL LIMITED
GLOBAL HOUSE
95 VANTAGE POINT,
THE PENSNETT ESTATE
KINGSWINFORD, DY6 7FT,
UNITED KINGDOM

Conex Bänninger

Technical Safety Authority of Saskatchewan
Registration No. 0A1489.93
File No. 105846
Registered
Date: October 22, 2026
Expiry Date: September 11, 2036
Codes & Standards Compliance Office

SCOPE OF CRN REGISTRATION

Product Description	Design Code	Fitting Material Specification	
>B< MaxiPro Press Fittings **(Note 5)**	ASME B31.5, 2022	Refrigerant Grade Copper Cu-DHP R290 in accordance with EN 12735-1	
Product Size	**MAWP at MAWT**	**MDMT**	**Report Number**
1/4"	700 psig at 250°F	- 40°F	R-2372A Rev. 0
5/16"	700 psig at 250°F		
3/8"	700 psig at 250°F		
1/2"	700 psig at 250°F		
5/8"	700 psig at 250°F		
3/4"	700 psig at 250°F		
7/8"	700 psig at 250°F		
1-1/8"	700 psig at 250°F		
1-3/8"	700 psig at 250°F		
1-5/8"	700 psig at 100°F, 623 psig at 250°F		
2-1/8"	700 psig at 100°F, 623 psig at 250°F		

Note 1: MAWP = Maximum Allowable Working Pressure, MAWT = Maximum Allowable Working Temperature, MDMT = Minimum Design Metal Temperature.

Note 2: The fittings shall meet all applicable construction and testing requirements of CSA B52 and/or ASME B31.5. The fittings shall be adequate and safe for the design conditions.

Note 3: The MAWP of the >B< MaxiPro fittings may be limited by the pressure rating of the tube that the fittings are installed on. The piping designer / installer shall ensure that the tube the fittings are installed on is suitable for the systems operating pressures and temperatures.

Note 4: See attached Worldwide Locations Appendix for manufacturing locations.

CONTINUED NEXT PAGE

CONEX UNIVERSAL LIMITED
GLOBAL HOUSE
95 VANTAGE POINT,
THE PENSNETT ESTATE
KINGSWINFORD, DY6 7FT,
UNITED KINGDOM

SCOPE OF CRN REGISTRATION

Note 5: This CRN is valid for the following listed fitting Model Codes.

Description	Code	Size
MPA5001 90° Street Bend	MPA5001 5160001	5/16"
	MPA5001 0030001	3/8"
	MPA5001 0040001	1/2"
	MPA5001 0050001	5/8"
	MPA5001 0060001	3/4"
	MPA5001 0070001	7/8"
	MPA5001 0090001	1-1/8"
	MPA5001 0110001	1-3/8"
	MPA5001 0130001	1-5/8"
	MPA5001 0170001	2 1/8"
MPA5002 90° Bend	MPA5002 0020001	1/4"
	MPA5002 5160001	5/16"
	MPA5002 0030001	3/8"
	MPA5002 0040001	1/2"
	MPA5002 0050001	5/8"
	MPA5002 0060001	3/4"
	MPA5002 0070001	7/8"
	MPA5002 0090001	1-1/8"
	MPA5002 0110001	1-3/8"
MPA5002L 90° Bend	MPA5002L0040001	1/2"
	MPA5002L0050001	5/8"
	MPA5002L0060001	3/4"
	MPA5002L0070001	7/8"
	MPA5002L0090001	1-1/8"
	MPA5002L0110001	1-3/8"
	MPA5002L0130001	1-5/8"
	MPA5002L0170001	2-1/8"

Description	Code	Size
MPA5041 45 Obtuse Elbow	MPA5041 0020001	1/4"
	MPA5041 5160001	5/16"
	MPA5041 0030001	3/8"
	MPA5041 0040001	1/2"
	MPA5041 0050001	5/8"
	MPA5041 0060001	3/4"
	MPA5041 0070001	7/8"
	MPA5041 0090001	1-1/8"
	MPA5041 0110001	1-3/8"
	MPA5041 0130001	1-5/8"
	MPA5041 0170001	2-1/8"
MPA5240 Reducing Coupler	MPA5240 0030201	3/8" x 1/4"
	MPA5240 0035161	3/8" x 5/16"
	MPA5240 0040201	1/2" x 1/4"
	MPA5240 0040301	1/2" x 3/8"
	MPA5240 0050201	5/8" x 1/4"
	MPA5240 0050301	5/8" x 3/8"
	MPA5240 0050401	5/8" x 1/2"
	MPA5240 0060301	3/4" x 3/8"
	MPA5240 0060401	3/4" x 1/2"
	MPA5240 0060501	3/4" x 5/8"
	MPA5240 0070401	7/8" x 1/2"
	MPA5240 0070501	7/8" x 5/8"
	MPA5240 0070601	7/8" x 3/4"
	MPA5240 0090501	1 1/8" x 5/8"
	MPA5240 0090601	1 1/8" x 3/4"
	MPA5240 0090701	1 1/8" x 7/8"
	MPA5240 0110701	1 3/8" x 7/8"
	MPA5240 0110901	1 3/8" x 1 1/8"
	MPA5240 0130901	1 5/8" x 1 1/8"

CONTINUED NEXT PAGE

CONEX UNIVERSAL LIMITED
GLOBAL HOUSE
95 VANTAGE POINT,
THE PENSNETT ESTATE
KINGSWINFORD, DY6 7FT,
UNITED KINGDOM

Conex Bänninger

SCOPE OF CRN REGISTRATION

Description	Code	Size	Description	Code	Size
MPA5240 Reducing Coupler	MPA5240 0131101	1 5/8 x 1 3/8"	MPA5270 Straight Coupler	MPA5270 0020001	1/4"
	MPA5240 0171101	2 1/8" x 1 3/8"		MPA5270 5160001	5/16"
	MPA5240 0171301	2 1/8" x 1 5/8"		MPA5270 0030001	3/8"
MPA5240L Long Reducing Coupler	MPA5240L0030201	3/8" x 1/4"		MPA5270 0040001	1/2"
	MPA5240L0050301	5/8" x 3/8"		MPA5270 0050001	5/8"
	MPA5240L0050401	5/8" x 1/2"		MPA5270 0060001	3/4"
MPA5243 Fitting Reducer	MPA5243 5160201	5/16" x 1/4"		MPA5270 0070001	7/8"
	MPA5243 0055161	5/8" x 5/16"		MPA5270 0090001	1-1/8"
	MPA5243 0030201	3/8" x 1/4"		MPA5270 0110001	1-3/8"
	MPA5243 0040301	1/2" x 3/8"		MPA5270 0130001	1-5/8"
	MPA5243 0050301	5/8" x 3/8"		MPA5270 0170001	2-1/8"
	MPA5243 0050401	5/8" x 1/2"	MPA5270L Long Coupler	MPA5270L0020001	1/4"
	MPA5243 0060401	3/4" x 1/2"		MPA5270L0030001	3/8"
	MPA5243 0060501	3/4" x 5/8"		MPA5270L0040001	1/2"
	MPA5243 0070401	7/8" x 1/2"		MPA5270L0050001	5/8"
	MPA5243 0070501	7/8" x 5/8"		MPA5270L0060001	3/4"
	MPA5243 0070601	7/8" x 3/4"		MPA5270L0070001	7/8"
	MPA5243 0090401	1-1/8" x 1/2"		MPA5270L0090001	1-1/8"
	MPA5243 0090501	1-1/8" x 5/8"		MPA5270L0110001	1-3/8"
	MPA5243 0090601	1-1/8" x 3/4"		MPA5270L0130001	1-5/8"
	MPA5243 0090 701	1-1/8" x 7/8"		MPA5270L0170001	2-1/8"
	MPA5243 0110701	1-3/8" x 7/8"	MPA5275L Long Repair Coupler	MPA5275L0020001	1/4"
	MPA5243 0110901	1-3/8" x 1-1/8"		MPA5275L0030001	3/8"
	MPA5243 0130901	1-5/8" x 1-1/8"		MPA5275L0040001	1/2"
	MPA5243 0131101	1-5/8 x 1-3/8"		MPA5275L0050001	5/8"
	MPA5243 0171101	2-1/8" x 1-3/8"		MPA5275L0060001	3/4"
	MPA5243 0171301	2-1/8" x 1-5/8"		MPA5275L0070001	7/8"
				MPA5275L0090001	1-1/8"
				MPA5275L0110001	1-3/8"
				MPA5275L0130001	1-5/8"
				MPA5275L0170001	2-1/8"

CONTINUED NEXT PAGE

CONEX UNIVERSAL LIMITED
GLOBAL HOUSE
95 VANTAGE POINT,
THE PENSNETT ESTATE
KINGSWINFORD, DY6 7FT,
UNITED KINGDOM

Conex Bänninger

SCOPE OF CRN REGISTRATION

Description	Code	Size	Description	Code	Size
MPA5285G SAE Copper Formed Flare - Brass Nut	MPA5285G0020201	1/4"	MPA5T Equal Tee	MPA5T 002020201	1/4"
	MPA5285G0030301	3/8"		MPA5T5165165161	5/16"
	MPA5285G0040401	1/2"		MPA5T 003030301	3/8"
	MPA5285G0050501	5/8"		MPA5T 004040401	1/2"
	MPA5285G0060601	3/4"		MPA5T 005050501	5/8"
MPA5286G SAE Stainless Machined Flare - Brass Nut - Copper Washer	MPA5286G0020201	1/4"		MPA5T 006060601	3/4"
	MPA5286G0030301	3/8"		MPA5T 007070701	7/8"
	MPA5286G0040401	1/2"		MPA5T 009090901	1-1/8"
	MPA5286G0050501	5/8"		MPA5T 011111101	1-3/8"
	MPA5286G0060601	3/4"		MPA5T 013131301	1-5/8"
MPA5289G SAE Stainless Machined Flare - Stainless Nut - Copper Washer	MPA5289G0020201	1/4"		MPA5T 017171701	2 1/8"
	MPA5289G0030301	3/8"	MPA5698 P-Trap	MPA5698 0050001	5/8"
	MPA5289G0040401	1/2"		MPA5698 0060001	3/4"
	MPA5289G0050501	5/8"		MPA5698 0070001	7/8"
	MPA5289G0060601	3/4"		MPA5698 0090001	1-1/8"
MPA5301 Stop End	MPA5301 0020001	1/4"	MPA5R >B< Flow Y-Joint (with insulation)	MPBF5 0030303F1	3/8"
	MPA5301 5160001	5/16"		MPBF5 0040404F1	1/2"
	MPA5301 0030001	3/8"		MPBF5 0050505F1	5/8"
	MPA5301 0040001	1/2"		MPBF5 0060606F1	3/4"
	MPA5301 0050001	5/8"		MPBF5 0070707F1	7/8"
	MPA5301 0060001	3/4"		MPBF5 0090909F1	1-1/8"
	MPA5301 0070001	7/8"	MPA5R >B< Flow Y-Joint (without insulation)	MPBF5 003030301	3/8"
	MPA5301 0090001	1-1/8"		MPBF5 004040401	1/2"
	MPA5301 0110001	1-3/8"		MPBF5 005050501	5/8"
	MPA5301 0130001	1-5/8"		MPBF5 006060601	3/4"
	MPA5301 0170001	2 1/8"		MPBF5 007070701	7/8"
				MPBF5 009090901	1-1/8"
				MPBF5 011111101	1-3/8"
				MPBF5 013131301	1-5/8"

WORLDWIDE LOCATIONS APPENDIX

MANUFACTURING LOCATIONS & CERTIFYING AUTHORITIES

(rev. August 31, 2026)

Conex Universal Limited
Global House,
95 Vantage Point,
The Pensnett Estate,
Kingswinford,
DY6 7FT,
United Kingdom
ISO 9001 Certified by BSI (FM 578065)

IBP Atcosa
Poligono Industrial Quintos-Aeropuerto,
Apartado de Correos 16,
Cordoba,
14080,
Spain
ISO 9001 Certified by BSI (FM 27094)

IBP Instalfittings Polska Sp. Z o.o.,
ul. Stanislawa Zwierzchowskiego 29
Poznan
61-249
Poland
ISO 9001 Certified by BSI (FM 39649)

IBP Instalfittings Sp. z o.o.,
ul. Za Motelem 2A,
Sady/Tarnowo Podgórne
62-080
Poland
ISO 9001 Certified by BSI (FM 39649)