



345 Carlingview Drive  
Toronto, Ontario M9W 6N9  
Tel.: 416.734.3300  
Fax: 416.231.1626  
Toll Free: 1.877.682.8772  
[www.tssa.org](http://www.tssa.org)

January 08, 2019

SCOTT ISLIP  
ROUND ENGINEERING INC  
10 SEGWUN RD  
WATERDOWN ON L8B 0K6  
CA

Service Request Type: BPV-Piping registration  
Service Request No.: 2462000  
Your Reference No.: R-1030  
Install At: PLAINS MIDSTREAM CANADA  
4300 MATCHETTE RD, WINDSOR ON N9C 0C4 CA

Dear SCOTT ISLIP,

Technical Standards and Safety Authority (TSSA) is pleased to inform you that your submission has been reviewed and registered as follows:

**CRN No.:** P46470  
**Main Design No.:** PID-2018-032-01 REV A, GA-2018-032-01/02/03 REV 1,  
Pipe Specification R-1030

- The system is subject to inspection. Before commencing the system installation, please contact your authorized inspector.
- The CRN covers the piping system only and does not include registration of boilers, pressure vessels and fittings required under the Technical Standards and Safety Act, 2000 (the Act), Boilers and Pressure Vessels Regulations.
- Welding/brazing procedures and welders/brazers are to be approved by the Technical Standards and Safety Authority, Boilers and Pressure Vessels Safety Program. Boning procedures and performance qualifications shall be accepted by authorized inspector.
- All manufacturers and installers of pressure piping parts and systems must hold a valid Certificate of Authorization for piping from TSSA.

The stamped copy of the approved registration and the invoice are mailed separately. Should you have any questions or require further assistance, please contact a Customer Service Advisor at 1.877.682.TSSA (8772) or e-mail [customerservices@tssa.org](mailto:customerservices@tssa.org). We will be happy to assist you. When contacting TSSA regarding this file, please refer to the Service Request number provided above.

Yours truly,

Ruiming You, P.Eng.  
Mechanical Engineer, BPV  
Tel.: 416-734-3428  
Fax: 416-231-6183  
Email: [ryou@tssa.org](mailto:ryou@tssa.org)