

## REGISTRATION OF A BOILER OR PRESSURE VESSEL DESIGN

19-May-22

TSSA  
345 Carlingview Drive  
Toronto, Ontario  
M9W 6N9

**Attention: Tanya Francis**

**File Number: 62998 [ 0V]**

**Re: Manufacturer: Armstrong-Hunt, Inc.**  
**Item: Constantcoil Heat Exchanger Housing (E300)**  
**Drawing Number: A68439 REF Rev. A & A68438 REF Rev. B**

TSASK Codes and Standards Compliance has registered the design listed above in accordance with The Boiler and Pressure Vessel Act and Regulations. The Canadian Registration Number (CRN) is:

**R6274.53**

This item was registered with the following design conditions:

<b>MAWP:</b>	<b>517 kPa</b>	<b>Design Temp:</b>	<b>160 °C</b>
<b>MDMT:</b>	<b>-29 °C</b>	<b>Corrosion Allowance:</b>	<b>0 mm</b>

Please note that every piece of equipment must be constructed in strict accordance with the registered design.

In addition to stamping every unit with the CRN given, and as required in CSA B51, a Manufacturer's Data Report shall be forwarded to this office at the time the unit is shipped. The Manufacturer's Data Report form is available on the TSASK website at [www.tsask.ca](http://www.tsask.ca).

Should you require anything further, please do not hesitate to contact the Codes and Standards Compliance Office at your convenience.

Yours truly,



Athan Syrgiannis, P.Eng.  
Codes and Standards Compliance

### Remarks:

The scope of this registration covers the transfer of CRN ownership from the original manufacturer Leslie Controls to Armstrong-Hunt, Inc.

No change to the original design.

This registration also includes Design Report Number R-0905 E300 DI.